

CERTIFICATE OF COMPLIANCE

Certificate Number 20140128-E1200258
Report Reference E120058-20140127
Issue Date 2014-JANUARY-28

Issued to: MEASUREMENT TECHNOLOGY LTD
GREAT MARLINGS
BUTTERFIELD
LUTON
LU2 8DL UNITED KINGDOM

This is to certify that representative samples of PROCESS CONTROL EQUIPMENT FOR USE IN HAZARDOUS LOCATIONS
Models/Product

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 61010-1, Safety requirements for electrical equipment for measurement, control, and laboratory use - part 1: general requirements
ANSI/ISA 12.12.01, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
UL 913, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations
UL 60079-0, Explosive atmospheres – Part 0: Equipment – General requirements
UL 60079-11, Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.




William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20140128-E1200258
Report Reference E120058-20140127
Issue Date 2014-JANUARY-28

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, Associated Apparatus for use in Unclassified Locations or Class I, Division 2, Groups A, B, C, D Hazardous Locations.

Models MTL4541S, MTL4544S, MTL4544D, MTL5541S, MTL5544S and MTL5544D provide intrinsically safe outputs for use in Class I, Groups A, B, C, D; Class II, Groups E, F, G; Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. SCI-1063.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

