

CERTIFICATE OF COMPLIANCE

Certificate Number 20140321-E120058
Report Reference E120058-20140317
Issue Date 2014-MARCH-21

Issued to: MEASUREMENT TECHNOLOGY LTD
GREAT MARLINGS
BUTTERFIELD
LUTON
LU2 8DL UNITED KINGDOM

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS


USL, Associated Apparatus for use in Unclassified
Locations or Class I, Division 2, Groups A, B, C, D
Hazardous Locations.

Models MTL4510, MTL4510B, MTL4513, MTL5510,
MTL5510B and MTL5513 provide intrinsically safe outputs
for use in Class I, Groups A, B, C, D; Class II, Groups E, F,
G; Class III Hazardous Locations when installed in
accordance with manufacturer's control drawing no. SCI-
1033.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum page
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20140321-E120058
Report Reference E120058-20140317
Issue Date 2014-MARCH-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

UL 61010-1-Safety requirements for electrical equipment for measurement, control, and laboratory use - part 1: general requirements,
ANSI/ISA 12.12.01-Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations,
UL 913-Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations,
UL 60079-0-Explosive atmospheres – Part 0: Equipment – General requirements,
UL 60079-11-Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

