



Factory Mutual Research

1151 Boston-Providence Turnpike
P.O. Box 9102
Norwood, Massachusetts 02062

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following company:

Measurement Technology Limited
Power Court, Luton
Bedfordshire, England LU1 3JJ

For:

ANALOG MULTIPLEXER TRANSMITTER. Model MTL831B

IS/II/1/ABCD - SCI-245/5; Entity
NI/II/2/ABCD

Max. Entity Parameters: Per installation drawing.

Equipment Ratings: Intrinsically Safe apparatus for Class I, Division 1, Group A, B, C and D in accordance with entity requirements and MTL Installation Drawing SCI-245; nonincendive for Class I, Division 2, Group A, B, C and D hazardous indoor locations.

Manufactured By: Measurement Technology Limited
Power Court, Luton
Bedfordshire, England LU1 3JJ

FACTORY MUTUAL RESEARCH CORPORATION

This certifies that the equipment described has been found to comply with the following Factory Mutual Research Corporation Approval Standards:

Approval Standard Class 3600 - 1989
Approval Standard Class 3610 - 1988
Approval Standard Class 3611 - 1986
Approval Standard Class 3810 - 1989

Approval Job Identification: 5B0A8.AX Issue Date: September 2, 1997

Related Approval Job Identification: None.

Subsequent Revision Reports/Date Approval Amended: None


Factory Mutual Research Corporation



Frank J. McGowan, Manager
Instrumentation Section
Approval Division

10/1/97
Date

MEASUREMENT TECHNOLOGY LTD. Luton, England.			
4	3.92	P.S.	MTL 831B added.
5	9.96	P.S.	
Copyright Reserved - Written Permission to Copy Should be Obtained			
Chk	Modification		
1	11.89/DRG		
2	11.90 DRG.		
3	12.90 ACW	See Sheet 9	
Iss	Date Drawn		



Certifying Authority : FACTORY MUTUAL

Scale

Tolerance unless otherwise stated ±

Sheet 1 of 10

Title INSTALLATION FOR THE MTL 831 & 831B MULTIPLEXER TRANSMITTER


Drq. No.

SCI - 245

Size A4


Size A4

MEASUREMENT TECHNOLOGY LTD. Luton, England.		4	3.92	P.S.	MTL 831B added.
Copyright Reserved - Written Permission to Copy Should be Obtained		5	9.96	P.S.	
Iss.	Date Drawn	1	11.89	DRG.	
		2	11.90	DRG.	
		3	12.90	ACTV	See Sheet 9
Modification		Chk			




Certifying Authority: FACTORY MUTUAL				Scale	
Tolerance (unless otherwise stated)				Sheet 3 of 10	
Title: INSTALLATION FOR THE MTL 831 & 831B MULTIPLEXER TRANSMITTER				Dwg. No. SCI - 245	

MEASUREMENT TECHNOLOGY LTD. Luton, England.	4	3-92	P.S.	MTL 831B added.
Copyright Reserved - Written Permission to Copy Should be Obtained	5	9-96	P.S.	
Modification	1	11-89/DRG.		
	2	11-90 DRG.		
	3	12-90 Acw		
See Sheet 9				




Certifying Authority : FACTORY MUTUAL		Scale
Tolerance unless otherwise stated ±		Sheet 5 of 10
Title INSTALLATION FOR THE MTL 831 & 831B MULTIPLEXER TRANSMITTER		Drq. No. SCI-245

MEASUREMENT TECHNOLOGY LTD.	4	3.92 P.S.	MTL 831B added.
	5	9.96 P.S.	
Copyright Reserved - Written Permission to Copy Should be Obtained			
Iss	Date Drawn	Modification	Chk
1	11.89/DRE.		
2	11.90 DRE		
3	12.90 ACW	See Sheet 9	



Certifying Authority FACTORY MUTUAL		Scale
Tolerance unless otherwise stated		Sheet 6 of 10
Title INSTALLATION FOR THE MTL 831 & 831B MULTIPLEXER TRANSMITTER		Drq. No. SC1 - 245

Iss.	Date/Drawn	Modification	Chk	Copyright Reserved - Written Permission to Copy Should be Obtained	MEASUREMENT TECHNOLOGY LTD. Luton, England.	4	392 P.S.	MTL 831B added.
						5	9.96 P.S.	
1	11.89/DRG							
2	11.90 DRG							
3	12.00 ACW							



Note 1 The Non-Hazardous Location or Control Room mounted equipment should not use or generate more than 250 volts rms.

Note 2 The Hazardous Location mounted equipment may be switches. Other apparatus such as THCs, switches and non-inductive resistors may be used if the auto-ignition temperature of the hazardous location is greater than T4 (135°C.275°F). Certified devices with the correct Entity Conect parameters may also be used.

Note 3 When there is a ground connection then the circuit in the Hazardous Location must be capable of withstanding a test voltage of 500 volts rms with respect to ground or frame of the apparatus for a period of one minute without breakdown (dc resistance and impedance at 60Hz shall not be less than 100K). Otherwise there is no need for this requirement.

Note 4 The following cable parameters must not be exceeded.

Group	Capacitance μF	Inductance mH
A + B	0.8	120
C	2.4	360
D	6.4	960


Certifying Authority: FACTORY MUTUAL		Scale N/A
Tolerance unless otherwise stated $\pm$		Sheet 7 of 10
Title INSTALLATION FOR THE MTL 831 & 831B MULTIPLEXER TRANSMITTER		Drg. No. SCI-245

MEASUREMENT TECHNOLOGY LTD. Luton, England.			Dimensions in mm	Do not Scale	Third Angle Projection												
Copyright Reserved - Written Permission to Copy Should be Obtained 4 3.92 P.S.			<u>Note 5</u>														
			<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 20%;">Group</th> <th style="width: 40%;">Capacitance μF</th> <th style="width: 40%;">Inductance mH</th> </tr> </thead> <tbody> <tr> <td>A + B</td> <td>0.11</td> <td>1.3</td> </tr> <tr> <td>C</td> <td>0.33</td> <td>3.9</td> </tr> <tr> <td>D</td> <td>0.88</td> <td>10.4</td> </tr> </tbody> </table>			Group	Capacitance μF	Inductance mH	A + B	0.11	1.3	C	0.33	3.9	D	0.88	10.4
			Group	Capacitance μF	Inductance mH												
			A + B	0.11	1.3												
C	0.33	3.9															
D	0.88	10.4															
<u>Note 6</u>																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 20%;">Group</th> <th style="width: 40%;">Capacitance μF</th> <th style="width: 40%;">Inductance mH</th> </tr> </thead> <tbody> <tr> <td>C</td> <td>0.33</td> <td>1.75</td> </tr> <tr> <td>D</td> <td>0.88</td> <td>4.6</td> </tr> </tbody> </table>			Group	Capacitance μF	Inductance mH	C	0.33	1.75	D	0.88	4.6						
Group	Capacitance μF	Inductance mH															
C	0.33	1.75															
D	0.88	4.6															
<u>Note 7</u>																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 20%;">Group</th> <th style="width: 40%;">Capacitance μF</th> <th style="width: 40%;">Inductance mH</th> </tr> </thead> <tbody> <tr> <td>A + B</td> <td>0.75</td> <td>5.2</td> </tr> <tr> <td>C</td> <td>2.25</td> <td>15.6</td> </tr> <tr> <td>D</td> <td>6.00</td> <td>41.6</td> </tr> </tbody> </table>			Group	Capacitance μF	Inductance mH	A + B	0.75	5.2	C	2.25	15.6	D	6.00	41.6			
Group	Capacitance μF	Inductance mH															
A + B	0.75	5.2															
C	2.25	15.6															
D	6.00	41.6															
<u>Note 8</u>			The following cable parameters must not be exceeded (MTL 715):-														
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 20%;">Group</th> <th style="width: 40%;">Capacitance μF</th> <th style="width: 40%;">Inductance mH</th> </tr> </thead> <tbody> <tr> <td>A + B</td> <td>0.75</td> <td>1.65</td> </tr> <tr> <td>C</td> <td>2.25</td> <td>4.95</td> </tr> <tr> <td>D</td> <td>6.0</td> <td>13.2</td> </tr> </tbody> </table>			Group	Capacitance μF	Inductance mH	A + B	0.75	1.65	C	2.25	4.95	D	6.0	13.2			
Group	Capacitance μF	Inductance mH															
A + B	0.75	1.65															
C	2.25	4.95															
D	6.0	13.2															
<u>Note 9</u>			The following cable parameters must not be exceeded (MTL 767):-														
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 20%;">Group</th> <th style="width: 40%;">Capacitance μF</th> <th style="width: 40%;">Inductance mH</th> </tr> </thead> <tbody> <tr> <td>A + B</td> <td>0.5</td> <td>0.32</td> </tr> <tr> <td>C</td> <td>1.5</td> <td>0.96</td> </tr> <tr> <td>D</td> <td>4.0</td> <td>2.56</td> </tr> </tbody> </table>			Group	Capacitance μF	Inductance mH	A + B	0.5	0.32	C	1.5	0.96	D	4.0	2.56			
Group	Capacitance μF	Inductance mH															
A + B	0.5	0.32															
C	1.5	0.96															
D	4.0	2.56															
<u>Note 10</u>			The MTL 715 may be replaced by $\frac{1}{2}$ MTL 767. In this case the connection shown to terminal 4 must be taken separately to the busbar.														
<u>Note 11</u>			An additional MTL 831 Multiplexer may be connected in parallel with H1+ and H1- without affecting the cable parameters.														
<u>Note 12</u>			The MTL 767 may be replaced by two MTL 715 barriers of the same polarity.														
<u>Note 13</u>			An additional MTL 831 Multiplexer may be connected in parallel with H1+, H2+, H1- and H2- without affecting the cable parameters.														
Modification Chk			Certifying Authority : FACTORY MUTUAL		Scale N/A												
			Tolerance unless otherwise stated $\pm$		Sheet 8 of 10												
			Title INSTALLATION FOR THE MTL 831 MULTIPLEXER TRANSMITTER		Drg. No. SCI-245												
Iss.	1 11.89/DRG	2 11.90 DRG	3 12.90 ACW	See Sheet 9													

Ckd		CL		No		Modification		Date Dwn		Is													
MEASUREMENT TECHNOLOGY LTD Luton, England Copyright Reserved - Written Permission to Copy Should be Obtained																							
Ckd		CL		No		Modification		Date Dwn		Is													
1		11.89		DRG																			
2		11.90		DRG																			
3		12.90		ACW																			
4		3.92		PS																			
Dimensions in mm Do Not Scale Third Angle Projection <u>Note 14</u> For single highway operation, the busbar connections to the transmitter may be omitted and H1- connected to terminal 4 on the MTL 767 in place of H2+. <u>Note 15</u> Where the hazardous location cable is part of a multicore, it must comply with the requirements of ANSI/ISA RP12.6. <u>Note 16</u> For guidance on the installation see ANSI/ISA RP12.6. <u>Note 17</u> When all the inputs I1 to I16 are interconnected the following cable parameters must not be exceeded:- <table border="1"> <thead> <tr> <th>Group</th> <th>Capacitance μF</th> <th>Inductance mH</th> </tr> </thead> <tbody> <tr> <td>A + B</td> <td>0.8</td> <td>35</td> </tr> <tr> <td>C</td> <td>2.4</td> <td>105</td> </tr> <tr> <td>D</td> <td>6.4</td> <td>280</td> </tr> </tbody> </table> <u>Note 18</u> The input circuit of the MTL 831 may be connected as shown on sheet 10 when the cable parameters in Note 17 above apply. This input circuit can be used for all the circuit configurations shown elsewhere on this drawing. <u>Note 19</u> When a single barrier or interface is connected to H1+ and H1- or H2+ and H2-, the Entity Parameters are $V_{max} = 30\text{volts}$, $I_{max} = 300\text{mA}$, $P_{max} = 1.2\text{W}$, $C_i = 0\text{nF}$, $L_i = 0\text{mH}$. When two barriers or interfaces are connected, one to H1+ and H1-, one to H2+ and H2-, the Entity Parameters are $V_{max} = 20\text{volts}$, $I_{max} = 150\text{mA}$, $P_{max} = 1.2\text{W}$, $C_i = 0\text{nF}$, $L_i = 0\text{mH}$, for each input. <u>Note 20</u> The Entity Parameters for each pair of terminals I1 to I16 are as follows for Groups A and B. $V_{oc} = 13.5\text{ volts}$ $I_{sc} = 15\text{mA}$ $C_a = 0.9\mu A$ $L_a = 150\text{mH}$												Group	Capacitance μF	Inductance mH	A + B	0.8	35	C	2.4	105	D	6.4	280
Group	Capacitance μF	Inductance mH																					
A + B	0.8	35																					
C	2.4	105																					
D	6.4	280																					
Certifying Authority: FACTORY MUTUAL								Scale N/A															
Tolerance unless otherwise stated $\pm$								Sheet 9 of 10															
Title INSTALLATION FOR THE MTL 831 MULTIPLEXER TRANSMITTER								Drg. No. SCI-245															

MEASUREMENT, TECHNOLOGY LTD			4	3.92	P.S.	MTL 831B added.
Luton, England.			5	9.96	P.S.	
Copyright Reserved - Written Permission to Copy Should be Obtained						
Modification						
Date/Drawn						
1 11.69 / DRG.						
2 11.90 DRG.						
3 12.90 AOW						
See Sheet 9						

Dimensions in mm Do not Scale Third Angle Projection



Certifying Authority: FACTORY MUTUAL		Scale	N/A
Tolerance unless otherwise stated ±		Sheet	10 of 10
Title INSTALLATION FOR THE MTL 831 & 831B TRANSMITTER		Dwg. No.	SCI - 245