

PAG	- '			
8	·			
	Note 4 Entity Parameters for terminals 1	Note 4 Entity Parameters for terminals 1 to 4 of the MTL4023 (without the MTL2220) are:		
	Voc ≤ 25V	Isc ≤ 147mA.		
Modification	Groups A and B Ca	$\leq 0.17 \mu F$ La $\leq 1.6 m$	Н	
41616	Groups C and E Ca	$\leq 0.51 \mu F$ La $\leq 4.8 \text{ m}$	Ħ	
₽ 	Groups D,F and G Ca	≤13.6μF La ≤ 12.8n	nH	
With the MTL2220 connected, Entity Parameters for terminals 1 and 4 of the Vt ≤ 31.88V It ≤ 147mA.			nd 4 of the MTL4023 are:-	
Y LTD Permission		$\leq 0.09 \mu F$ La $\leq 1.6 m$		
TECHNOLOGY LTD England - Written Permiss 1d be Obtained		$\leq 0.27 \mu F$ La $\leq 4.8 \text{ m}$		
TECHNOLOGY L England - Written Perr Id be Obtained	Groups D,F and G Ca	$\leq 0.72 \mu F$ La $\leq 12.8 n$	nH	
Copyright Reserved - to Copy Should	Note 6 Use FMRC Approved or NRTL Listed dust-ignition proof enclosure(s) appropriate for environmental protection in class II, Division 2, Groups F and G, Class III Divisions 2 Hazardous Locations. Note 8 For use in Division Hazardous Locations, the MTL4023 must be installed in Factor Mutual Research Corporation Approved Backplanes. When the MTL4023 is installed in Division 2 Hazardous Locations, a warning label must be prominently affixed near the unit(s) which warns that the MTL4023 must not be removed or inserted unless the area is known to be non-hazardous.			
			•	
Modification				
c 3	System Certificate No: N/A		Scale N/A	
ACM ACM	Certifying Authority: Factory Mutu	ua l	Sheet 2 of 2	
Iss Date	Title Installation Drawing for the MTL4 Driver with line Fault Detection	023 Solenoid/Alarm	SCI-477	
	Dir:Cert Drwgs	riAminro\SCI\As Drowing No		