



Is	1	Cl	Ckd
Date	9.94	Drn	ACH
Modification		No	
Modification		Cl	Ckd



THESE TERMINALS MAY OPTIONALLY BE CONNECTED TO ANY NUMBER OF MTL4017 UNITS



THIS MAY ONLY BE CONNECTED IN THE HAZARDOUS LOCATION UNLESS AN I.S. GROUND IS AVAILABLE IN THE NON-HAZARDOUS LOCATION

HAZARDOUS LOCATION
 CLASS I, DIV 1, GRPS A,B,C,D
 CLASS II, DIV.1 GRPS E,F,G
 CLASS III

NON-HAZARDOUS LOCATION

Note 1 The Hazardous location devices may be switches or thermocouples. Other apparatus such as RTD's LEDs and non-inductive resistors may be used if the auto-ignition temperature of the hazardous location is greater than T4 (275°F or 135°C). Certified devices with the correct Entity Concept parameters may also be used.

Note 2 The Non-Hazardous Location (or Control room) devices must not generate or use more than 250V rms.

Note 3 For guidance on the installation see ANSI/ISA RP12.6.

Certifying Authority : Factory Mutual		Scale	N/A
Tolerance unless otherwise stated ± N/A		Sheet	1 of 2
Title Installation Drawing for the MTL4017 Two-Channel Switch/Proximity Detector Interface with Line Fault Detection		Drng. No.	SCI-484

MEASUREMENT TECHNOLOGY LTD
 Copyright Reserved - Written Permission to Copy Should be Obtained

Note 4 Entity Parameters for each channel, i.e channel 1 (terminals 1 & 2), channel 2 (terminals 4 & 5) of the MTL4017 without the MTL2220 connected are as follows.

Terminals 1 and 2} $V_{oc} \leq 10.5V$

Terminals 4 and 5} $I_{sc} \leq 14mA$.

Groups A and B	$C_a \leq 2.4\mu F$	$L_a \leq 165mH$
Groups C and E	$C_a \leq 7.2\mu F$	$L_a \leq 495mH$
Groups D,F and G	$C_a \leq 19.2\mu F$	$L_a \leq 1000mH$

With the MTL2220 connected, Entity Parameters are:

Terminals 1 and 2} $V_t \leq 18.50V$ $I_t \leq 14mA$.

Terminals 4 and 5}

Groups A and B	$C_a \leq 0.36\mu F$	$L_a \leq 165mH$
Groups C and E	$C_a \leq 1.08\mu F$	$L_a \leq 495mH$
Groups D,F and G	$C_a \leq 2.88\mu F$	$L_a \leq 1000mH$

Note 5 The MTL4017 is Associated Apparatus and when mounted in the appropriate enclosure (See notes 6 and 7) is suitable for installation in the following areas:-

Non-Hazardous Locations

Class I, Division 2, Groups A,B,C and D Hazardous Locations

ClassII, Division 2, Groups F and G Hazardous Locations

Class III, Division 2 Hazardous Locations.

Note 6 Associated Apparatus must be installed in accordance with the National Electrical Code in an enclosure meeting the requirements of ANSI/ISA-S82.

Note 7 Use FMRC Approved or NRTL Listed dust-ignition proof enclosure(s) appropriate for environmental protection in class II, Division 2, Groups F and G; Class III Divisions 2 Hazardous Locations.

Note 8 For use in Division Hazardous Locations, the MTL4017 must be installed in Factory Mutual Research Corporation Approved Backplanes.

When the MTL4017 is installed in Division 2 Hazardous Locations, a warning label must be prominently affixed near the unit(s) which warns that the MTL4017 must not be removed or inserted unless the area is known to be non-hazardous.

System Certificate No:	Scale	N/A
Certifying Authority: Factory Mutual	Sheet	2 of 2
Title Installation Drawing for the MTL4017 Two-channel Switch/Proximity Detector Interface with Line Fault Detection		SCI-484

MEASUREMENT TECHNOLOGY LTD
 Luton, England
 Copyright Reserved - Written Permission
 to Copy Should be Obtained