



EC-TYPE EXAMINATION CERTIFICATE

Equipment or Protective System Intended for use in Potentially Explosive Atmospheres

Directive 94/9/EC

- 3 EC-Type Examination Certificate Number : BAS01ATEX7151
- 4 Equipment or Protective System: MTL5031 VIBRATION TRANSDUCER INTERFACE
- 5 Manufacturer: MEASUREMENT TECHNOLOGY LIMITED
- 6 Address: Luton, Bedfordshire, LU1 3JJ
- This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- The Electrical Equipment Certification Service, notified body number 600 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No

01(C)0220 dated 18 December 2001 (held on EECS 0703/02/299)

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 50014: 1997 + Amds 1 & 2

EN 50020: 1994

except in respect of those requirements listed at item 18 of the Schedule.

- If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- This EC-TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment or protective system.
- 12 The marking of the equipment or protective system shall include the following:-

 $\langle E \rangle$ II (1) GD [EEx ia] IIC (-20°C $\leq T_a \leq +60$ °C)

This certificate may only be reproduced in its entirety and without any change, schedule included.

File No: EECS 0703/02/326


This certificate is granted subject to the general conditions of the Electrical Equipment Certification Service. It does not necessarily indicate that the apparatus may be used in particular industries or circumstances.



Electrical Equipment Certification Service Health and Safety Executive Harpur Hill, Buxton, Derbyshire, SK17 9JN, United Kingdom Tel: +44(0)1298 28000 Fax: +44(0)1298 28244 internet: www.baseefa.com e-mail: baseefa.info.eecs@hsl.gov.uk



I M CLEARE DIRECTOR 29 April 2002





13 Schedule

EC-TYPE EXAMINATION CERTIFICATE N° BAS01ATEX7151

15 Description of Equipment or Protective System

An MTL5031 Vibration Transducer Interface is designed to restrict the transfer of energy from unspecified safe area apparatus to an intrinsically safe vibration transducer by the limitation of voltage and current. Three transformers and an opto-isolator provide galvanic isolation between the hazardous and non-hazardous area circuitry.

The apparatus comprises of three isolating transformers and two detection circuits with zener-diode/resistance combinations to provide voltage and current limitation. The above, together with other electronic components are mounted on a printed circuit board and housed in a moulded plastic enclosure. Polarised plugs and sockets are provided for the hazardous and non-hazardous connections.

CON 4, Pins 11, 12 and CON 5, Pins 13 &14

$$U_{\rm m} = 250 \mathrm{V}$$

14

The circuit connected to the safe area terminals CON 4 and CON 5 is designed to operate from a d.c. supply voltage of up to 35V.

CON 1, Pin 2 and 3 w.r.t. Pin 1

$$U_o = 26.6 \text{V}$$

$$I_o = 94 \text{mA}$$

$$P_{\rm o} = 0.66{\rm W}$$

$$C_i = 0$$

$$L_i = 0$$

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area load must not exceed the following values:

GROUP	CAPACITANCE	INDUCTANCE	OR	L/R RATIO
	(μ F)	(mH)		(µH/ohm)
IIC	0.094	4.21		58
IIB	0.730	17.37		219
IIA	2.420	35.29		463

Equipment referred to in this certificate having the same type number as items in BASEEFA Certificate No Ex 96D2132 may be used as a direct substitute in a system provided that the cable parameters used are within the limits shown on this certificate.



13 Schedule

14 EC-TYPE EXAMINATION CERTIFICATE N° BAS01ATEX7151

VARIATION 0.1

To permit the connection of MTL5000 Ring Terminal assemblies in place of the safe and hazardous area screw terminals. The enclosure remains IP20 whether or not the Ring Terminal is fitted. The following MTL5000 Ring Terminals may be connected to the MTL5031. Blanking covers may be removed if necessary.

Hazardous Area Terminal	MTL5031 pins	1, 2, 3	
Hazardous Alea Terrimiar	HAZ-RT-1-3	1, 2, 3	
Safe Area Terminal	MTL5031 pins	11, 12	
Sale Alea Terrimiar	SAF-RT-11-12	7, 8	

16 Report No

STANDARD ST

01(C)0220

17 Special Conditions For Safe Use

None.

18 Essential Health and Safety Requirements

Clause	Subject	Compliance
1.1.3	Changes in characteristics of materials and combinations thereof	Report No 01(C)0220 Clause 5.1.1.3
1.2.2	Components for incorporation or replacement	Report No 01(C)0220 Clause 5.1.2.2
1.2.5	Additional means of protection	Report No 01(C)0220 Clause 5.1.2.5
1.2.7	Protection against other hazards	Report No 01(C)0220 Clause 5.1.2.7
1.4.2	Withstanding attack by aggressive substances	Report No 01(C)0220 Clause 5.1.4.2

19 DRAWINGS

Number	Sheet	Issue	Date	Description
CI5031-1	2	3	11.01	MTL5031 Parts List
CI5031-1	3	1	02.96	MTL5031 Circuit Diagram
CI5031-1	4	2	12.01	MTL5031 Component Layout
CI5031-1	5	1	02.96	MTL5031 General Assembly
CI5031-1	6	2	11.01	MTL5031 Internal Construction
CI5031-1	7	1	02.96	MTL5031 PCB Track Layout



13

Schedule

14 EC-TYPE EXAMINATION CERTIFICATE N° BAS01ATEX7151

Number	Sheet	Issue	Date	Description
CI5031-1	8	2	08.96	MTL5031 Transformer Winding Details
*CI4000-1	1	2	11.92	MTL4000 Series 2-core IS Transformer
*CI4000-1	2	2	11.92	MTL4000 Series 2-core IS Transformer

Drawings marked * are associated with and are held on BASEEFA Certificate BAS01ATEX7163

Drawing associated with Variation 0.1

Number	Sheet	Issue	Date	Description
**CI5000-12	1 to 4	1	02.02	MTL5000 Ring Terminal

Drawing marked ** is associated with and held on BASEEFA Certificate BAS01ATEX7144

This certificate may only be reproduced in its entirety and without any change, schedule included.

BASEEFA List Keywords 2ISOLBAR