



# EC-TYPE EXAMINATION CERTIFICATE

Equipment or Protective System Intended for use  
in Potentially Explosive Atmospheres  
Directive 94/9/EC

EC-Type Examination Certificate Number : **BAS01ATEX7154**

Equipment or Protective System: **MTL5043 REPEATER POWER SUPPLY 4/20mA**

Manufacturer: **MEASUREMENT TECHNOLOGY LIMITED**

Address: **Luton, Bedfordshire, LU1 3JJ**

This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

The Electrical Equipment Certification Service, notified body number 600 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report N°

**01(C)0220 dated 18 December 2001 (held on EECS 0703/02/299)**

Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 50014: 1997 + Amds 1 & 2                      EN 50020: 1994**

except in respect of those requirements listed at item 18 of the Schedule.

If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

This EC-TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified equipment or protective system. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment or protective system.

The marking of the equipment or protective system shall include the following:-

**Ex II (1) GD    [EEEx ia] IIC    (-20°C ≤ T<sub>a</sub> ≤ +60°C)**

This certificate may only be reproduced in its entirety and without any change, schedule included.

File No: EECS 0703/02/329

This certificate is granted subject to the general conditions of the Electrical Equipment Certification Service. It does not necessarily indicate that the apparatus may be used in particular industries or circumstances.



Electrical Equipment Certification Service  
Health and Safety Executive  
Harpur Hill, Buxton, Derbyshire, SK17 9JN, United Kingdom  
Tel: +44(0)1298 28000 Fax: +44(0)1298 28244  
internet: www.baseefa.com e-mail: baseefa.info.eecs@hsl.gov.uk



**IM CLEARE  
DIRECTOR  
29 April 2002**

Re-issued 5 July 2002 to correct drawing numbers.



13 Schedule

14 EC-TYPE EXAMINATION CERTIFICATE N° BAS01ATEX7154

15 Description of Equipment or Protective System

The MTL5043 Repeater Power Supply 4/20 mA is designed to provide a fully floating d.c. supply for energising a certified 4/20mA transmitter which may be located in the hazardous area. This repeats the current in two floating circuits to drive two safe area loads. The MTL5043 is designed to restrict the transfer of energy from unspecified safe-area apparatus to an intrinsically safe circuit by the limitation of voltage and current. An LED indicator is provided to indicate power-on.

The MTL5043 apparatus comprises four isolating transformers which provide galvanic isolation between the hazardous area and the non-hazardous area circuitry and a detection circuit with zener diode/resistance combination to provide voltage and current limitation. The above, together with other electronic components are mounted on a printed circuit board and housed in a moulded plastic enclosure. Polarised plugs and sockets are provided for the hazardous area and non-hazardous area connections.

CON 3, Pins 7, 8, 9; CON 4, Pins 10, 11, 12 and CON 5, Pins 13 & 14

$$U_m = 250V$$

The circuit connected to the safe area terminals on CON 3, CON 4 and CON 5 is designed to operate from a d.c. supply voltage of up to 35V.

CON 1 pins 1 and 2

$$U_o = 28V$$

$$I_o = 93mA$$

$$P_o = 0.65W$$

$$C_i = 0$$

$$L_i = 0$$

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area load must not exceed the following values for either channel:

GROUP	CAPACITANCE ( $\mu F$ )	INDUCTANCE (mH)	OR L/R RATIO ( $\mu H/ohm$ )
IIC	0.083	3.05 (4.2)	55
IIB	0.650	9.15 (12.6)	210
IIA	2.150	24.4 (33.6)	444

When the external circuit contains no lumped inductance greater than  $10\mu H$  i.e. the  $L_i$  of any attached apparatus is less than  $10\mu H$ , the cable inductance may be increased to the values within parentheses.



13 Schedule

14 EC-TYPE EXAMINATION CERTIFICATE N° BAS01ATEX7154

Equipment referred to in this certificate having the same type number as items in BASEEFA Certificate No Ex 97D2248 may be used as a direct substitute in a system provided that the cable parameters used are within the limits shown on this certificate.

**VARIATION 0.1**

To permit the connection of MTL5000 Ring Terminal assemblies in place of the safe and hazardous area screw terminals. The enclosure remains IP20 whether or not the Ring Terminal is fitted. The following MTL5000 Ring Terminals may be connected to the MTL5043. Blanking covers may be removed if necessary.

Hazardous Area Terminal	MTL5043 pins	1, 2
	HAZ-RT-1-2	1, 2
Safe Area Terminal	MTL5043 pins	8, 9, 11, 12
	SAF-RT-8-12	5, 6, 7, 8

16 Report No

01(C)0220

17 Special Conditions For Safe Use

None.

18 Essential Health and Safety Requirements

ESSENTIAL HEALTH & SAFETY REQUIREMENTS not covered by standards listed in Section 9		
Clause	Subject	Compliance
1.1.3	Changes in characteristics of materials and combinations thereof	Report No 01(C)0220 Clause 5.1.1.3
1.2.2	Components for incorporation or replacement	Report No 01(C)0220 Clause 5.1.2.2
1.2.5	Additional means of protection	Report No 01(C)0220 Clause 5.1.2.5
1.2.7	Protection against other hazards	Report No 01(C)0220 Clause 5.1.2.7
1.4.2	Withstanding attack by aggressive substances	Report No 01(C)0220 Clause 5.1.4.2

19 DRAWINGS

Number	Sheet	Issue	Date	Description
CI5043	1	2	11.01	MTL5043 Parts List
CI5043	2	4	09.99	MTL5043 Circuit Diagram
CI5043	3	1	03.97	MTL5043 Component Layout
CI5043	4	2	11.01	MTL5043 General Assembly
CI5043	5	3	09.99	MTL5043 PCB Track Layout



13

**Schedule**

14

**EC-TYPE EXAMINATION CERTIFICATE N° BAS01ATEX7154**

<b>Number</b>	<b>Sheet</b>	<b>Issue</b>	<b>Date</b>	<b>Description</b>
CI5043	6	1	03.97	MTL5043 Transformer Winding Details
*CI 5000-1	1	1	5.95	I.S. Transformer TRF301
*CI 5000-1	2	1	5.95	I.S. Transformer TFR301
*CI 5000-2	1	1	5.95	I.S. Transformer TFR300
*CI 5000-2	2	1	5.95	I.S. Transformer TFR300

Drawings marked \* are associated with and are held on BASEEFA Certificate BAS01ATEX7157

**Drawing associated with Variation 0.1**

<b>Number</b>	<b>Sheet</b>	<b>Issue</b>	<b>Date</b>	<b>Description</b>
**CI5000-12	1 to 4	1	02.02	MTL5000 Ring Terminal

Drawing marked \*\* is associated with and held on BASEEFA Certificate BAS01ATEX7144



This certificate may only be reproduced in its entirety and without any change, schedule included.