



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION
IEC Certification Scheme for Explosive Atmospheres
for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEx BAS 04.0003** issue No.: **2**

Certificate history:
Issue No. 2 (2009-5-6)
Issue No. 1 (2005-4-20)

Status: **Current**

Date of Issue: **2009-05-06** Page 1 of 4


Applicant: **Measurement Technology Limited**
Great Marlings
Butterfield
Luton
Bedfordshire
LU2 8DL
United Kingdom

Electrical Apparatus: **MTL4015 / MTL4016 Single / Two Channel Switch / Proximity Detector Interface – Dual Relay Output**
Optional accessory:

Type of Protection: **Intrinsic Safety**


Marking: **IECEx BAS 04.0003**
[Ex ia] IIC
-20°C ≤ Ta ≤ +60°C
Um = 250V

Approved for issue on behalf of the IECEx
Certification Body:

 R S Sinclair

Position: **Managing Director**

Signature:
(for printed version)


6/5/09

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

Baseefa
Rockhead Business Park
Staden Lane
Buxton
Derbyshire
SK17 9RZ
United Kingdom





IECEX Certificate of Conformity

Certificate No.: IECEX BAS 04.0003

Date of Issue: 2009-05-06

Issue No.: 2

Page 2 of 4

Manufacturer: **Measurement Technology Limited**
Great Marlings
Butterfield
Luton
Bedfordshire
LU2 8DL
United Kingdom

Manufacturing location(s):
MTL Instruments PVT Ltd
No 3 Old Mahabalipuram
Road
Sholinganallur
Chennai
India

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2000 Edition: 3.1	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
IEC 60079-11 : 1999 Edition: 4	Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety 'i'

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEX ATR:
UK/BAS/03/0917/1

File Reference:
03/0917



IECEx Certificate of Conformity

Certificate No.: IECEx BAS 04.0003

Date of Issue: 2009-05-06

Issue No.: 2

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

An MTL4016 Two Channel Switch / Proximity Detector Interface – Dual Relay Output is designed to restrict the transfer of energy from unspecified safe-area apparatus to two independent intrinsically safe circuits by the limitation of voltage and current. Transformers and opto-isolators provide galvanic isolation between the hazardous and non-hazardous area circuitry.

Each channel of the interface monitors either a detector or a switch located in the hazardous area and controls a safe-area load via relay outputs. Independent phase-reverse controls allow an alarm condition to be signalled for either state of a sensor by means of two switches on the top of the unit. A further two switches are provided to permit the optional use of a line fault detection system on each channel. LED indication is provided to indicate power-on and the state of each output.

The MTL4015 Single Channel Switch / Proximity Detector, Dual Contact Output is formed by the removal of components associated with the second channel of the MTL4016.

For electrical data see Additional information.

CONDITIONS OF CERTIFICATION: NO



IECEX Certificate of Conformity

Certificate No.: IECEx BAS 04.0003

Date of Issue: 2009-05-06

Issue No.: 2

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Variation 2.1

This document permits existing information (for example on Schedule Drawings) to be replaced by the revised certificate holders address. No other changes may be made to the certified design.