






# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx BAS 04.0037 issue No.: 1  
Status: **Current**  
Date of Issue: 2009-05-06 Page 1 of 4  
Applicant: **Measurement Technology Limited**  
Great Marlings  
Butterfield  
Luton  
Bedfordshire  
LU2 8DL  
United Kingdom  
Electrical Apparatus: **MTL5081 Millivolt Isolator**  
Optional accessory:  
Type of Protection: **Intrinsic Safety**  
Marking: **IECEX BAS 04.0037**  
**[Ex ia] IIC (-20°C ≤ Ta ≤ +60°C)**  
Approved for issue on behalf of the IECEx Certification Body:  R S Sinclair  
Position: Managing Director  
Signature:   
(for printed version)   
Date: 6/5/09

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

Baseefa  
Rockhead Business Park  
Staden Lane  
Buxton  
Derbyshire  
SK17 9RZ  
United Kingdom





# IECEX Certificate of Conformity

Certificate No.: IECEX BAS 04.0037

Date of Issue: 2009-05-06

Issue No.: 1

Page 2 of 4

Manufacturer: **Measurement Technology Limited**  
Great Marlings  
Butterfield  
Luton  
Bedfordshire  
LU2 8DL  
United Kingdom

Manufacturing location(s):  
**MTL Instruments PVT  
Limited**  
No3 Old Mahabalipuram Road  
Sholinganallur  
Chennai  
Tamilnadu  
600 119  
India

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

<b>IEC 60079-0 : 2000</b> Edition: 3.1	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
<b>IEC 60079-11 : 1999</b> Edition: 4	Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety 'i'

*This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

IECEX ATR:  
**UK/BAS/03/0253**

File Reference:  
**03/0253**



# IECEx Certificate of Conformity

Certificate No.: IECEx BAS 04.0037

Date of Issue: 2009-05-06

Issue No.: 1

Page 3 of 4

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

The MTL5081 Millivolt Isolator restricts the transfer of energy from unspecified safe area apparatus to intrinsically safe circuits by the limitation of voltage and current. The MTL5081 Millivolt Isolator comprises two isolating transformers which provide galvanic isolation between the hazardous area and the non-hazardous area circuitry and a combination of diodes and resistance on the output channel to provide voltage and current limitation.

The above, together with other electronic components are mounted on a printed circuit board and housed in a moulded plastic enclosure. Polarized plugs and sockets are provided for the hazardous area and non-hazardous area connections.

For electrical data see Annex.

**CONDITIONS OF CERTIFICATION: NO**



# IECEx Certificate of Conformity

Certificate No.: IECEx BAS 04.0037

Date of Issue: 2009-05-06

Issue No.: 1

Page 4 of 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

### Variation 1.1

This document permits existing information (for example on Schedule Drawings) to be replaced by the revised certificate holders address. No other changes may be made to the certified design.