Certificate Number Baseefa15ATEX0032 Issue 1



Issued 26 September 2016 Page 1 of 4

EU - TYPE EXAMINATION CERTIFICATE

Safety Device, Controlling Device or Regulating Device intended for use outside a potentially explosive atmosphere but required for or contributing to the safe functioning of Equipment and Protective Systems with respect to the risks of explosion

Directive 2014/34/EU

3 EU - Type Examination Certificate Number:

Baseefa15ATEX0032 - Issue 1

3.1 In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.

4 Product:

1

MTL4541Y Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters

5 Manufacturer:

Eaton Electric Limited

6 Address:

Great Marlings, Butterfield, Luton, Bedfordshire, LU2 8DL

- 7 This re-issued certificate extends EC Type Examination Certificate No. Baseefa15ATEX0032 to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.
- 8 SGS Baseefa, Notified Body number 1180, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. See Certificate History

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0: 2012 + A11: 2013 EN 60079-11: 2012

except in respect of those requirements listed at item 18 of the Schedule.

- 10 If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.
- 11 This EU TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.
- 12 The marking of the product shall include the following:

ⓑ II (1) GD [Ex ia Ga] IIC (-20°C ≤ T_a ≤ +60°C) [Ex ia Da] IIIC (-20°C ≤ T_a ≤ +60°C)

E I (M1) [Ex ia Ma] I (-20°C $\leq T_a \leq +60$ °C)

SGS Baseefa Customer Reference No. 0703

Project File No. 16/0371

This document is issued by the Company subject to its General Conditions for Certification Services accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited

Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601
e-mail baseefa@sgs.com web site www.sgs.co.uk/baseefa
Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN

R S SINCLAIR TECHNICAL MANAGER On behalf of SGS Baseefa Limited 13

14

Schedule

Certificate Number Baseefa15ATEX0032 - Issue 1

15 Description of Product

The MTL4541Y Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters is designed to provide a floating d.c. supply for energising a conventional 2 or 3-Wire 4/20mA Transmitter in the hazardous area and repeat these currents in the non-hazardous area, whilst restricting the transfer of energy from unspecified non-hazardous area equipment to the intrinsically safe circuits by means of limitation of current and voltage. The equipment also allows bi-directional signal communication between the hazardous and non-hazardous area by connection of a hand-held communicator (HHC).

The MTL4541Y Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters comprises two isolating transformers that provide galvanic isolation between the hazardous and non-hazardous area circuitry, zener diode chains and resistors providing voltage and current limitation. The above, together with other electronic components, are mounted on a single printed circuit board (PCB) and housed in a moulded plastic enclosure. Polarised plug and sockets are provided for hazardous and non-hazardous area connections. A LED is fitted to provide power on indication.

Input / Output Parameters

Non-Hazardous Area Terminals 8, 9, 12, 13 & 14

$$U_m = 253V$$

The apparatus is designed to operate on the above terminals from a d.c. supply voltage of up to 35V.

Hazardous Area Terminals 2 w.r.t. 1

Hazardous Area Terminals 3 w.r.t. 1

U_{o}	=	1.1V	U_i	=	30V
I_{o}	=	53mA	$\mathbf{I_i}$	=	121mA
P_{o}	=	15mW			
C_{i}	=	0			
L_i	=	0			

When an intrinsically safe source is connected to these terminals it should have a source resistance of U_i / I_i and the capacitance and either the inductance or inductance to resistance ratio (L/R) of the hazardous area connections must not exceed the values detailed in the certificate of the intrinsically safe source.

Hazardous Area Terminal 2 must not be used when the source is connected to these terminals.

Hazardous Area Terminals 2 w.r.t. 3

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area load connected must not exceed the following values:

Certificate Number Baseefa15ATEX0032 Issue 1



Issued 26 September 2016 Page 3 of 4

GROUP	CAPACITANCE (µF)	INDUCTANCE (mH)	OR	L/R RATIO (µH/ohm)			
Hazardous Area	Hazardous Area Terminals 2 w.r.t. 1						
IIC	0.083	4.2		56			
IIB**	0.65	12.6		210			
IIA	2.15	33.6		444			
I	3.76	53.7		668			
Hazardous Area	Hazardous Area Terminals 3 w.r.t. 1						
IIC	100	12.8		2,438			
IIB**	1,000	47.8		8,932			
IIA	1,000	104.7		18,140			
I	1,000	156.2		28,229			
Hazardous Area Terminals 2 w.r.t. 3							
IIC	0.083	4.9		59			
IIB**	0.65	20.0		222			
IIA	2.15	40.9		469			
I	3.76	59.1		710			

^{**} Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

Notes:

- 1) The above load parameters apply when one of the two conditions below is given:
 - the total L_i of the external circuit (excluding the cable) is < 1% of the L_o value or
 - the total C_i of the external circuit (excluding the cable) is < 1% of the C_o value.
- 2) The above parameters are reduced to 50% when both of the two conditions below are given:
 - the total L_i of the external circuit (excluding the cable) is $\geq 1\%$ of the L_o value and
 - the total C_i of the external circuit (excluding the cable) is $\geq 1\%$ of the C_o value.

The reduced capacitance of the external circuit (including cable) shall not be greater than $1\mu F$ for Groups IIB, IIA & I and 600nF for Group IIC.

16 Report Number

GB/BAS/ExTR16.0237/00

17 Specific Conditions of Use

None

18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject	Compliance
1.2.7	Protection against other hazards (LVD type requirements, etc.)	Manufacturer responsibility
1.2.8	Overloading of equipment (protection relays, etc.)	User/Installer responsibility
1.4.1	External effects	User/Installer responsibility
1.4.2	Aggressive substances, etc.	User/Installer responsibility

19 Drawings and Documents

New drawings submitted for this issue of certificate:

Number	Sheet	Issue	Date	Description
CI4541Y-7	1 of 1	2	7.16	MTL4541Y Certification Label Details – Baseefa – Ex i

Certificate Number Baseefa15ATEX0032 Issue 1



Issued 26 September 2016 Page 4 of 4

Current drawings which remain unaffected by this issue:

Number	Sheet	Issue	Date	Description
CI4500-100	1 of 1	2	1.13	MTL 4500 Case
CI4541Y-1	1 & 2	1	11.14	Circuit Diagram for the MTL 4541Y
CI4541Y-2	1 & 2	1	10.14	MTL4541Y Parts List
CI4541Y-3	1 of 1	1	11.14	Track Layout for MTL4541Y
CI4541Y-4	1 & 2	1	10.14	MTL4541Y Component Layout
CI4541Y-5	1 of 1	1	10.14	PCB Detail for TPL300
CI4541Y-6	1 of 1	1	10.14	PCB Detail for TPL301

The above drawings are associated and held with IECEx Certificate No. IECEx BAS 15.0014

20 Certificate History

Certificate No.	Date	Comments	
Baseefa15ATEX0032	9 March 2015	The release of the prime certificate. The associated test and assessment against the requirements of EN 60079-0: 2012 and EN 60079-11: 2012 is documented in Certification Test Report No. GB/BAS/ExTR15.0036/00.	
Baseefa15ATEX0032 Issue 1	26 September 2016	This issue of the certificate confirms the current designs meet the requirements of EN 60079-0: 2012 + A11: 2013 in respect of differences from EN 60079-0: 2012.	
		The certificate also permits the manufacturer's name to be changed on page 1 of the certificate and on the equipment marking.	
		The associated assessment is documented in Certification Report No. GB/BAS/ExTR16.0237/00.	
For drawings applicable to each issue, see original of that issue.			