

IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx BAS 17.0015	5X	issue No.:0	Certificate history:
Status:	Current			
Date of Issue:	2017-03-02	Р	age 1 of 3	
Applicant:	Eaton Electric Lin Great Marlings Butterfield Luton Bedfordshire LU2 8DL United Kingdom	nited		
Equipment: Optional accessory:	FS32 & FS32G Surg	e Protection D	evice	
Type of Protection:	Increased Safety			
Marking:	Ex ec IIC T4 Gc (-40	°C ≤ Ta ≤ +70°	C)	
Approved for issue on b Certification Body:	ehalf of the IECEx	R.S. Sinclair	PP DOREAN	EJ
Position:		Technical Ma	nager	
Signature: (for printed version)		TBre	aly	
Date:		_ 2	13/17	
 This certificate and so This certificate is not if The Status and auther 	chedule may only be rep transferable and remain enticity of this certificate i	roduced in full. s the property o may be verified	f the issuing body. by visiting the Official	IECEx Website.
Certificate issued by: SGS Rockh Buxton, D	Baseefa Limited ead Business Park Staden Lane Derbyshire, SK17 9RZ nited Kingdom		SG	S Baseefa



IECEx Certificate of Conformity

Certificate No .:

IECEx BAS 17.0015X

Date of Issue:

2017-03-02

Issue No.: 0

Page 2 of 3

Manufacturer:

Eaton Electric Limited Great Marlings Butterfield Luton Bedfordshire LU2 8DL United Kingdom

Additional Manufacturing location(s): **MTL Instruments PvT Limited** No 3 Old Mahabalipuram Road Sholinganallur Chennai 600119 India

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition: 6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-7 : 2015 Edition: 5.0	Explosive atmospheres - Part 7: Equipment protection by increased safety "e"

This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report: GB/BAS/ExTR17.0023/00

Quality Assessment Report:

GB/BAS/QAR06.0022/06

GB/BAS/QAR07.0017/06



IECEx Certificate of Conformity

Certificate No .:

IECEx BAS 17.0015X

Date of Issue:

2017-03-02

Issue No.: 0

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The FS32 & FS32G Surge Protection Devices are designed to provide protection for sensitive electronic equipment mounted in a zone 2 hazardous area. The equipment provides no voltage or current limitation and therefore must be supplied from a suitable zone 2 source.

The FS32 & FS32G Surge Protection Devices have identical circuit but differ in the configuration of the connection pins. Both comprise a diode bridge circuit, two gas discharge tubes, a silicon avalanche diode and two metal oxide varistors mounted on a single printed circuit board. This assembly is housed in a plastic enclosure with the lower section encapsulated. External input and output connections to the circuit are provided via plug and socket connectors with an additional M3 screw providing the earth connection to the equipment earth facility, and two M2.5 screws providing the means to secure the device to the equipment to which it is connected to.

Input / Output Parameters

Top Connector Input - '+', '-' & 'S'

Maximum Rated Voltage = 32V d.c.

Bottom Connector Output '+', '-' & 'S'

Output Voltage = Input Voltage

SPECIFIC CONDITIONS OF USE: YES as shown below:

1) The equipment must be installed in an area of at least Pollution Degree 2, as defined in IEC 60664-1, and in an enclosure that provides a degree of protection of at least IP54 and meets the relevant requirements of IEC 60079-0 and IEC 60079-7.

2) The equipment may not be capable of withstanding the 500V dielectric strength test in accordance with clause 7.1 of IEC 60079-7. This must be taken into account during installation.

3) All connections to the equipment must not be inserted or removed unless either the area in which the equipment is installed is known to be non-hazardous, or the circuit to which it is connected has been de-energised.