

CERTIFICATE OF CONFORMITY



1. **HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS**
2. **Certificate No:** FM16CA0050X
3. **Equipment:** Model MTL4500Y Series Isolators
(Type Reference and Name)
4. **Name of Listing Company:** Eaton Electric Ltd
5. **Address of Listing Company:** Great Marlings, Butterfield
Luton, Bedfordshire, LUS 8DL
United Kingdom
6. The examination and test results are recorded in confidential report number:

3057037 dated 28th March 2017
7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

CSA-C22.2 No.213-M1987:2013, CAN/CSA-C22.2 No. 60079-0:2015, CAN/CSA-C22.2 No. 60079-11:2014, CAN/CSA-C22.2 No. 60079-15:2012, CAN/CSA-C22.2 No. 61010-1:2012
8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

Certificate issued by:



J.E. Marquedant
Manager, Electrical Systems

28 March 2017

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



Canadian Certificate Of Conformity No: FM16CA0050X

10. Equipment Ratings:

Model MTL4514N

Associated Apparatus providing Intrinsically Safe Circuits for Class I, II, III, Division 1, Groups A, B, C, D, E, F, and G when installed per control drawing SCI-1076; Class I, Division 2, Groups A, B, C, and D; Associated Apparatus providing Intrinsically Safe ia Circuits for IIC Ga when installed per control drawing SCI-1076; Enclosed Break for IIC Gc hazardous locations with an ambient temperature rating of -20°C to +60°C.

Models MTL4521Y, MTL4523Y, MTL4541Y, MTL4541YA, MTL4545Y, MTL4573Y

Associated Apparatus providing Intrinsically Safe Circuits for Class I, II, III, Division 1, Groups A, B, C, D, E, F, and G when installed per control drawing show below; Class I, Division 2, Groups A, B, C, and D; Associated Apparatus providing Intrinsically Safe ia Circuits for IIC Ga when installed per control drawing show below; Non Sparking for IIC Gc hazardous locations with an ambient temperature rating of -20°C to +60°C.

Control Dawing	Models
SCI-1077	MTL4521Y, MTL4523Y
SCI-1078	MTL4541Y
SCI-1079	MTL4541YA
SCI-1080	MTL4545Y
SCI-1081	MTL4573Y

11. The marking of the equipment shall include:

Model MTL4514N

Provides Intrinsically Safe Circuits for Class I, II, III Division 1, Groups A, B, C, D, E, F, G
Class I, Division 2, Groups A, B, C, D; T4
[Ex ia] IIC Ga
Ex nC IIC T4 Gc
Ta = -20°C to +60°C

Model MTL4521Y, MTL4523Y, MTL4541Y, MTL4541YA, MTL4545Y, MTL4573Y

Provides Intrinsically Safe Circuits for Class I, II, III Division 1, Groups A, B, C, D, E, F, G
Class I, Division 2, Groups A, B, C, D; T4
[Ex ia] IIC Ga
Ex nA IIC TGc
Ta = -20°C to +60°C
Per control drawing (see section 10 for actual drawing number)

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

SCHEDULE



Canadian Certificate Of Conformity No: FM16CA0050X

12. Descriptin of Equipment:

General – The MTL4514N Switch / Proximity Detector Interface with Line Fault Detection alarm is designed to restrict the transfer of energy from unspecified non-hazardous area equipment to an intrinsically safe circuit by limitation of voltage and current. Relays and a transformer provide galvanic isolation between the hazardous and non-hazardous area circuitry.

The MTL4521Y & MTL4523Y Solenoid / Alarm Drivers are designed to control and monitor a device located in the hazardous area and restrict the transfer of energy from unspecified equipment in the non-hazardous area to an intrinsically safe circuit in the hazardous area by the limitation of voltage and current. Opto-isolators and a transformer provide galvanic isolation between the hazardous and non-hazardous area circuitry.

The MTL4541Y Repeater Power Supply, 4/20mA for 2 or 3-Wire Transmitters is designed to provide a floating d.c. supply for energising a conventional 2 or 3-Wire 4/20mA Transmitter in the hazardous area and repeat these currents in the non-hazardous area, whilst restricting the transfer of energy from unspecified non-hazardous area equipment to the intrinsically safe circuits by means of limitation of current and voltage. The equipment also allows bi-directional signal communication between the hazardous and non-hazardous area by connection of a hand-held communicator (HHC).

The MTL4541YA Single Channel Current Repeater, 4/20mA Passive Input for Smart Transmitters is designed to repeat a current signal from a separately powered 4/20mA transmitter located in the hazardous area to unspecified equipment location in the non-hazardous area, whilst restricting the transfer of energy from the unspecified non-hazardous area equipment to the intrinsically safe equipment by means of current and voltage limitation. The equipment also allows bi-directional signal communication between hazardous and non-hazardous area by connection of a hand-held communicator (HHC).

The MTL4545Y Isolating Driver, 4/20mA for Smart I/P Converters accepts a 4/20mA signal from a controller located in the non-hazardous area to drive a load in the hazardous area. It permits bi-directional transmissions of a digital signal to and from an operator station or handle-held communicators. The equipment restricts the transfer of energy from unspecified non-hazardous area equipment to an intrinsically safe circuit by limitation of voltage and current. Three transformers provide galvanic isolation between the hazardous and non-hazardous circuitry.

The MTL4573Y Temperature Converter is designed for connection to thermocouples or two, three or four wire RTD's situated in the hazardous area. The apparatus converts the low level d.c. signal from the sensor mounted in the hazardous area into a 4/20mA current for driving a load in the non-hazardous area. An optional cold junction compensation (CJC) plug can be fitted to the hazardous area connection which alters the internal connections and affects the output parameters.

Construction - The MTL4500Y series isolator's electronics are housed in a molded polymeric enclosure. The safe area terminals are on the bottom of the enclosure and connect using mechanical retention to a Base Plate. The intrinsically safe terminals are pluggin blue connectors on the top of the enclosure.

Ratings - The MTL4500Y series isolators operate at 20-35 Vdc. The transmitters are rated for use in an ambient temperature range of -20°C to +60°C.

MTL4514N Switch/Proximity Detector Interface

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

SCHEDULE



Canadian Certificate Of Conformity No: FM16CA0050X

MTL4521Y Solenoid Alarm Driver
MTL4523Y Solenoid Alarm Driver with Line Fault Detection Alarm
MTL4541Y Repeater Power Supply
MTL4545Y Isolating Driver, 4/20mA for smart I/P converters
MTL4573Y Temperature Converter

13. Specific Conditions of Use:

1. When installed in a hazardous area, the MTL4500Y series module series shall be used with Yokogawa A2BN4D Base Plate.
2. When installed as Class I Division 2 equipment, the apparatus shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I Division 2 wiring methods per the Canadian Electric Code (C22.1).
3. When installed as Zone 2 equipment, the apparatus shall be mounted within a tool-secured enclosure which meets the requirements of IP54 and is capable of accepting one or more of the Zone 2 wiring methods specified in the Canadian Electrical Code (C22.1).

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
28 th March 2017	Original Issue.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com