



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1965361

Master Contract: 215080

Project: 2071023

Date Issued: 2009/01/23

Issued to: Elpro Technologies P/L
9/12 Billabong St
Stafford
Brisbane, Queensland 4053
Australia
Attention: Mr. Steve Brennan

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: David Wood

Authorized by: Patricia Pasemko, Operations Manager

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

CLASS 4871 01 - TELECOMMUNICATION EQUIPMENT

CLASS 4871 81 - TELECOMMUNICATION EQUIPMENT - Certified to US Standards

Class I, Division 2, Groups A, B, C and D;



Certificate: 1965361

Master Contract: 215080

Project: 2071023

Date Issued: 2009/01/23

Serial I/O Module, 115S Series:

Model: 115S-11-24, rated 10.8-30Vdc, 300mA, Tcode T5.

Model: 115S-12-24, rated 10.8-30Vdc, 900 mA, Tcode T5.

Model: 115S-13-24, rated 10.8-30Vdc, 900 mA, Tcode T5.

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No 0-M91 - General Requirements, Canadian Electrical Code, Part II

CAN/CSA C22.2 No 60950-1-03- Information Technology Equipment – Safety Part 1: General Requirements

CAN/CSA-C22.2 No. 213-M1987 -Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations.

ANSI/UL 60950-1 1st Ed (2003) - Information Technology Equipment – Safety Part 1: General Requirements.

ANSI/ISA 12.12.01 – 2000 -Non-Incendive Electrical Equipment for Use in Class I and II, Division 2, Class III Divisions 1 and 2 Hazardous (Classified) Locations