

Certificate No.: LC17ATEX13545X-4S



Certificate of Conformity

For

ELPRO Technologies Pty Ltd.

9/12 Billabong Street
Stafford Queensland 4053
Australia

For Compliance of:

Equipment: Expansion I/O Module
Model No.: 115S-11-24
Rated: Ex nA IIC T6 Gc, II 3 G, $-40\text{ }^{\circ}\text{C} \leq T_a \leq +60\text{ }^{\circ}\text{C}$
Input 10.8-30Vdc, 300mA, IP20
Report No.: 10192-3S

To the following Directive(s):

- 2014/34/EU– ATEX Directive

To the following standard(s):

- EN 60079-15:2010, 4th Edition

“Specific Conditions of Use “X”:

- Unit to be installed with an enclosure that complies with the requirements of EN 60529 for IP54 minimum.

Project No.: 13545

Issued by:

A handwritten signature in blue ink, appearing to read 'Kavinder Dhillon', written over a horizontal line.

Kavinder Dhillon, Eng.L.
Certification Manager

Issue Date: May 23, 2017