



Certificate of Compliance

Certificate: 2327835

Master Contract: 215080

Project: 2327835

Date Issued: November 17, 2010

Issued to: Elpro Technologies P/L
9/12 Billabong St
Stafford
Brisbane, Queensland 4053
Australia
Attention: George Sutherland

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Ron Wachowicz

Issued by: Ron Wachowicz, C.E.T.

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

Class I, Division 2, Groups A, B, C and D:

Wireless HART gateway Model 315-WH-GT; Input Ratings 9-30VDC, 1000mA; Temperature Code T6;
Ambient Temperature Range -40°C to +60°C.

Conditions of Acceptability

- Equipment must be powered by a suitable certified Class II power supply
- When being installed in a Class I, Division 2 hazardous area, the equipment must be installed in a suitable enclosure such that a tool is required to gain access to the connectors external to the certified equipment.
- Final acceptability of the equipment is subject to the authority having local jurisdiction



Certificate: 2327835

Master Contract: 215080

Project: 2327835

Date Issued: November 17, 2010

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 0-10 - General Requirements - Canadian Electrical Code Part II

CAN/CSA-C22.2 No. 61010-1-04 – Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

CSA Standard C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

UL 61010-1, Second Edition – Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

ANSI/ISA-12.12.01-2007 – Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations