

# **IECEx Certificate** of Conformity

# INTERNATIONAL ELECTROTECHNICAL COMMISSION **IEC Certification Scheme for Explosive Atmospheres**

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:

Date of Issue:

**IECEx BAS 14.0083X** 

issue No.:2

Status:

Current

2016-11-16

Page 1 of 4

Certificate history:

Issue No. 2 (2016-11-

16)

Issue No. 1 (2014-11-

13)

Issue No. 0 (2014-7-18)

Applicant:

**Eaton Electric Limited** 

**Great Marlings** Butterfield Luton Bedfordshire LU2 8DL

**United Kingdom** 

Equipment:

MTL4573 & MTL4573Y Temperature Converter

Optional accessory:

Type of Protection:

Type of Protection 'n'

Marking:

Ex nA IIC T4 Gc (-20°C ≤ Ta ≤ +60°C)

Approved for issue on behalf of the IECEx

Certification Body:

R. S. Sinclair

**Technical Manager** 

Position:

Signature: (for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

SGS Baseefa Limited Rockhead Business Park Staden Lane Buxton, Derbyshire, SK17 9RZ **United Kingdom** 





# **IECEx Certificate** of Conformity

Certificate No.:

**IECEx BAS 14.0083X** 

Date of Issue:

2016-11-16

Issue No.: 2

Page 2 of 4

Manufacturer:

**Eaton Electric Limited** 

Great Marlings Butterfield Luton Bedfordshire LU2 8DL

**United Kingdom** 

Additional Manufacturing location(s):

MTL Instruments PvT Limited No 3 Old Mahabalipuram Road Sholinganallur Chennai 600119

India

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2011

Explosive atmospheres - Part 0: General requirements

Edition: 6.0

IEC 60079-15: 2010

Explosive atmospheres - Part 15: Equipment protection by type of protection "n"

Edition: 4

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

GB/BAS/ExTR14.0165/00

GB/BAS/ExTR14.0323/00

GB/BAS/ExTR16.0241/00

Quality Assessment Report:

GB/BAS/QAR06.0022/06

GB/BAS/QAR07.0017/06



# IECEx Certificate of Conformity

Certificate No.:

IECEx BAS 14.0083X

Date of Issue:

2016-11-16

Issue No.: 2

Page 3 of 4

#### Schedule

#### **EQUIPMENT:**

Equipment and systems covered by this certificate are as follows:

The MTL4573 & MTL4573Y Temperature Converters are designed to restrict the transfer of energy from unspecified non-hazardous area or Zone 2 mounted equipment to either thermocouples or resistance temperature detectors (RTD's) located in the hazardous area (Zones 0, 1 or 2) by limitation of voltage and current. A transformer and opto-isolator provide galvanic isolation between the hazardous and non-hazardous area circuitry.

The MTL4573 & MTL4573Y Temperature Converters are designed for connection to thermocouples or two, three or four wire RTD's situated in the hazardous area. The apparatus converts the low level d.c. signal from the sensor mounted in the hazardous area into a 4/20mA current for driving a load in either the non-hazardous area or Zone 2 hazardous area. An optional cold junction compensation (CJC) plug can be fitted to the hazardous area connection which alter the internal connections and affects the output parameters.

The equipment comprises an isolating transformer, an opto-isolator, duplicated zener diode chains and current limiting resistors to provide voltage and current limitation. The above, together with other electronic components are mounted on a printed circuit board (PCB) and housed in a moulded plastic enclosure. Polarised plugs and sockets are provided for hazardous and non-hazardous area connections. A jack socket is provided for the connection of a suitably certified data terminal for programming the equipment during installation and maintenance.

The MTL4573Y Temperature Converter differs from the MTL4573 with regards to the configuration of the non-hazardous area circuitry. In terms of Type 'n' test and assessment, all are identical. This certificate covers the installation of the MTL4573 & MTL4573Y (IECEx BAS 14.0081) in a Zone 2 location. The MTL4573 & MTL4573Y variants are designed to be installed on a separately certified backplane.

See Certificate Annex for electrical parameters.

### SPECIFIC CONDITIONS OF USE: YES as shown below:

- 1) The equipment must be installed in an area of not more than Pollution Degree 2 as defined in IEC 60664-1, and in an enclosure that provides a degree of protection of at least IP54 and meets the relevant requirements of IEC 60079-0 and IEC 60079-15.
- 2) All connections to the equipment must not be inserted or removed unless either the area in which the equipment is installed is known to be non-hazardous, or the circuit to which it is connected has been de-energised.
- 3) Any backplane used does not form part of this certificate and shall be separately certified for use in Zone 2.
- 4) The external backplane must be fitted with two retention clips type MTL 012-533 that allow the equipment to be 'clipped' to the backplane. The retention clips shall always be in place when the equipment is energised.



# IECEx Certificate of Conformity

| 100 |      |     |    |     |   |  |
|-----|------|-----|----|-----|---|--|
| Ce  | rtif | ina | +0 | NI  | - |  |
| CE  | LUI  | IUa | ιe | 1.4 | u |  |

IECEx BAS 14.0083X

Date of Issue:

2016-11-16

Issue No.: 2

Page 4 of 4

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

### Variation 2.1

ExTR: GB/BAS/ExTR16.0241/00

To permit the manufacturer's name to be changed on the certificate and equipment marking. No other changes are made to the equipment design.

File Reference: 16/0371

Annex: IECEx BAS 14.0083X Annex.pdf

## **SGS Baseefa Limited**

Rockhead Business Park Staden lane, Buxton, Derbyshire SK17 9RZ United Kingdom



Date: 2014/07/18

ANNEX to IECEx BAS 14.0083X

Issue No. 0

## MTL4573 & MTL4573Y Temperature Converter

### **Input / Output Parameters**

Supply Circuit - Terminals 13 & 14

Supply Voltage Range = 20 - 35V d.c.

## Thermocouple and 2-, 3- & 4-Wire RTD's Inputs

Terminals 1 to 6 (forming part of the same circuit)

Maximum output voltage = 6.6V

Terminals 1 & 3 (Without the Cold Junction Compensation (CJC) Plug fitted)

Maximum output voltage = 1.1V

Terminals 1, 2 & 3 (with or without CJC plug fitted)

Maximum Output Voltage = 6.6V

Or

The maximum values for the intrinsically safe circuits have to be taken from IECEx Certificate No. IECEx BAS 14.0081.

## Signal Outputs - Terminals 8, 9 & 11

Nominal Output of 4-20mA into a maximum load of  $600\Omega$ .