

# ATEX Category 3 Certificate

Certificate of Conformity for Group II Category 3 G equipment in accordance with Directive 2014/34/EU.

Certificate relating to the following products:-

**SD07, SD16, SD32, SD55 & SDRTD with or without suffix R, X, T3 or R3;  
SD07M, SD16M, SD32M & SD55M with or without suffixes XX, XL, DX, DL;  
SD32-MXX-HC, SD32-MXL-HC; SDBE with suffix -BCN, -BDN, -BCG or -BDG;  
SDBE with suffix -CCN, -CDN, -CCG or -CDG**

This equipment fulfils all the requirements for Group II, Category 3 G equipment in accordance with Directive 2014/34/EU when installed according to the Special Conditions of Safe Use listed below. The design complies with EN IEC 60079-0:2018 and EN 60079-7:2015+A1:2018. The analysis is fully documented in Technical File TF\_SD.

The equipment in normal operation is incapable of producing arcs, sparks or hot surfaces which may cause ignition and is designed to be installed and used in accordance with EN 60079-14:2008 incorporating corrigendum October 2011. Note Special Conditions of Safe Use below.

The required marking of the apparatus is as specified in the Technical File referenced above and includes the distinctive community mark:



In addition, the marking will include the CENELEC codes:

**Ex ec IIC T4 Gc (-30°C ≤ Ta ≤ +75°C) - non HC models**

**Ex ec IIC T3 Gc (-30°C ≤ Ta ≤ +75°C) – HC models**

**Ex ec IIC T4 Gc (-30°C ≤ Ta ≤ +45°C) – HC models**

The equipment is incapable in normal operation of producing sparks or hot surfaces that may cause ignition.

The ambient temperature limitation for the equipment is -30°C to +75°C or -30°C to +45°C.

The apparatus meets the ATEX Directive requirements for electromagnetic radiation by complying with the EMC Directive 2014/30/EU.

The standards published in the Official Journal of the European Commission with reference to the Low Voltage Directive 2014/35/EU have been used to fulfil the requirements of 1.2.7 of Annex II of directive 2014/34/EU to avoid electrical risks.

If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to Special Conditions of Safe Use specified elsewhere in this certificate.

#### Special Conditions of Safe Use

- a. The equipment shall only be installed in an area of at least Pollution Degree 2, as defined in IEC 60664-1, and in an enclosure that provides a degree of protection of at least IP54 and meets the relevant requirements of EN IEC 60079-0 & EN IEC 60079-7.
- b. The equipment may not be capable of withstanding the 500V dielectric strength test in accordance with clause 7.1 of EN IEC 60079-7, and this must be taken into account during installation.
- c. All pluggable connections between the module and base, and where fitted, the disconnect or fuse links must not be inserted or removed unless the area in which the equipment is installed is known to be non-hazardous, or the circuit to which it is connected has been de-energised.
- d. Unused terminals on the equipment shall be tightened.