

स्वीड पोस्ट  
SWISS POST



Government of India  
Ministry of Commerce & Industry  
Petroleum & Explosives Safety Organisation (PESO)  
5th Floor, A-Block, CGO Complex, Seminary Hills,  
Nagpur - 440006



E-mail : explosives@explosives.gov.in

Phone/Fax No : 0712 -2510248, Fax-2510577

Approval No : A/P/HQ/TN/104/5855 (P458611)

Dated : 20/02/2020

To,

24 FEB 2020

M/s. Eaton Electric Ltd.,  
Great Marlings, Butterfield, Bedfordshire, LU2 8DL, Luton  
LU2 8DL  
UK

Sub : Approval of Intrinsically Safe Type Electrical Equ under Petroleum Rules 2002- Regarding.

Sir(s),

Please refer to your letter No. **MTLC/CCOE/D/108** dated **05/12/2019** on the subject.

The following Ex electrical equipment(s) manufactured by you according to **EN 60079-0 : 2012/A11 : 2013, EN 60079-11 : 2012**, standards and covered under **SGS Baseefa Ltd.** Test reports mentioned below is/are approved for use in **Zone 1** of Gas **IIC** hazardous areas coming under the the Petroleum Rules, 2002 administered by this Organization.

Sr. No	Description	Safety Protection	Equipment reference Number	Test Agency			Drawing no
				Name	Certificate No.	Certificate Date	
1	MTL5526 Two Channel Switch-operated Relay Output	[Ex ia Ga] IIC	P458611/1	SGS Baseefa Ltd.	Baseefa08ATEX0084 - Issue 3	05/10/2016	as per test report
2	MTL5514D Single Channel Switch/ Proximity Detector Interface with Dual Output, Line Fault Detection & Phase Reversal	[Ex ia Ga] IIC	P458611/2	SGS Baseefa Ltd.	Baseefa13ATEX0242 - Issue 1	05/10/2016	as per test report
3	MTL5510/ MTL5510B/ MTL5513 Switch/ Proximity Detector Interface	[Ex ia Ga] IIC	P458611/3	SGS Baseefa Ltd.	Baseefa07ATEX0210 - Issue 3	05/10/2016	as per test report
4	MTL5546/ MTL5546Y/ MTL5546Y-T Single Channel Isolating Driver, 4/20mA for Smart I/P Converters	[Ex ia Ga] IIC	P458611/4	SGS Baseefa Ltd.	Baseefa07ATEX0214 - Issue 6	04/04/2017	as per test report
5	MTL552 * Series Solenoid/ Alarm Drivers	[Ex ia Ga] IIC	P458611/5	SGS Baseefa Ltd.	Baseefa07ATEX0212 - Issue 7	27/03/2017	as per test report
6	MTL5501-SR Failsafe Switch/ Proximity Detector Interface	[Ex ia Ga] IIC	P458611/6	SGS Baseefa Ltd.	Baseefa08ATEX0082 - Issue 4	05/10/2016	as per test report
7	MTL5511/ MTL5514/ MTL5514-T/ MTL5516C/ MTL5517 Switch/ Proximity Detector Interface	[Ex ia Ga] IIC	P458611/7	SGS Baseefa Ltd.	Baseefa07ATEX0211 - Issue 7	03/04/2017	as per test report

This Approval is granted subject to observance of the following conditions:-

- 1)The design and construction of the equipment shall be strictly in accordance with description, condition and drawings as mentioned in the SGS Baseefa Ltd. Test Reports referred to above.
- 2)The equipment shall be used only with approved type of accessories and associated apparatus.
- 3)Each equipment shall be marked either by raised lettering cast integrally or by plate attached permanently to the main structure to indicate conspicuously:-
  - (a) Name of the manufacturer
  - (b) Name and number by which the equipment is identified.
  - (c) Number & date of the test report of the SGS Baseefa Ltd. applicable to the equipment.
  - (d) Equipment reference number of this letter by which use of apparatus is approved.
  - (e) Protection level.

- 4) A certificate to the effect that the equipment has been manufactured strictly in accordance with the drawing referred to in the SGS Baseefa Ltd. Test report and is identical with the one tested and certified at SGS Baseefa Ltd. shall be furnished with each equipment.
- 5) The customer shall be supplied with a copy of this letter, an extract of the conditions and maintenance schedule, if any, recommended by SGS Baseefa Ltd. in their test reports and copy of instructions booklet detailing operation & maintenance of the equipment so as to maintain its Flame Proof characteristics.
- 6) The After sales service and maintenance of subject equipment shall be looked after by your representative MTL Instruments Pvt. Ltd., 3, Old Mahabalipuram Road, Sholinganallur, Chennai - 600119

This approval also covers the permissible variations as approved under the SGS Baseefa Ltd. test reports referred above. This approval is liable to be cancelled if any of the conditions of the approval is violated or not complied with. The approval may also be amended or withdrawn at any time, if considered necessary in the interest of safety.

The field performance report from actual users/your customers of the subject equipment may please be collected and furnished to this office for verification and record on annual basis.

The Approval is Valid upto **31/12/2024**

Yours faithfully,

(K Srinivasa Rao)  
Controller of Explosives  
For Chief Controller of Explosives  
Nagpur

Copy to :

1. Jt. Chief Controller of Explosives, South Circle Office, CHENNAI
2. MTL Instruments Pvt. Ltd., 3, Old Mahabalipuram Road, Sholinganallur, Chennai - 600119

for Chief Controller of Explosives  
Nagpur

(For more information regarding status, fees and other details please visit our website <http://peso.gov.in>)

**Note:- Please submit the revalidation application one month before the date of Expiry of approval otherwise approval will be treated as cancelled and a fresh application for approval will be considered for the approval.**