



中国国家强制性产品认证证书



证书编号: 2020322310001821

认证委托人名称: Relcom Inc.
 认证委托人地址: 2221 Yew St, Forest Grove, OR 97116, United States of America
 生产者名称: Relcom Inc.
 生产者地址: 2221 Yew St, Forest Grove, OR 97116, United States of America
 生产企业名称: Relcom Inc.
 生产企业地址: 2221 Yew St, Forest Grove, OR 97116, United States of America

产品名称: 模拟发讯机
 系列、规格、型号: MTL831C, MTL831C-P[S, C]
 标准: GB 3836.1-2010、GB 3836.4-2010

上述产品符合强制性产品认证实施规则 **CNCA-C23-01:2019** 的要求, 特发此证。

发证日期: 2020年9月24日 有效期至: 2025年9月23日

首次发证日期: 2020年9月24日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322310001821

APPLICANT: Relcom Inc.
ADDRESS: 2221 Yew St, Forest Grove, OR 97116, United States of America
MANUFACTURER: Relcom Inc.
ADDRESS: 2221 Yew St, Forest Grove, OR 97116, United States of America
FACTORY: Relcom Inc.
ADDRESS: 2221 Yew St, Forest Grove, OR 97116, United States of America

PRODUCTNAME: Analog Transmitter
SERIES,SPECIFICATION,MODEL: MTL831C, MTL831C-P[S,C]
STANDARDS: GB 3836.1-2010、 GB 3836.4-2010

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:September 24, 2020 **Valid until:** September 23, 2025

Date of original certification:September 24, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA’s website: www.cnca.gov.cn



APPROVAL: 

 Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sifilias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0001131



中国国家强制性产品认证证书



证书编号：2020322310001821

附件

产品名称： 模拟发讯机

型号规格： MTL831C, MTL831C-P[S,C]

其中MTL831C-P[S,C]型号配置有可插拔螺丝端子和可插拔弹簧夹端子，当使用可插拔螺丝端子时，型号为MTL831C-PS，当使用可插拔弹簧夹端子时，型号为MTL831C-PC。

防爆标志： Ex ia IIC T4 Ga

电气参数： $U_i = 24V$, $I_i = 250mA$, $P_i = 1.2W$, $C_i = 0$, $L_i = 0$
 $U_o = 5.88V$, $I_o = 48.1mA$, $P_o = 71mW$

气体级别	简单设备		其他	
	Co (μF)	Lo (mH)	Co (μF)	Lo (mH)
II A	987	369	487	184
II B	987	189	487	94
II C	30	49	9.4	24

批 准：



上海仪器仪表自控系统检验测试所有限公司