

CERTIFICATE OF CONFORMITY



1. **HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS**
2. **Certificate No:** FM19CA0095X
3. **Equipment:** FPS Series. Fieldbus Power Systems.
(Type Reference and Name)
4. **Name of Listing Company:** Relcom Inc.
5. **Address of Listing Company:** 2221 Yew Street
Forest Grove, Oregon 97116
USA
6. The examination and test results are recorded in confidential report number:

3039769 dated 16th August 2010
7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

CSA-C22.2 No. 0:R1991, CSA-C22.2 No. 213:R1987, CSA-C22.2 No. 1010.1:R1992,
CAN/CSA-E60079-0:R2002, CAN/CSA-E60079-15:2002
8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.
10. **Equipment Ratings:**

Nonincendive for use in Class I, Division 2, Groups A, B, C and D, and Non-Sparking for Class I, Zone 2 IIC, Temperature Class T4, with an ambient temperature rating of -40°C to +60°C, indoor Hazardous Locations.
11. The marking of the equipment shall include:

Certificate issued by:



J.E. Marquedant
VP, Manager - Electrical Systems

24 October 2019

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0095X

Class I Division 2, Groups A, B, C, D; T4 Ta = -40°C to +60°C
Class 1, Zone 2, Ex nA, Groups A, B, C, D; T4 Ta = -40°C to +60°C

12. Description of Equipment:

General - The Fieldbus Power System (FPS) provides redundant or dual power conditioning for Fieldbus H1 network segments and facilitates the connection of redundant input power supplies.

Construction - The equipment is provided without a final enclosure. Use in a Class I, Division 2 and or a Class I, Zone 2 Hazardous location(s) requires that the equipment be installed within an enclosure capable of accepting one of the Class I, Division 2 or Zone 2 wiring methods specified in the Canadian Electrical Code (CSA C22.1).

Ratings - The subject equipment operates on an input voltage of 18 to 30 VDC. The Fieldbus Power System (FPS) is rated for use in an ambient temperature range of -40°C to +60°C.

FPS Series. Fieldbus Power Systems.

NI / I / 2 / ABCD / T4 Ta = -40°C to +60°C

I/2/Ex nA/T4, T4 Ta = -40°C to +60°C

Model FPS-1. Redundant Fieldbus Power System with Built-in Terminator. System includes:

- (1) FPS-RCT. Redundant Coupler.
- (2) FPS-A01. Three-Pin Fieldbus Connectors.
- (1) FPS-A03. Power and Alarm Connector.
- (1) FPS-A04. Power and Alarm Jumper Assembly.

Model FPS-2. Redundant Fieldbus Power System without Built-in Terminator. System includes:

- (1) FPS-RC. Redundant Coupler without Terminator.
- (2) FPS-A01. Three-Pin Fieldbus Connectors.
- (1) FPS-A03. Power and Alarm Connector.
- (1) FPS-A04. Power and Alarm Jumper Assembly.

Model FPS-DT. Dual Fieldbus Power System with Built-in Terminators. System includes:

- (1) FPS-DCT. Dual Coupler.
- (4) FPS-A05. Three-Pin Fieldbus Connectors (3.81 mm).
- (1) FPS-A03. Power and Alarm Connector.
- (1) FPS-A04. Power and Alarm Jumper Assembly.

Model FPS-D. Dual Fieldbus Power System without Built-in Terminators. System includes:

- (1) FPS-DC. Dual Coupler without Terminator.
- (4) FPS-A05. Three-Pin Fieldbus Connectors (3.81 mm).
- (1) FPS-A03. Power and Alarm Connector.
- (1) FPS-A04. Power and Alarm Jumper Assembly.

13. Specific Conditions of Use:

The subject equipment shall be installed in accordance with the enclosure, mounting, spacing, and segregation requirements of the ultimate application.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

SCHEDULE

Canadian Certificate Of Conformity No: FM19CA0095X

14. **Test and Assessment Procedure and Conditions:**

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

15. **Schedule Drawings**

A copy of the technical documentation has been kept by FM Approvals.

16. **Certificate History**

Details of the supplements to this certificate are described below:

Date	Description
16 th August 2010	Original Issue.
24 th October 2019	Supplement 1: Report Reference: – RR220666 dated 24 th October 2019. Description of the Change: Removed <i>FPS-IPM. Isolated Power Modules</i> as an FM Approved module. Update to new Certificate format.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE