



中国国家强制性产品认证证书



证书编号: 2020322309003445

认证委托人名称: Eaton Electric Limited
认证委托人地址: Great Marlings Butterfield Luton Bedfordshire LU2 8DL
United Kingdom
生产者名称: Eaton Electric Limited
生产者地址: Great Marlings Butterfield Luton Bedfordshire LU2 8DL
United Kingdom
生产企业名称: Gecma Components electronic GmbH
生产企业地址: Heinrich- Hertz- Strasse 12 50170 Kerpen
产品名称: 防爆操作终端
系列、规格、型号: MTL Gecma 系列
标 准: GB 3836.1-2010、GB 3836.3-2010、GB 3836.4-2010、
GB 3836.9-2014

上述产品符合强制性产品认证实施规则 **CNCA-C23-01:2019** 的要求, 特发此证。

发证日期: 2020 年 12 月 3 日 有效期至: 2025 年 12 月 2 日

首次发证日期: 2020 年 12 月 3 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322309003445

APPLICANT: Eaton Electric Limited
ADDRESS: Great Marlings Butterfield Luton Bedfordshire LU2 8DL
 United Kingdom

MANUFACTURER: Eaton Electric Limited
ADDRESS: Great Marlings Butterfield Luton Bedfordshire LU2 8DL
 United Kingdom

FACTORY: Gecma Components electronic GmbH
ADDRESS: Heinrich- Hertz- Strasse 12 50170 Kerpen

PRODUCTNAME: MTL GECMA Ex Workstation

SERIES,SPECIFICATION,MODEL: MTL Gecma series

STANDARDS: GB 3836.1-2010、GB 3836.3-2010、GB 3836.4-2010、
 GB 3836.9-2014

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:December 3, 2020

Valid until: December 2, 2025

Date of original certification:December 3, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA’s website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0004197



中国国家强制性产品认证证书



SITIIS
Worldwide Access

证书编号: 2020322309003445

附 件

产品名称: 防爆操作终端

型号规格: MTL Gecma aa-bb-cc-dd-ee-fff-gg-h
aa 可为 RT, TC 或 PC
bb 可为 AC 或 DC
cc 可为 Cu, MM 或 SM
dd 可为 19, 22 或 24
ee 可为 Touch 或空白
fff 可为 KBi 或空白
gg 可为 Ji, Mi, TBi, TPi 或空白
h 可为 D 或 G

防爆标志: Ex eb mb [ib] ib IIC T4 Gb

电气参数: AC 版本: 100-230 VAC, 50/60Hz, 1.2A
DC 版本: 18-36 VDC, 5.5A, 100W

批 准:



上海仪器仪表自控系统检验测试所有限公司