

# **1. EU-TYPE EXAMINATION CERTIFICATE**

- 2. Equipment or Protective systems intended for use in Potentially Explosive Atmospheres - Directive 2014/34/EU
- 3. EU-Type Examination Certificate No:
- 4. Equipment or protective system: (Type Reference and Name)
- 5. Name of Applicant:
- 6. Address of Applicant

FM20ATEX0048X

Model MTL831C Analog Transmitter

**Relcom Inc** 

2221 Yew St. Forest Grove, Oregon 97116, USA

- 7. This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and documents therein referred to.
- 8. FM Approvals Europe Ltd, notified body number 2809 in accordance with Article 17 of Directive 2014/34/EU of 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report number:

PR457637 dated 12<sup>th</sup> January 2021

9. Compliance with the Essential Health and Safety Requirements, with the exception of those identified in item 15 of the schedule to this certificate, has been assessed by compliance with the following documents:

EN IEC 60079-0:2018. EN 60079-11:2012

- 10. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
- 11. This EU-Type Examination certificate relates only to the design, examination and tests of the specified equipment or protective system in accordance to the directive 2014/34/EU. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- 12. The marking of the equipment or protective system shall include:

II 1 G Ex ia IIC T4 Ga; -40°C ≤ Tamb ≤ +70°C Ahhlongiz Certificate issued by: Certification Manager, FM Approvals Europe Ltd. Date 23 April 2024 THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE FM Approvals Europe Ltd. One Georges Quay Plaza, Dublin. Ireland. D02 E440 T: +353 (0) 1761 4200 E-mail: atex@fmapprovals.com www.fmapprovals.com Page 1 of 3

F ATEX 020 (Dec/2020)



### 13. Description of Equipment or Protective System:

**General** - The Model MTL831C Series Analog Transmitters convert temperature measurements to an electrical signal or accept mV input signals for delivery to the control room. Each transmitter contains up to 16 sensor inputs.

**SCHEDULE** EU-Type Examination Certificate No. FM20ATEX0048X

**Mechanical** - The Model MTL831C Series Transmitter's enclosure is constructed from polymeric materials. Each transmitter is a rectangular block approximately 188mm (7.4") in length by 74mm (2.9") in width by 48mm (1.9") in depth. The top side has rows of terminal on each side for accepting power and up to 16 analog inputs. The Model MTL831C Transmitter contains fixed recessed screw clamp type terminals and the Model MTL831C-PS Transmitter contains pluggable recessed screw clamp type terminals.

**Ratings** - For type of protection intrinsic safety, connections can only made by connecting certified associated apparatus having energy limitation parameters. The output of the associated apparatus shall not exceed the energy limitation parameters for the Model MTL831C Series Transmitter as shown below.

Intrinsic Safety Energy Limitation Parameters: Ui = 24V, Ii = 250mA, Pi = 1.2W, Ci = 0, Li = 0. Nominal Operation: 10-24VDC, 25-35mA

The Model MTL831C Series Transmitters are rated for an ambient temperature range of -40°C to +70°C.

#### MTL831Ca Analog Transmitter.

a = Terminals: Blank or -PS Energy Limitation Parameters: Ui = 24V, Ii = 250mA, Pi = 1.2W, Ci = 0, Li = 0. Sensor Terminals (Connection to Intrinsically Safe Equipment): Group IIC; Uo = 5.88V, Io = 48.1mA, Po = 71mW, Co =  $9.4\mu$ F, Lo = 7.68mH. Group IIB; Uo = 5.88V, Io = 48.1mA, Po = 71mW, Co =  $487\mu$ F, Lo = 30.73mH. Group IIA; Uo = 5.88V, Io = 48.1mA, Po = 71mW, Co =  $487\mu$ F, Lo = 61.47mH. Sensor Terminals (Connection of Simple Apparatus): Group IIC; Uo = 5.88V, Io = 48.1mA, Po = 71mW, Co =  $30\mu$ F, Lo = 15.36mH. Group IIB; Uo = 5.88V, Io = 48.1mA, Po = 71mW, Co =  $987\mu$ F, Lo = 61.47mH. Group IIB; Uo = 5.88V, Io = 48.1mA, Po = 71mW, Co =  $987\mu$ F, Lo = 61.47mH.

#### 14. Specific Conditions of Use:

1. The surface of the equipment may cause risk of electrostatic discharge. Avoid installation that could cause electrostatic build-up, and only clean with a damp cloth.

#### 15. Essential Health and Safety Requirements:

The relevant EHSRs that have not been addressed by the standards listed in this certificate have been identified and assessed in the confidential report identified in item 8.

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals Europe Ltd. One Georges Quay Plaza, Dublin. Ireland. D02 E440 T: +353 (0) 1761 4200 E-mail: <u>atex@fmapprovals.com</u> <u>www.fmapprovals.com</u>



#### **SCHEDULE** EU-Type Examination Certificate No. FM20ATEX0048X

#### 16. Test and Assessment Procedure and Conditions:

This EU-Type Examination Certificate is the result of testing of a sample of the product submitted, in accordance with the provisions of the relevant specific standard(s), and assessment of supporting documentation. It does not imply an assessment of the whole production.

Whilst this certificate may be used in support of a manufacturer's claim for CE Marking, FM Approvals Europe Ltd accepts no responsibility for the compliance of the equipment against all applicable Directives in all applications.

This Certificate has been issued in accordance with FM Approvals Europe Ltd's ATEX Certification Scheme.

#### 17. Schedule Drawings

A list of the significant parts of the technical documentation is annexed to this certificate and a copy has been kept by the Notified Body.

#### 18. Certificate History

Details of the supplements to this certificate are described below:

Date	Description		
13 January 2021	Original Issue.		
13 July 2021	Supplement 1:   Report Reference: - RR228941 dated 12 <sup>th</sup> July 2021.   Description of the Change:   Corrected Lo values for energy limitation parameters.		
3 March 2023	<u>Supplement 2:</u> Report Reference: – RR235962 dated 23 <sup>rd</sup> February 2023. Description of the Change: Drawing update to include circuit modifications for EMI Improvement		
23 April 2024	Supplement 3: Report Reference: RR240995 dated 15 April 2024. Description of the Changes: Minor updates to drawings that do not affect certification.		

**MApprovals** 

#### THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals Europe Ltd. One Georges Quay Plaza, Dublin. Ireland. D02 E440 T: +353 (0) 1761 4200 E-mail: <u>atex@fmapprovals.com</u> <u>www.fmapprovals.com</u>

# Blueprint Report

# **Relcom Inc (1000006875)**

Class No 3	610		
<b>Original Project</b>	<i>I.D.</i> 457637		
Certificate I.D.	FM20ATEX0048X		
Drawing No.	Revision Level	Drawing Title	Last Report
503-214	F.0	MTL831C[-xx] Analog Transmitter Ex Certification Package	RR240995
503-215	F.0	MTL831C[-xx] Analog Transmitter Ex Safety Instructions	RR240995