

EU - TYPE EXAMINATION CERTIFICATE

- 1
- 2 **Safety Device, Controlling Device or Regulating Device intended for use outside a potentially explosive atmosphere but required for or contributing to the safe functioning of Equipment and Protective Systems with respect to the risks of explosion**
Directive 2014/34/EU
- 3 EU - Type Examination Certificate Number: **SGS24ATEX0059 Issue 0**
- 4 Product: **PCL45USB configurator for MTL converters**
- 5 Manufacturer: **Eaton Electric Limited**
- 6 Address: **Great Marlings, Butterfield, Luton, Bedfordshire, LU2 8DL
United Kingdom**
- 7 This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- 8 SGS Fimko Oy, Notified Body number 0598, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.
- The examination and test results are recorded in confidential Report No. **GB/SGS/ExTR24.0062/00**
- 9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
EN IEC 60079-0: 2018 IEC 60079-11: 2023
- except in respect of those requirements listed at item 18 of the Schedule.
- 10 If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.
- 11 This EU - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.
- 12 The marking of the product shall include the following:
- | | | |
|-------------|-----------------|--------------------|
| ⊕ II (1) GD | [Ex ia Ga] IIC | |
| | [Ex ia Da] IIIC | -10°C ≤ Ta ≤ +60°C |
| ⊕ I (M1) | [Ex ia Ma] I | |

SGS Fimko Oy Customer Reference No. **0703**

Project File No. **24/0080**

This document is issued by the Company subject to their General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of their intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Oy

Takomotie 8
FI-00380 Helsinki, Finland
Telephone +358 (0)9 696 361
e-mail sgs.fimko@sgs.com
web site www.sgs.fi

Business ID 0978538-5 Member of the SGS Group (SGA SA)



Mikko Välimäki
SGS Fimko Oy

13 **Schedule**

14 **Certificate Number SGS24ATEX0059**

15 **Description of Product**

The PCL45USB configurator allows MTL converters to be configured from a standard PC running a Microsoft® Windows® operating system.

This apparatus is an associated electrical apparatus for use in safe areas. Converters can be configured from the safe area, while on-line, and configurations can be saved to disk and printed out when required. It is suitable for use with MTL4500 and MTL5500 range of products.

The configurator is made in a rectangular plastic case, inside of which is located the main electronics of the product. One single printed circuit board (PCBA) holds all electronics.

There are two fixed leads with connectors located on opposite sides of the case for connections:-

- PC side (Safe area connection): cable with USB connector,
- Converter side (Hazardous area connection): cable with 3.5mm 3 pole jack plug for MTL4500 and MTL5500 range of converters.

Input / Output Parameters

Safe Area Connections (USB)

$$U_m = 253V \text{ r.m.s.}$$

Hazardous Area Terminals (3.5mm Jack Plug)

$$\begin{array}{llll} U_o = 6.51V & C_i = 0.3nF & U_i = 8V \\ I_o = 15.2mA & L_i = 1.3\mu H & P_i = 27mW \\ P_o = 25mW \end{array}$$

The capacitance and either the inductance or inductance to resistance ratio (L/R) of the hazardous area terminals must not exceed the following values:

GROUP	CAPACITANCE (μF)	INDUCTANCE (mH)	OR	L/R RATIO ($\mu H/ohm$)
IIC	22	153		1,437
IIB**	500	615		5,749
IIA	1000	1,000		10,000
I	1000	1,000		10,000

** Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

Notes:

- 1) The above load parameters apply when one of the two conditions below is given:
 - the total L_i of the external circuit (excluding the cable) is $< 1\%$ of the L_o value or
 - the total C_i of the external circuit (excluding the cable) is $< 1\%$ of the C_o value.
- 2) The above parameters are reduced to 50% when both of the two conditions below are given:
 - the total L_i of the external circuit (excluding the cable) is $\geq 1\%$ of the L_o value and
 - the total C_i of the external circuit (excluding the cable) is $\geq 1\%$ of the C_o value.

The reduced capacitance of the external circuit (including cable) shall not be greater than $1\mu F$ for Groups IIB, IIA & I and $600nF$ for Group IIC.

16 Report Number

GB/SGS/ExTR24.0062/00

17 Specific Conditions of Use

None.

18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject
1.2.7	Protection against other hazards (LVD type requirements, etc.)
1.2.8	Overloading of equipment (protection relays, etc.)
1.4.1	External effects
1.4.2	Aggressive substances, etc.

19 Drawings and Documents

Number	Sheet	Issue	Date	Description
CIPCL45USB-1	1 to 7	1	30-04-24	PCL45USB Certification Drawing
CI4000-2	1 to 2	2	11.92	MTL4000 Series Double Toroid 2-core I.S. Transformer
CITFR172-1	1 to 2	1	7.24	TFR172 ATEX & IECEX Certification Drawing

The above drawings are associated with IECEX SGS 24.0018 Issue 0.