

1 **UK-TYPE EXAMINATION CERTIFICATE**

2 **Safety Device, Controlling Device or Regulating Device intended for use outside a potentially explosive atmosphere but required for or contributing to the safe functioning of Product and Protective Systems with respect to the risks of explosion**  
**UKSI 2016:1107 (as amended) – Schedule 3A, Part 1**

3 UK-Type Examination Certificate Number: **BAS21UKEX0446**

4 Product: **MTL5549 & MTL5549Y 2 Channel Isolating Driver, 4/20mA for Smart I/P Converters**

5 Manufacturer: **Eaton Electric Limited**

6 Address: **Great Marlings, Butterfield, Luton, Bedfordshire, LU2 8DL**

7 This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 SGS Baseefa, Approved Body number 1180, in accordance with Regulation 43 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended), certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

The examination and test results are recorded in confidential Report No. **21(C)0386/07**

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:  
**EN IEC 60079-0: 2018 EN 60079-11: 2012**

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign “X” is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This UK-TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Regulations apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following:

⊗ II (1) GD [Ex ia Ga] IIC (-20°C ≤ T<sub>a</sub> ≤ +60°C)  
[Ex ia Da] IIIC (-20°C ≤ T<sub>a</sub> ≤ +60°C)

⊗ I (M1) [Ex ia Ma] I (-20°C ≤ T<sub>a</sub> ≤ +60°C)

SGS Baseefa Customer Reference No. **0703**

Project File No. **21/0386**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SGS Baseefa Limited**

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [baseefa@sgs.com](mailto:baseefa@sgs.com) web site [www.sgs.co.uk/sgsbaseefa](http://www.sgs.co.uk/sgsbaseefa)  
Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65  
3EN



R S SINCLAIR  
TECHNICAL MANAGER  
On behalf of SGS Baseefa Limited

13

## Schedule

14

Certificate Number BAS21UKEX0446

### 15 Description of Product

The MTL5549 & MTL5549Y 2 Channel Isolating Driver, 4/20mA for Smart I/P Converters accepts up to two separate 4/20mA signals from controllers located in the non-hazardous area to drive loads in the hazardous area. It permits bi-directional transmission of digital signals to and from an operator station or hand-held communicator. The apparatus restricts the transfer of energy from unspecified non-hazardous area apparatus to intrinsically safe circuit by limitation of voltage and current. Three transformers on each channel provide galvanic isolation between the hazardous and non-hazardous area circuitry.

Each channel of the apparatus comprises a power transformer, two current transformers, zener diodes and current limiting resistors to provide voltage and current limitation. The above, together with other electronic components are mounted on a printed circuit board and housed in a moulded plastic enclosure. Polarised plugs and sockets are provided for hazardous and non-hazardous area connections.

The MTL5549 & MTL5549Y models in terms of intrinsic safety are identical. The difference between them is the MTL5549Y have the Line Fault Detection (LFD) facility disabled.

#### Input/Output Parameters

##### Non-Hazardous Area Terminals 8, 9, 11, 12, 13 & 14

$U_m = 253V$  r.m.s.

The circuit connected to non-hazardous area terminals 8, 9, 11, 12, 13 & 14 are designed to operate from a d.c. supply voltage up to 35V.

##### Hazardous Area Terminals 2 w.r.t. 1 (Channel 1)

Or

##### Hazardous Area Terminals 5 w.r.t. 4 (Channel 2)

$U_o = 28V$   
 $I_o = 93mA$   
 $P_o = 0.65W$   
 $C_i = 0$   
 $L_i = 0$

Each channel must be considered as a separate intrinsically safe circuit

#### Load Parameters

The capacitance and either the inductance or inductance to resistance ratio (L/R) of the load connected must not exceed the following values:

GROUP	CAPACITANCE ( $\mu F$ )	INDUCTANCE (mH)	OR	L/R RATIO ( $\mu H/ohm$ )
IIC	0.083	4.2		56
IIB*	0.65	12.6		210
IIA	2.15	33.6		444
I	3.76	53.7		668

\* Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

Notes:

- 1) The above load parameters apply when one of the two conditions below is given:
  - the total  $L_i$  of the external circuit (excluding the cable) is  $< 1\%$  of the  $L_o$  value or
  - the total  $C_i$  of the external circuit (excluding the cable) is  $< 1\%$  of the  $C_o$  value.
  
- 2) The above parameters are reduced to 50% when both of the two conditions below are given:
  - the total  $L_i$  of the external circuit (excluding the cable) is  $\geq 1\%$  of the  $L_o$  value and
  - the total  $C_i$  of the external circuit (excluding the cable) is  $\geq 1\%$  of the  $C_o$  value.

The reduced capacitance of the external circuit (including cable) shall not be greater than  $1\mu\text{F}$  for Groups IIB, IIA & I and  $600\text{nF}$  for Group IIC.

**16 Report Number**

21(C)0386/07

**17 Specific Conditions of Use**

None

**18 Essential Health and Safety Requirements**

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject	Compliance
13	Protection against other hazards (LVD type requirements, etc.)	Manufacturer responsibility
14	Overloading of equipment (protection relays, etc.)	User/Installer responsibility
22(1)	External effects	User/Installer responsibility
22(2)	Aggressive substances, etc.	User/Installer responsibility

**19 Drawings and Documents**

Number	Sheet	Issue	Date	Description
CI5549-1	1 of 1	5	8.21	MTL5549 Certification Label Details and DIN rail fittings - BASEEFA

These drawings are held with BAS21UKEX0446 (prime).

For other current drawings not re-submitted for this assessment, see Baseefa07ATEX0215 - Issue 4.