

Terminals 1, 3, 4 & 5: Voc <= 6.51V lsc <=

Groups A, B, IIC	Ca ≤ 22µF	La ≤ 355.5mH
Groups C, E, IIB	Ca ≤ 500µF	La ≤ 1,000mH
Groups D, F, G, IIA	Ca ≤ 1000µF	La ≤ 1,000mH

Programming / Configuration port Voc <= 6.68V lsc <= 12mA10mA

Groups A, B, IIC	$Ca \le 0.478 \mu F$	La ≤ 79.4mH
Groups C, E, IIB	Ca ≤ 2.88µF	La ≤ 317.9mH
Groups D, F, G, IIA	Ca ≤ 11.6µF	La ≤ 635.8mH

This component / assembly to be in compliance with RoHS & REACH regulations.				2
Tolerance (Unless Otherwise Stated): $\pm N?A$	Scale: N/A	Drawn by: PT	Drawn Date:	5/23
Title: Control Drawing for the MTL5582B		Drawing Number: SCI-1087		Revision: 1

Е

	1	2		3		4	
Third Angle Projection		Do No	Do Not Scale		All Dimensions in mm		
Date	ate Modification		Powering Bu	Eaton Electric Limited, Great Marlings, Butterfield, Luton, Bedfordshire, England, LU2 8DL Telephone: +44 (0)1582 723633 Web: www.mtl-inst.com Email: mtlenquiry@eaton.com			A
			This drawing and any information or descriptive material set out on it are the confidential and copyright property of Eaton Electric Limited and MUST NOT BE DISCLOSED, COPIED, LOANED in whole or part or used for any purpose without the written permission of Eaton Electric Limited.				
	Note 5						

The MTL5582B is Associated Apparatus and when mounted in the appropriate enclosure (see notes 7 and 8) is suitable for installation in the following areas:

Non - Hazardous Locations

Class I Division 2 Groups A,B,C and D Hazardous Locations Class I Zone 2 Hazardous Locations Class II, Division 2, Groups F,G Hazardous Locations Class III, Division 2, Hazardous Locations

Note 6

Associated Apparatus must be installed in accordance with the National Electrical Code (ANSI/NFPA-70) in an enclosure meeting the requirements of ANSI/ISA 61010-1.

Note 7

Use FMRC Approved or NRTL Listed dust-ignition proof enclosure(s) appropriate for environmental protection in Class II, Division 2, Groups F and G; Class III Division 2 Hazardous Locations.

Note 8

When the MTL5582B is installed in Division 2 Hazardous Locations, a warning label must be prominently affixed near the unit (s) which warns that the MTL5582B must not be removed or inserted unless the area is known to be non-hazardous.

Note 9

Installations in Canada must comply with the Canadian Electrical Code, Part 1 (CSA C22.1).

<u>Note 10</u>

Specific Conditions of Use:

- 1. For equipment installed in the United States: The equipment must be installed in an area of not more than Pollution Degree 2 as defined in IEC 60664-1, and in an enclosure that provides a degree of protection of at least IP54 and meets the relevant requirements of ANSI/UL 60079-0 and ANSI/UL 60079-15.
- 2. For equipment installed in Canada: The equipment must be installed in an area of not more than Pollution Degree 2 as defined in IEC 60664-1, and in an enclosure that provides a degree of protection of at least IP54 and meets the relevant requirements of CSA C22.2 No. 60079-0 and CSA C22.2 No. 60079-15.
- 3. All connections to the equipment must not be inserted or removed unless either the area in which the equipment is installed is known to be non-hazardous, or the circuit to which it is connected has been de-energized.

			-		
This component / assembly to be in compliance with RoHS & REACH regulations.				2	F
Tolerance (Unless Otherwise Stated): ± N?A	Scale: N/A	Drawn by: PT	Drawn Date:	5/23	
Title:		Drawing Number:		Revision:	
Control Drawing for the MTL5582B		SCI-1087		1	
Title: Control Drawing for the MTL5582B		Drawing Number: SCI-1087		Revision:	

В

С

D

E