



Member of the FM Global Group

FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

### ***FBT-6-a Fieldbus Network Monitor***

IS / I / 1 / ABCD / T4 Ta = +50°C - 501-353; Entity; FISCO  
I / 0 / AEx ia IIC T4 Ta = +50°C - 501-353; Entity; FISCO  
IPA / I / 2 / ABCD / T4 Ta = +50°C - 501-353; NIFW, FNICO  
I / 2 / IIC / T4 Ta = 50°C - 501-353; NIFW, FNICO

a = PA or blank

#### Entity parameters

Vmax = 24V  
Imax = 250mA  
Ci = 0  
Li = 0  
Pi = 1.2W  
Voc = 0  
Isc = 0

#### FISCO parameters

Vmax = 17.5V  
Imax = See Table  
Pi = 5.32W  
Ci = 0  
Li = 0  
Voc = 0  
Isc = 0

#### Nonincendive Field Wiring parameters

Vmax = 32V  
Ci = 0  
Li = 0  
Voc = 0  
Isc = 0

#### FNICO parameters

Vmax = 17.5V  
Imax = See Table



Member of the FM Global Group

Ci = 0  
Li = 0  
Voc = 0  
Isc = 0

	Division 1	Division 2
Groups A,B	183 mA	274 mA
Groups C, D	380 mA	570 mA

	Zone 0 and 1	Zone 2
Group IIC	183 mA	274 mA
Group IIB, IIA	380 mA	570 mA

*Special conditions of use*

1. The USB connector shall only be connected to other apparatus when the FBT-6 is located in an unclassified location.

### Equipment Ratings:

Intrinsically safe for Class I, Division 1, Groups A,B,C,&D and Class I, Zone 0, Group IIC when used in accordance with the Entity and FISCO concepts and Control Drawing 501-353. Temperature Class T4 at an ambient of 50°C

Nonincendive for Class I, Division 2, Groups A, B, C, & D and Class I Zone 2 when used in accordance with the NIFW and FNICO concepts and Control Drawing 501-353. Temperature Class T4 at an ambient of 50°C.

### FM Approved for:

Relcom Inc, 2221 Yew St, Forest Grove OR 97116

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

C22.2 No. 157	1992
C22.2 No. 213	1987
CAN/CSA-E79-0-95	1995
CAN/CSA-E79-11-95	1995


Original Project ID: 3028840

Approval Granted: *MARCH 8, 2007*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

  
\_\_\_\_\_  
Roger L. Allard  
Assistant Vice President

*MARCH 8, 2007*  
\_\_\_\_\_  
Date