



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEx BAS 14.0133X** Page 1 of 4 [Certificate history:](#)  
Issue 0 (2014-10-23)

Status: **Current** Issue No: 1

Date of Issue: 2024-04-17

Applicant: **Eaton Electric Limited**  
Great Marlings  
Butterfield  
Luton  
Bedfordshire  
LU2 8DL  
United Kingdom

Equipment: **93ZX-FB-\*\*-\*\* Fieldbus Barrier System**

Optional accessory:

Type of Protection: **Flameproof, Increased Safety, Encapsulation, Intrinsic Safety, Dust Protection by Enclosure**

Marking: **Ex db eb ib mb [ia Ga] IIC T4 Gb**  
**Ex tb III C T80°C Db**  
**(-30°C ≤ T<sub>a</sub> ≤ +65°C)**

Approved for issue on behalf of the IECEx  
Certification Body:

**D Brearley**

Position:

**Certification Consultant**

Signature:  
(for printed version)

Date:  
(for printed version)

17/4/2024

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**SGS UK Limited**  
Rockhead Business Park  
Staden Lane  
Buxton, Derbyshire SK17 9RZ  
United Kingdom





# IECEx Certificate of Conformity

Certificate No.: **IECEx BAS 14.0133X**

Page 2 of 4

Date of issue: 2024-04-17

Issue No: 1

Manufacturer: **Eaton Electric Limited**  
Great Marlings  
Butterfield  
Luton  
Bedfordshire  
LU2 8DL  
**United Kingdom**

Manufacturing locations: **Eaton Electric Limited**  
Great Marlings  
Butterfield  
Luton  
Bedfordshire  
LU2 8DL  
**United Kingdom**

**MTL Instruments Pvt Limited**  
No 3 Old Mahabalipuram Road  
Sholinganallur  
Chennai 600119  
**India**

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

## STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements  
Edition:7.0

[IEC 60079-1:2014](#) Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"  
Edition:7.0

[IEC 60079-11:2011](#) Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"  
Edition:6.0

[IEC 60079-18:2017](#) Explosive atmospheres - Part 18: Protection by encapsulation "m"  
Edition:4.1

[IEC 60079-31:2013](#) Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"  
Edition:2

[IEC 60079-7:2017](#) Explosive atmospheres - Part 7: Equipment protection by increased safety "e"  
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

## TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[GB/BAS/ExTR14.0258/00](#)

[GB/BAS/ExTR16.0282/00](#)

Quality Assessment Reports:

[GB/BAS/QAR06.0022/11](#)

[GB/BAS/QAR07.0017/10](#)



# IECEx Certificate of Conformity

Certificate No.: **IECEx BAS 14.0133X**

Page 3 of 4

Date of issue: 2024-04-17

Issue No: 1

## **EQUIPMENT:**

Equipment and systems covered by this Certificate are as follows:

The 93ZX-FB-\*\*-\*\* Fieldbus Barrier System comprises one or two 937X-FB-\*\*-\*\* Fieldbus Barrier Modules (IECEx BAS 09.0081U) housed inside an appropriately certified stainless steel enclosure. Each 937X-FB-\*\*-\*\* Fieldbus Barrier Module is either a 6 way simplex unit, a 12 way simplex unit or a 5 way redundant unit.

The 93ZX-FB-\*\*-\*\* Fieldbus Barrier System is designed to be supplied from a power supply conforming to IEC 61158 and produce several Spur outputs that are each compliant with the FISCO Power Supply requirements. The Spur outputs are isolated from the input supply but are not isolated from each other. Electrical connections are made via screw terminals.

The 93ZX-FB-\*\*-\*\* Fieldbus Barrier System has a certification temperature range of -30°C to +65°C.

See certificate Annex for the Terminal Parameters.

## **SPECIFIC CONDITIONS OF USE: YES as shown below:**

1. The equipment shall only be powered from supplies conforming to IEC 61158.
2. When a Trunk Surge Module is fitted, the power input circuit will not withstand a 500V a.c. isolation test to earth. This must be taken into account during installation.
3. When one or more Spur Surge Modules are fitted, the spur outputs will not withstand a 500V a.c. isolation test to earth. This must be taken into account during installation.
4. Potential electrostatic hazard. The equipment should only be cleaned with a damp cloth.



# IECEx Certificate of Conformity

Certificate No.: **IECEx BAS 14.0133X**

Page 4 of 4

Date of issue: 2024-04-17

Issue No: 1

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

### Variation 1.1

To permit a change of company name, the addition of an alternative manufacturing site, an update to the referenced standards and the use of alternative enclosures.

ExTR: **GB/BAS/ExTR16.0282/00**

File Reference: **16/0371**

### Annex:

[IECEx BAS 14.0133X Annex 1.pdf](#)

**Terminal Parameters - SPUR+ve Output Terminal and Shield Terminal w.r.t Spur-ve (each channel)**

**9387 & 9388 Units - Simplex Models**

$U_o$	= 17.5V
$I_o$ peak	= 249.5mA
$I_o$ continuous	= 113mA
$P_o$	= 982mW
$U_i$	= 17.5V
$C_i$	= 0
$L_i$	= 0

The capacitance and either the inductance or inductance to resistance ratio (L/R) of the load connected to hazardous area terminals TB1 must not exceed the following values:

GROUP	CAPACITANCE ( $\mu$ F)	INDUCTANCE (mH)	OR	L/R RATIO ( $\mu$ H/ohm)
IIC	0.339	0.57		32.5
IIB	1.97	2.28		130
IIA	8.2	4.57		260

The above parameters apply when one of the two conditions below is given:

- the total  $L_i$  of the external circuit (excluding the cable) is < 1% of the  $L_o$  value or
- the total  $C_i$  of the external circuit (excluding the cable) is < 1% of the  $C_o$  value.

The above parameters are reduced to 50% when both of the two conditions below are given:

- the total  $L_i$  of the external circuit (excluding the cable)  $\geq$ 1% of the  $L_o$  value and
- the total  $C_i$  of the external circuit (excluding the cable)  $\geq$ 1% of the  $C_o$  value.

Note: the reduced capacitance of the external circuit (including cable) shall not be greater than 1 $\mu$ F for Groups IIA & IIB, and 600nF for Group IIC.

The values of  $L_o$  and  $C_o$  determined by this method shall not be exceeded by the sum of all of the  $L_i$  plus cable inductances in the circuit and the sum of all of  $C_i$  plus cable capacitances respectively.

**9391 - Redundant Models**

$U_o$	= 16.4V
$I_o$ peak	= 246mA
$I_o$ continuous	= 215mA
$P_o$	= 912mW
$U_i$	= 17.5V
$C_i$	= 0
$L_i$	= 0

The capacitance and either the inductance or inductance to resistance ratio (L/R) of the load connected to hazardous area terminals TB1 must not exceed the following values:

GROUP	CAPACITANCE ( $\mu\text{F}$ )	INDUCTANCE (mH)	OR	L/R RATIO ( $\mu\text{H}/\text{ohm}$ )
IIC	0.424	0.59		35.2
IIB	2.51	2.35		140
IIA	10.0	4.70		281

The above parameters apply when one of the two conditions below is given:

- the total  $L_i$  of the external circuit (excluding the cable) is  $< 1\%$  of the  $L_o$  value or
- the total  $C_i$  of the external circuit (excluding the cable) is  $< 1\%$  of the  $C_o$  value.

The above parameters are reduced to 50% when both of the two conditions below are given:

- the total  $L_i$  of the external circuit (excluding the cable)  $\geq 1\%$  of the  $L_o$  value and
- the total  $C_i$  of the external circuit (excluding the cable)  $\geq 1\%$  of the  $C_o$  value.

Note: the reduced capacitance of the external circuit (including cable) shall not be greater than  $1\mu\text{F}$  for Groups IIA & IIB, and  $600\text{nF}$  for Group IIC.

The values of  $L_o$  and  $C_o$  determined by this method shall not be exceeded by the sum of all of the  $L_i$  plus cable inductances in the circuit and the sum of all of  $C_i$  plus cable capacitances respectively.