



Member of the FM Global Group

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

F600A-a-b. Redundant Fieldbus Power System.

NI/1/2/ABCD T4 Ta = 60°C

a = Left/right orientation – CL or CR

b = Connection type – ST, PS, PC or PC2

Special Conditions of Use:

The subject equipment shall be installed in accordance with the enclosure, mounting, spacing, and segregation requirements of the ultimate application.

F690A-a-b. Redundant Fieldbus Power System.

NI/1/2/ABCD T4 Ta = 60°C

a = Left/right orientation – CL or CR

b = Connection type – PA, PB, PC or PS

Special Conditions of Use:

The subject equipment shall be installed in accordance with the enclosure, mounting, spacing, and segregation requirements of the ultimate application.

Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups A, B, C, and D, temperature code T4 at 60°C maximum ambient, indoor hazardous (classified) locations

FM Approved for:

Measurement Technology Limited
Luton, Bedfordshire, United Kingdom, LU1 3JJ

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3611	2004
Class 3810	1989
Including Supplement #1	1995


Original Project ID: 3027616

Approval Granted: *October 27, 2006*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC


Robert L. Martell, Jr.
Assistant Vice President

October 27, 2006
Date