



Member of the FM Global Group

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

F801. Field Bus Supply Module and Carriers.

NI / I / 2 / ABCD / T4 Ta = 65 °C

I / 2 / IIC / T4 Ta = 65 °C

Field Bus Supply Module and Carriers combination part numbers: F880-PS, F880-PS-NR, F880-PC, F880-PC-NR, F880-LS, F880-LS-NR, F880-LC, F880-LC-NR, F880-RS, F880-RS-NR, F880-RC, F880-RC-NR, F890-PS, F890-PC, F890-PS-NR, F890-PC-NR, F892-PS, F892-PC, F892-PS-NR, F892-PC-NR

Carrier part numbers: F880-CA-a, F880-CL-a, F880-CR-a, F890-CA-a, F892-CA-a

Where a = None, -PC, or -PS.

Special Condition for use;

- 1. The F801 Field Bus Supply Module and Carriers shall be installed in compliance with the enclosure, mounting, and spacing, and segregation requirement of the ultimate application, including a tool removable cover.*
- 2. When installed in Division 2 Hazardous (classified) locations, a warning label must be prominently affixed near the unit(s) which warns that the cables must not be removed or inserted unless the area is known to be non-hazardous.*

Equipment Ratings:

Nonincendive for Class I, Division 2, Groups A, B, C, and D and Class I, Zone 2, Group IIC hazardous (classified) locations.

FM Approved for:

Relcom Inc
Forest Grove, OR, USA



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

C22.2 No. 213	1987
C22.2 No. 142	1987

Original Project ID: 3025124

Approval Granted:

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

Robert L. Martell, Jr.
Assistant Vice President

Date