

Member of the FM Global Group

FM Approvals 1151 Boston Providence Turnpike P.O. Box 9102 Norwood, MA 02062 USA T: **781 762 4300** F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

F802. Fieldbus Supply Module and Carriers. NI/I/2/ABCD/T4 Ta = 65°C I/2/IIC/T4 Ta = 65°C NI/I/2/ABCD/T4 Ta = 50°C (>60% Load)1/2/IIC/T4 Ta = 50°C (>60% Load)

Fieldbus Supply Module and Carriers combination part numbers: F880-2-PS, F880-2-PS-NR, F880-2-PC, F880-2-PC-NR, F880-2-LS, F880-2-LS-NR, F880-2-LC, F880-2-LC-NR, F880-2-RS, F880-2-RS-NR, F880-2-RC, F880-2-RC-NR, F890-2-PS, F890-2-PC, F890-2-PS-NR, F890-2-PC-NR, F892-2-PS, F892-2-PC, F892-2-PS-NR, F892-2-PC-NR.

Carrier part numbers: F880-CA, F880-CL, F880-CR, F890-CA, F892-CA.

Special Conditions of Use:

- 1. The F802 Fieldbus Supply Module and Carriers shall be installed in compliance with the enclosure, mounting, spacing, and segregation requirements of the ultimate application, including a tool removable cover.
- When installed in hazardous (classified) locations, a warning label must be prominently affixed near the unit(s) which warns that the cables or Fieldbus Supply Modules must not be removed or inserted unless the area is known to be non-hazardous.

Equipment Ratings:

Nonincendive for Class I, Division 2, Groups A, B, C, and D and Class I, Zone 2, Group IIC hazardous locations.

FM Approved for:

Relcom Inc. Forest Grove, OR, USA



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

FM3600

1998

FM3611

2004

FM3810

2005

Original Project ID: 3033657

Approval Granted: Declara 20, 2005

Subsequent Revision Reports / Date Approval Amended

Report Number

Date

Report Number

Date

FM Approvals LLC

Robert L. Martell, Gr

Assistant Vice President

David Gal 30, 2008 Date