

# CERTIFICATE

## (1) EU-Type Examination

(2) **Equipment or protective systems intended for use in potentially explosive atmospheres - Directive 2014/34/EU**

(3) EU-Type Examination Certificate Number: **KEMA 03ATEX1194 X** Issue Number: 8

(4) Product: **Loop Powered Indicator MTL661, MTL662, MTL663 and MTL665**

(5) Manufacturer: **Eaton Electric Limited**

(6) Address: **Great Marlings, Butterfield, Luton, Bedfordshire, LU2 8DL, United Kingdom**

(7) This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) DEKRA Certification B.V., Notified Body number 0344 in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential test report number NL/KEM/ExTR08.0008/04.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN IEC 60079-0 : 2018**

**EN 60079-11 : 2012**

except in respect of those requirements listed at item 18 of the Schedule.

(10) If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

(11) This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

(12) The marking of the product shall include the following:



**II 1 G Ex ia IIC T4 Ga**  
**II 1 D Ex ia IIIC T<sub>200</sub> 100 °C Da**  
**I M1 Ex ia I Ma (Type MTL663 only)**

Date of certification: 30 October 2023

DEKRA Certification B.V.

R. Schuller  
Certification Manager

Page 1/2



© Integral publication of this certificate and adjoining reports is allowed. This Certificate may only be reproduced in its entirety and without any change.

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate KEMA 03ATEX1194 X**

Issue No. 8

(15) **Description**

The 4 ... 20 mA Loop Powered Indicator Model MTL661, Model MTL662, Model MTL663 and Model MTL665 for panel mounting or field mounting, is connected in series in an intrinsically safe circuit. The input circuit of the indicator is designed such, that it does not influence the intrinsically safe circuit to which it is connected.

The indicator may optionally be provided with a backlight (Model MTL66xB).

The enclosure of the indicator provides a degree of protection of at least IP65 in accordance with EN 60529.

Ambient temperature range:

-30 °C to +50 °C for EPL Da.

-30 °C to +70 °C for EPL Db with a maximum dust layer thickness of 5 mm.

-30 °C to +70 °C for all other EPL's.

**Electrical data**

Input circuit (terminals 4 and 5):

in type of protection intrinsic safety Ex ia IIC/IIIC, only for connection to an intrinsically safe circuit, with the following maximum values:

$U_i = 30 \text{ V}$ ;  $I_i = 200 \text{ mA}$ ;  $P_i = 1,2 \text{ W}$ ;  $C_i = 0 \text{ nF}$ ;  $L_i = 0 \text{ mH}$

Backlight circuit (terminals 9 and 10):

in type of protection intrinsic safety Ex ia IIC/IIIC, only for connection to an intrinsically safe circuit, with the following maximum values:

$U_i = 28 \text{ V}$ ;  $I_i = 200 \text{ mA}$  (resistively limited);  $P_i = 0,96 \text{ W}$ ;  $C_i = 0 \text{ nF}$ ;  $L_i = 0 \text{ mH}$

The backlight circuit is separated from the input circuit.

**Installation instructions**

The instructions provided with the product shall be followed in detail to assure safe operation.

(16) **Report Number**

No. NL/KEM/ExTR08.0008/04.

(17) **Specific conditions of use**

When the enclosure of the Indicator is made of aluminium alloy, when used in a potentially explosive atmosphere requiring apparatus of equipment category 1 G, the Indicator shall be installed so, that even in the event of rare incidents, an ignition source due to impact or friction sparks between the enclosure and iron/steel is excluded.

(18) **Essential Health and Safety Requirements**

Covered by the standards listed at item (9).

(19) **Test documentation**

As listed in Report No. NL/KEM/ExTR08.0008/04.