

1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 <http://www.fmglobal.com>

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following company:

Measurement Technology Limited
Power Court, Luton
Bedfordshire, England LU1 3JJ

For:

MTL838B SERIES MULTIPLEXER RECEIVER

MTL838B-a. Multiplexer Receiver

NI/I/2/ABCD/T6 Ta = 50°C

Special Condition of Use:

1. Must be installed in suitable equipment enclosure.

a = Model version HKL, HON or MBF

Equipment Ratings: Nonincendive for installation in Class I, Division 2, Group A, B, C and D
hazardous indoor locations.

Manufactured By: Measurement Technology Limited
Power Court, Luton
Bedfordshire, England LU1 3JJ

FACTORY MUTUAL RESEARCH

This certifies that the equipment described has been found to comply with the following Factory Mutual Research Corporation Approval Standards:


Approval Standard Class 3600 - 1989
Approval Standard Class 3611 - 1986
Approval Standard Class 3810 - 1989

Approval Job Identification: 3002798 Issue Date: November 16, 1999

Related Approval Job Identification: None.

Subsequent Revision Reports/Date Approval Amended: None

Factory Mutual Research Corporation


Frank J. McGowan, Manager
Instrumentation Section
Approval Division

12/9/99
Date