

1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 <http://www.fmglobal.com>

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following company:

Measurement Technology Limited
Power Court, Luton
Bedfordshire, England LU1 3JJ

For:

MTL3052 DIGITAL ISOLATOR

MTL3052 Digital Isolator

AIS/I,II,III/1/ABCDEFG-SCI-223/3; Entity; NI/I/2/ABCD/T6 Ta = 60°C

Entity Parameters: Voc = 15 Vdc, Isc = 83.3 mA, Ca = 0.75 μ F, La = 5.2 mH

Special Condition of Use:

1. Must be installed in suitable equipment enclosure.

Equipment Ratings: Associated Intrinsically Safe apparatus with connections to Class I, II, III Division 1, Group A, B, C, D, E, F and G in accordance with entity requirements and MTL Installation Drawing SCI-223 Issue 3; nonincendive for Class I, Division 2, Group A, B, C and D hazardous indoor locations.

Manufactured By: Measurement Technology Limited
Power Court, Luton
Bedfordshire, England LU1 3JJ

FACTORY MUTUAL RESEARCH

This certifies that the equipment described has been found to comply with the following Factory Mutual Research Corporation Approval Standards:

Approval Standard Class 3600 - 1989
Approval Standard Class 3611 - 1986
Approval Standard Class 3810 - 1989

Approval Job Identification: 0X4Q0.AX

Issue Date: November 14, 1989

Related Approval Job Identification: None.

Subsequent Revision Reports/Date Approval Amended:

J.I. 1T4A0.AX May 3, 1990

J.I. 3002798 November 16, 1999

Factory Mutual Research Corporation



Frank J. McGowan, Manager
Instrumentation Section
Approval Division

12/9/99
Date

Chd		Modification		Dimensions in mm		Do Not Scale		Third Angle Projection																									
				<div><div>Hazardous location mounted equipment See note 1</div><div>See note 4</div><div>Hazardous location mounted equipment See note 1</div></div>		<div><div>50 60 70 80 MTL3052 01 02 03 04</div><div>50 60 70 80 MTL3052 01 02 03 04</div><div>50 60 70 80 MTL3052 01 02 03 04</div></div>		<div><div>Non-Hazardous location equipment See note 2</div><div>Non-Hazardous location equipment See note 2</div><div>Non-Hazardous location equipment See note 2</div></div>																									
Date Drn		Date		HAZARDOUS LOCATION Class I Div.1 Groups A,B,C,D. Class II Div.1 Groups E,F,G. Class III		NON-HAZARDOUS or DIVISION 2 HAZARDOUS LOCATION (See notes 7,8,9)		NON-HAZARDOUS LOCATION																									
Iss		Iss		<p>Note 1 The Hazardous location equipment - simple apparatus that will neither generate nor store more than 1.2V, 0.1A, 25mW or 20µJ; examples are switches. Other apparatus such as LEDs and non-inductive resistors may be used if the auto-ignition temperature of the hazardous location is greater than T4 (275°F or 135°C). Certified devices with correct Entity Concept parameters may also be used.</p> <p>Note 2 The Non-Hazardous Location (or Control room) equipment must not generate or use more than 250Vrms or Vdc.</p> <p>Note 3 For guidance on the installation see ANSI/ISA RP 12.6.</p> <p>Note 4 The following cable parameters must not be exceeded:</p> <table><tr><td>Group</td><td>Capacitance</td><td>Inductance</td></tr><tr><td>D</td><td>0.88 µF</td><td>10.4 mH</td></tr><tr><td>C</td><td>0.33 µF</td><td>3.9 mH</td></tr><tr><td>A + B</td><td>0.11 µF</td><td>1.3 mH</td></tr></table> <p>Note 5 The following cable parameters must not be exceeded:</p> <table><tr><td>Group</td><td>Capacitance</td><td>Inductance</td></tr><tr><td>D</td><td>6.00 µF</td><td>41.6 mH</td></tr><tr><td>C</td><td>2.25 µF</td><td>15.6 mH</td></tr><tr><td>A + B</td><td>0.75 µF</td><td>5.2 mH</td></tr></table> <p>Note 6 Entity Concept Parameters } Voc ≤ 15V Ca ≤ 0.75 µF } For Groups A and B } Terminals 6 & 7 } Isc ≤ 83.3mA La ≤ 5.2 mH }</p> <p>Note 7 The MTL3052 is Associated apparatus and when mounted in the appropriate enclosure (see notes 8 and 9) is suitable for the following areas: Non - Hazardous Locations Class I Division 2 Groups A,B,C and D Hazardous Locations Class II, Division 2, Groups F,G Hazardous Locations Class III, Division 2, Hazardous Locations</p> <p>Note 8 Associated Apparatus must be installed in accordance with the National Electrical Code in an enclosure meeting the requirements of ANSI/ISA - S82.</p> <p>Note 9 Use FMRC Approved or NRTL Listed dust ignition proof enclosure(s) appropriate for environmental protection in class II, Division 2, Groups F and G, Class III Division 2 Hazardous Locations.</p>						Group	Capacitance	Inductance	D	0.88 µF	10.4 mH	C	0.33 µF	3.9 mH	A + B	0.11 µF	1.3 mH	Group	Capacitance	Inductance	D	6.00 µF	41.6 mH	C	2.25 µF	15.6 mH	A + B	0.75 µF	5.2 mH
Group	Capacitance	Inductance																															
D	0.88 µF	10.4 mH																															
C	0.33 µF	3.9 mH																															
A + B	0.11 µF	1.3 mH																															
Group	Capacitance	Inductance																															
D	6.00 µF	41.6 mH																															
C	2.25 µF	15.6 mH																															
A + B	0.75 µF	5.2 mH																															
System Certificate No.		N/A		Scale		N/A																											
Certifying Authority:		FACTORY MUTUAL		Sheet		1 of 1																											
Title		INSTALLATION FOR THE MTL3052		Drg. No.		SCI-223																											