



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

Member of the FM Global Group

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

9211 Tofino™

NI/I/2/ABCD/T4 Ta = 70°C; SCI-1032;

I/2/AEx nC/IIC/T4 Ta = 70°C

Special Condition of Use:

1) In Class I, Division 2 installations, the subject equipment shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I, Division 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70).

2) In Class I, Zone 2 installations, the subject equipment shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I, Zone 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70). Where installed in outdoor or potentially wet locations, the enclosure shall, at a minimum, meet the requirements of IP54. Where installed in dry indoor locations, the enclosure shall, at a minimum, meet the requirements of IP4X.

Equipment Ratings:

Nonincendive for Class I, Division 2, Groups A, B, C, and D; Zone 2, AEx nC IIC T4 Ta = 70°C; in accordance with Control Drawing No. SCI-1032, indoor hazardous (classified) locations.

FM Approved for:

Measurement Technology Limited
Power Court, Luton Bedfordshire, England LU1 3JJ



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3611	2004
Class 3810	2005


Original Project ID: 3029914

Approval Granted: *DECEMBER 20, 2007*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC


Robert L. Martell, Jr.
Assistant Vice President

DECEMBER 20, 2007
Date