

British Approvals Service for Electrical Equipment in Flammable Atmospheres

1. **CERTIFICATE OF CONFORMITY**

2. BAS No Ex 882115

3. This certificate is issued for the intrinsically safe electrical system:

AN MTL 2213 3-CHANNEL SWITCH/PROXIMITY DETECTOR RELAY SYSTEM

4. submitted for certification by:

MEASUREMENT TECHNOLOGY LIMITED  
of Luton, Bedfordshire, LU1 3JJ

5. This electrical system and any acceptable variation thereto is specified in the Schedule to this Certificate and the documents therein referred to.

6. BASEEFA confirms that the system has been found to comply with European Standard BS 5501:Part9:1982 EN50 039

Relevant examination and test requirements are recorded in confidential Test Report No 88(i)053 dated 10 March 1988

7. This system is coded EEx ia IIC T4

8. The supplier and/or user of the intrinsically safe electrical system referred to in this certificate, has the responsibility to ensure that the system conforms to the specification laid down in the Schedule to this certificate and has satisfied routine verifications and tests specified therein.

File No: EECs 0703/02/018



IM

I M CLEAVE  
DIRECTOR  
10 March 1988

Sheet 1/3

This certificate is granted subject to conditions applicable to the Approval Service, it does not necessarily indicate that the apparatus may lawfully be used in particular industries or circumstances.

# CERTIFICATE OF CONFORMITY

# SCHEDULE

NUMBER Ex 882115

DATED 10 March 1988

## SYSTEM

An MTL 2213 3-CHANNEL SWITCH/PROXIMITY DETECTOR RELAY SYSTEM comprises:

1. Apparatus located in a non-hazardous area (Safe Area).

1.1 An MTL 2213 3-Channel Switch/Proximity Detector Relay (Certificate No Ex 88B2114).

1.2 Apparatus which is unspecified except that it must not be supplied from nor contain in normal or abnormal conditions a source of potential with respect to earth in excess of 250 volts r.m.s. or 250 volts d.c.

2. Apparatus which may be located in a Hazardous Area.

2.1 Apparatus which meets the requirements of Clause 1.3 of EN50 014 and installed in accordance with Clauses 4.1 and 5 of EN50 020.

3. Permissible Interconnecting Cables.

3.1 The Capacitance and Inductance OR Inductance to Resistance (L/R) ratio of the interconnecting cables must not exceed the following values:

GROUP	CAPACITANCE in $\mu\text{F}$	INDUCTANCE in mH	OR	L/R RATIO in $\mu\text{H}/\text{ohm}$
IIC	2.4	165		825
IIB	7.2	495		2475
IIA	19.2	1320		6600

## DRAWING Number

SCI-166  
Sheet 1 of 2

## Issue

1

## Date

Oct 87

## Description

MTL 2213 System

# CERTIFICATE OF CONFORMITY

# SCHEDULE

**NUMBER** Ex 882115

**DATED** 10 March 1988

**VARIATION ONE**

To permit the use of an MTL 2220 Earth Leakage Detector (Certificate No Ex 802327), located in a non-hazardous (safe) area, in the above system.

The Capacitance and Inductance OR Inductance to Resistance (L/R) ratio of the interconnecting cables must not exceed the following values:

GROUP	CAPACITANCE in $\mu\text{F}$	INDUCTANCE OR in mH	L/R RATIO in $\mu\text{H}/\text{ohm}$
IIC	0.44	165	825
IIB	1.32	495	2475
IIA	3.52	1320	6600

**DRAWING  
Number**

SCI-166  
Sheet 2 of 2

**Issue**

1


**Date**

Oct 87

**Description**

MTL 2213 with MTL 2220  
Earth Leakage Detector

See note 3 for cable parameters



NOTE! No safety earth required.

← HAZARDOUS AREA | SAFE AREA →

Note 1. Safe area apparatus - unspecified except that it must not be supplied from nor contain under normal or abnormal conditions a source of potential with respect to earth in excess of 250V r.m.s. or 250V d.c.

Note 2. Hazardous area apparatus - must meet the requirement of clause 1.3 of EN50 014 and must be selected and installed to meet the requirements of EN50 020, in particular with respect to clauses 4.1 and 5.

Note 3. The following cable parameters must not be exceeded (applies to each channel):-

Group	Capacitance	Inductance	or	L/R ratio
IIA	19.2 $\mu$ F	1320 mH		6600 $\mu$ H/ $\Omega$
IIB	7.2 $\mu$ F	495 mH		2475 $\mu$ H/ $\Omega$
IIC	2.4 $\mu$ F	165 mH		825 $\mu$ H/ $\Omega$

Note 4. Where the hazardous area cables are part of a multicore, they must be part of a Type A or Type B multicore cable (as defined in Clause 5.3 of BS5501: Part 9:1982 EN50 039). The peak voltage of any circuit contained within the multicore must not exceed 60 volts.

Note 5. For intrinsic safety purposes, the MTL2213 output circuit is considered to be a source of power with a maximum open circuit voltage of 10.5 volts, a maximum open circuit voltage of 10.5 volts, a maximum short circuit current of 14mA and a source resistance of 800 ohms minimum.

Note 6. When only one channel is used then the apparatus in the hazardous area need not meet the 500V insulation requirement provided there is no other earth connection. Otherwise the hazardous area apparatus must be capable of withstanding an a.c. test voltage of 500V r.m.s. with respect to earth or frame of the apparatus for a period of one minute without breakdown (d.c. resistance and impedance at 50 Hz shall not be less than 100K $\Omega$ ).

BASEEFA System Certificate no.Ex882115 Code EEx ia IIC T4

Used on Certifying Authority:- BASEEFA

Scale

Tolerance unless otherwise stated  $\pm$


Sheet 1 of 2

Title Installation drawing for the MTL2213 3-channel switch/proximity detector relay.




Drg. No. SCI-166

MEASUREMENT TECHNOLOGY LTD.  
Luton, England.  
Copyright Reserved - Written Permission  
to Copy Should be Obtained

Iss.	1
Date/Drawn	10.87/DRG
Modification	
Chk	





See note 3 for cable parameters



NOTE! No safety earth required

These terminals may or may not be connected to any number of MTL 2213 units.

This may be connected within the safe area



HAZARDOUS AREA

SAFE AREA

Note 1. Safe area apparatus - unspecified except that it must not be supplied from nor contain under normal or abnormal conditions a source of potential with respect to earth in excess of 250V r.m.s. or 250V d.c.

Note 2. Hazardous area apparatus - must meet the requirement of clause 1.3 of EN50 014 and must be selected and installed to meet the requirement of EN50 020, in particular with respect to clauses 4.1 and 5.

Note 3. The following cable parameters must not be exceeded (applies to each channel):-

Group	Capacitance	Inductance	or	L/R ratio
IIA	3.52 $\mu$ F	1320 mH		6600 $\mu$ H/ $\Omega$
IIB	1.32 $\mu$ F	495 mH		2475 $\mu$ H/ $\Omega$
IIC	0.44 $\mu$ F	165 mH		825 $\mu$ H/ $\Omega$

Note 4. Where the hazardous area cables are part of a multicore, they must be part of a Type A or Type B multicore cable (as defined in Clause 5.3 of BS5501: Part 9:1982 EN50 039). The peak voltage of any circuit contained within the multicore must not exceed 60 volts.

Note 5. For intrinsic safety purposes, the MTL2213 output circuit is considered to be a source of power with a maximum open circuit voltage of 10.5 volts, a maximum short circuit current of 14mA and a source resistance of 800 ohms minimum.

Note 6. The circuit in the hazardous area must be capable of withstanding a test voltage of 500 volts r.m.s. with respect to earth or frame of the apparatus for a period of one minute without breakdown (d.c. resistance and impedance at 50 Hz not be less than 100K $\Omega$ ).

Iss.	1
Date/Drawn	10.87/DRG
Modification	
Chk	

Used on Certifying Authority:- BASEEFA

Scale

Tolerance unless otherwise stated  $\pm$

Sheet 2 of 2

Title Installation drawing for the MTL2213 3-channel switch/proximity detector relay with the MTL2220

Drg. No.

SCI-166

British Approvals Service for Electrical Equipment in Flammable Atmospheres

## CERTIFICATE OF CONFORMITY VARIATION


THIS IS TO CERTIFY THAT CERTIFICATE OF CONFORMITY BAS NO Ex 882115

Issued to                   MEASUREMENT TECHNOLOGY LIMITED  
                                  of Luton, Beds  
                                  LU1 3JJ

for the                     MTL 2213 3-CHANNEL SWITCH/PROXIMITY DETECTOR  
                                  RELAY SYSTEM

is hereby extended to the apply to the system designed and constructed in accordance with the specification set out in the Schedule of the said Certificate but having the variations specified in the attached Schedule.

File: EECS 0703/02/018



CERTIFICATE OF CONFORMITY BAS NO Ex 882115/1  
Sheet 1/3  
BA

I M CLEARE  
DIRECTOR EECS  
20 September 1989

# CERTIFICATE OF CONFORMITY

# SCHEDULE

**NUMBER** Ex 882115/1

**DATED** 20 September 1989

## VARIATION TWO

To permit an alternative method of connection between the apparatus at Items 1.1 and 2.1 of the schedule.

The cable parameters are amended as follows:

GROUP	CAPACITANCE in $\mu\text{F}$	INDUCTANCE in mH	OR	L/R RATIO in $\mu\text{H}/\text{ohm}$
IIC	2.4	165		583.3
IIB	7.2	495		1750
IIA	19.2	1320		4666.7

## DRAWINGS

Number	Issue	Date	Description
SCI-220 Sheet 1 of 3	1	4.89	MTL 2213 system

## VARIATION THREE

To permit the use of an MTL Earth Leakage Detector (Certificate No Ex 802327), located in a non-hazardous (safe) area in the system outlined at Variation Two.

The cable parameters are amended as follows:-

GROUP	CAPACITANCE in $\mu\text{F}$	INDUCTANCE in mH	OR	L/R RATIO in $\mu\text{H}/\text{ohm}$
IIC	0.44	165		583.3
IIB	1.32	495		1750
IIA	3.52	1320		4666.7

## DRAWINGS

Number	Issue	Date	Description
SCI-220 Sheet 2 of 3	1	4.89	MTL 2213 system with Earth Leakage detector

## VARIATION FOUR

To permit the use of an additional MTL 2213 3-Channel Switch/ Proximity Detector Relay at Item 1.1 of the Schedule, with the optional use of an MTL 2220 Earth Leakage Detector (Cert. No. Ex 802327).

The cable parameters are amended as follows:-

# CERTIFICATE OF CONFORMITY



# SCHEDULE

**NUMBER** Ex 882115/1  
**DATED** 20 September 1989

---

GROUP	CAPACITANCE in $\mu$ F	INDUCTANCE OR inmH	L/R RATIO in $\mu$ H/ohm
IIC	0.27 (0.13)	50 (50)	291.6 (291.6)
IIB	0.81 (0.39)	150 (150)	875 (875)
IIA	2.16 (1.04)	400 (400)	2333.3 (2333.3)

---


The figures in parentheses are when the MTL 2220 Earth Leakage Detector is used.

## DRAWINGS

Number	Issue	Date	Description
SCI-220 Sheet 3 of 3	1	4.89	MTL 2213 system



See note 3 below



**NOTE!** No safety earth required.

**NOTE 1:** Safe Area Apparatus - unspecified, except that it must not be supplied from nor contain under normal or abnormal conditions a source of potential with respect to earth in excess of 250V. rms or 250V d.c.

**NOTE 2:** Hazardous Area Apparatus - must meet the requirements of clause 1.3 of EN50 014 and must be selected and installed to meet the requirements of EN50 020, in particular with respect to clauses 4.1 and 5. When the hazardous area apparatus are switches the system may be classified T6.

**NOTE 3:** The following cable parameters must not be exceeded:

Group	Capacitance	Inductance	or	L/R Ratio
IIA	19.2 $\mu$ F	1320 mH		4666.7 $\mu$ H/ $\Omega$
IIB	7.2 $\mu$ F	495 mH		1750 $\mu$ H/ $\Omega$
IIC	2.4 $\mu$ F	165 mH		583.3 $\mu$ H/ $\Omega$

**NOTE 4:** Where the hazardous area cables are part of a multicore cable, they must be part of a Type A or Type B multicore (as defined in Clause 5.3 of BS5501:Part 9:1982 EN50 039). The peak voltage of any circuit contained within the multicore must not exceed 60 volts.

**NOTE 5:** The circuit in the hazardous area must be capable of withstanding a test voltage of 500 volts rms with respect to earth or frame of the apparatus for a period of one minute without breakdown (d.c. resistance and impedance at 50Hz not less than 100K $\Omega$ ).

**NOTE 6:** The installation must comply with National Requirements (e.g. in the UK generally BS5345:Part 4:1977).


BASEEFA System Certificate No. Ex882115

Code EEx ia IIC T4

Iss.	1
Date/Drawn	4.89/DRG
Modification	
Chk	

CERTIFYING AUTHORITY: BASEEFA		Scale
Tolerance unless otherwise stated $\pm$		Sheet 1 of 3
Title MTL 2213 3-channel switch/proximity detector relay - Installation with commoned inputs		Drg. No. SCI-220

Iss.	1
Date/Drawn	4.89/DRG
Modification	
Chk	




These terminals may or may not be connected to any number of MTL 2213 units.

This may be connected within the safe area

MTL 2220

NOTE! No safety earth required



HAZARDOUS AREA

SAFE AREA

**NOTE 1:** Safe Area Apparatus - unspecified except that it must not be supplied from nor contain under normal or abnormal conditions a source of potential with respect to earth in excess of 250V r.m.s. or 250V d.c.

**NOTE 2:** Hazardous Area Apparatus - must meet the requirements of clause 1.3 of EN50 014 and must be selected and installed to meet the requirements of EN50 020 in particular with respect to clauses 4.1 and 5. When the hazardous area apparatus are switches the system may be classified T6.

**NOTE 3:** The following cable parameters must not be exceeded:-

Group	Capacitance	Inductance	or	L/R Ratio
IIA	3.52 $\mu\text{F}$	1320 mH		4666.7 $\mu\text{H}/\Omega$
IIB	1.32 $\mu\text{F}$	495 mH		1750 $\mu\text{H}/\Omega$
IIC	0.44 $\mu\text{F}$	165 mH		583.3 $\mu\text{H}/\Omega$

**NOTE 4:** Where the hazardous area cables are part of a multicore cable, they must be part of a Type A or Type B multicore (as defined in clause 5.5 of BS5501:Part 9:1982 EN50 039).

**NOTE 5:** The circuit in the hazardous area must be capable of withstanding a test voltage of 500 volts rms with respect to earth or frame of the apparatus for a period of one minute without breakdown (d.c. resistance and impedance at 50Hz not less than 100K  $\Omega$ ).

**NOTE 6:** The installation must comply with National requirements (e.g. in the UK generally BS5345:Part 4:1977).

CERTIFYING AUTHORITY: BASEEFA


Scale

Tolerance unless otherwise stated  $\pm$

Sheet 2 of 3

Title MTL 2213 3-channel switch/proximity detector relay - Installation with commoned input

Drg. No.  
SCI -220



**NOTE 1:** The following cable parameters must not be exceeded (the figures in ( ) apply when an MTL 2220 is connected).

Group	Capacitance	Inductance	or	L/R Ratio
IIA	2.16 (1.04)	400 (400) mH		2333.3 (2333.3) $\mu\text{H}/\Omega$
IIB	0.81 (0.39)	150 (150) mH		875 ( 875 ) $\mu\text{H}/\Omega$
IIC	0.27 (0.13)	50 ( 50) mH		291.6 ( 291.6) $\mu\text{H}/\Omega$

**NOTE 2:** The notes on the previous sheets also apply to this arrangement.

Ch

Modification

Date/Drawn

4.89/DRG

Iss.

1

CERTIFYING AUTHORITY: BASEEFA

Scale

Tolerance unless otherwise stated  $\pm$

Sheet 3 of 3

Title MTL 2213 3-channel switch/proximity detector relay - Installation with commoned input

Drg. No.

SCI-220