

1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

MTL 4840 HART® Connection System

NI/1/2/ABCD/T4 Ta = 60°C

MTL4841	Communication Module
MTL4842	HART Interface Module
BPMH64	HART Backplane
HCU16	HART Connection Unit
HCU1492AO	16-Ch. Analogue Output HART Interface
HCU1492AO-CC	16-Ch. Analogue Output HART Interface
HCU1492AI	16-Ch. Analogue Input HART Interface
HCU1492AI(-CC)	16-Ch. Analogue Input HART Interface
MTL HM64RIB-XX	Ribbon Cable
BUSRIB-XX	Ribbon Cable.
XX = Cable Length	

Special conditions:

Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application

Equipment Ratings:

Nonincendive for Class I Division 2 Groups ABCD
Indoor Hazardous (Classified) Locations

Approved for:

Measurement Technology Limited
Power Court
Luton Bedfordshire LU1 3JJ, England


This certifies that the equipment described has been found to comply with the following
Factory Mutual Research Approval Standards and other documents:

Class 3600	1998
Class 3611	1999
Class 3810	1989
Including Supplement #1	1995

Original Approval Job Identification: 3009149 Approval Granted: June 10, 2002

Subsequent Revision Reports / Date Approval Amended

Factory Mutual Research Corporation



David W. Styracula
Technical Team Manager
Approvals Division

June 18, 2002
Date