



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

Member of the FM Global Group

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

TPa-b. TP Series Surge Protectors.

IS / I,II,III / 1 / ABCDEFG / T* Ta = 60°C - 801640**; Entity;
I / 0 / AEx ia / IIC / T* Ta = 60°C - 801640**; Entity;
XP / I / 1 / ABCD / T6 Ta = 60°C; DIP / II,III / 1 / EFG / T6 Ta = 60°C;
NI / I / 2 / ABCD / T6 Ta = 60°C;
NI / I / 2 / IIC / T6 Ta = 60°C; S / II / 2 / FG / T6 Ta = 60°C; Type 4X

Entity Parameter Models 48, 48-3, 48-4, P48: Vmax = 60V, I_{max} = 250 mA, Pi = 1.2W, Ci = 0, Li = 0
Entity Parameter Models 24/7, 32, P32: Vmax = 17.5V, I_{max} = 183 mA, Pi = 2.56W, Ci = *, Li = 0

* For b = T-, Ci = 1.1 µf, T* = T4 else Ci = 0, T* = T6

a = Model: 24/7, 32, 48, 48-3, 48-4, P32, P48,

b = Connection: N, N-NDI, I, I-NDI, T-N, T-I, T-N-NDI, T-I-NDI, G-NDI

FP32. FP Series Surge Protectors.

IS / I, / 1 / ABCD / T4 Ta=60°C - 500182; Entity, Fisco
I / 0 / AEx ia / IIC / T4 Ta = 60°C - 500182; Entity, Fisco
I / 0 / AEx ia / IIB / T3 Ta = 60°C - 500182; Entity, Fisco
NI / I / 2 / ABCD / T6 Ta = 60°C;
NI / I / 2 / IIC / T6 Ta = 60°C

Entity Parameter: Vmax = 17.5V, I_{max} = 183 mA, Pi = 2.56W, Ci = 0, Li = 0

Fisco Parameter: Vmax = 17.5V, I_{max} = 380 mA, Pi = 5.32W, Ci = 0, Li = 0

Special Condition of use

The FP series shall be installed in compliance with the enclosure, mounting, and spacing, and segregation requirement of the ultimate application.



Member of the FM Global Group

IOPab. IOP Series Surge Protectors.

IS / I, / 1 / ABCD / T4 Ta=60°C - 801689; Entity,
I / 0 / AEx ia / IIC / T4 Ta = 60°C - 801689; Entity,
I / 0 / AEx ia / IIB / T3 Ta = 60°C - 801689; Entity,
NI / I / 2 / ABCD / T6 Ta = 60°C,
NI / I / 2 / IIC / T6 Ta = 60°C

a = Model: 32

b = D, Blank

Entity Parameter: $U_i = 32V$, $I_i = 250\text{ mA}$, $P_i = 1.2W$, $C_i = 0$, $L_i = 0$

Special Condition of use

The IOP series shall be installed in compliance with the enclosure, mounting, and spacing, and segregation requirement of the ultimate application.

SLPab. SLP Series Surge Protectors.

IS / I, / 1 / ABCD / T4 Ta=60°C - 801744; Entity,
I / 0 / AEx ia / IIC / T4 Ta = 60°C - 801744; Entity,
I / 0 / AEx ia / IIB / T3 Ta = 60°C - 801744; Entity,
NI / I / 2 / ABCD / T6 Ta = 60°C,
NI / I / 2 / IIC / T6 Ta = 60°C

a = Model: 7, 16, 32

b = D, Blank

Entity Parameter Model 7: $U_i = 7V$, $I_i = 250\text{ mA}$, $P_i = 1.2W$, $C_i = 0$, $L_i = 0$

Entity Parameter Model 16: $U_i = 16V$, $I_i = 250\text{ mA}$, $P_i = 1.2W$, $C_i = 0$, $L_i = 0$

Entity Parameter Model 32: $U_i = 32V$, $I_i = 250\text{ mA}$, $P_i = 1.2W$, $C_i = 0$, $L_i = 0$

Special Condition of use

The SLP series shall be installed in compliance with the enclosure, mounting, and spacing, and segregation requirement of the ultimate application.

Equipment Ratings:

TP Series:

Intrinsically safe for use in Class I, II, III Division 1, Groups A, B, C, D, E, F, G and Class I, Zone 0, Group IIC in accordance with manufacturer's Control Drawing; Explosionproof for Class I, Division 1, Groups A, B, C, and D; Dust-ignitionproof for Class II and III, Division 1, Groups E, F, and G; Nonincendive for Class I, Division 2, Groups A, B, C, D and Class I, Zone 2, Group IIC, Special Protection for Class II, Division 2, Groups F, G, Hazardous (Classified) Indoor/Outdoor (TYPE 4X) Locations

FP, IOP, SLP Series:

Intrinsically safe for use in Class I, II, III Division 1, Groups A, B, C and D and Class I, Zone 0, Groups IIC and IIB in accordance with manufacturer's Control Drawing; Nonincendive for Class I, Division 2, Groups A, B, C, D and Class I, Zone 2, Group IIC Hazardous (Classified) Indoor Locations

FM Approved for:

Cooper Crouse-Hinds MTL Inc/ MTL Surge Technologies
West Melbourne, FL USA 32904



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

| | |
|----------------|------|
| C22.2 No. 213 | 1987 |
| C22.2 No. 142 | 1987 |
| C22.2 No. 94 | 1991 |
| C22.2 No. 157 | 1992 |
| C22.2 No. 30 | 1986 |
| ANSI/NEMA 250 | 1991 |
| CAN/CSA-E79-0 | 2002 |
| CAN/CSA-E79-11 | 2002 |

Original Project ID: 3025374

Approval Granted: December 14, 2005

Subsequent Revision Reports / Date Approval Amended

| Report Number | Date | Report Number | Date |
|---------------|-------------------|---------------|------|
| 060821 | December 12, 2006 | | |
| 070122 | May 31, 2007 | | |
| 100902 | September 3, 2010 | | |
| 110113 | February 11, 2011 | | |

FM Approvals LLC

J.E. Marquedant
Group Manager, Electrical

11 February 2011
Date