

1 **EU - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 2014/34/EU**

3 EU - Type Examination Certificate **Baseefa09ATEX0180X – Issue 2**
Number:

3.1 In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.

4 Product: **FS32/FS32G Fieldbus Surge Protection Device**

5 Manufacturer: **Eaton Electric Limited**

6 Address: **Great Marlings, Butterfield, Luton, Bedfordshire, LU2 8DL**

7 This re-issued certificate extends EC Type Examination Certificate No. Baseefa09ATEX0180X to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

8 SGS Baseefa, Notified Body number 1180, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. **See Certificate History**

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0:2012 + A11: 2013 EN 60079-11: 2012

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign “X” is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following :

⊕ II 1G Ex ia IIB T3 Ga or Ex ia IIC T4 Ga (See Schedule)
(-40°C ≤ Ta ≤ +50°C or +75°C) (See Schedule)

SGS Baseefa Customer Reference No. **0703**

Project File No. **16/0371**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited


Rockhead Business Park, Staden Lane,
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601

e-mail baseefa@sgs.com web site www.sgs.co.uk/baseefa

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN



R S SINCLAIR

TECHNICAL MANAGER

On behalf of SGS Baseefa Limited

13

Schedule

14

Certificate Number Baseefa09ATEX0180X – Issue 2

15 Description of Product

The FS32/FS32G Fieldbus Surge Protection Devices are designed as a FISCO Field Device, to provide protection for sensitive electronic Fieldbus compatible equipment, and are intended to be mounted either in a Safe Area immediately following a certified FISCO Power Supply having an intrinsically safe output or within a Hazardous Area connected in an intrinsically safe circuit.

The FS32/FS32G Fieldbus Surge Protection Devices have identical circuits but differ in the physical arrangement of the connecting pins. Both units do not in themselves provide any intrinsically safe voltage or current limiting functions and must be supplied from a suitably certified intrinsically safe FISCO source. They connect across the positive and negative lines with screen and earth, and all connections must form part of the same intrinsically safe circuit.

The units comprise a diode bridge circuit, two gas discharge tubes, a silicon avalanche diode and two metal oxide varistors mounted on a printed circuit board. This assembly is housed within a plastic enclosure, with the lower section encapsulated, which is provided with a three pin input connector and a three pin output connector. An additional central M3 screw provides the earth connection and two M2.5 screws provide the mounting arrangement.

The FS32/FS32G Fieldbus Surge Protection Devices are considered to be coded Ex II 1G Ex ia IIB T3 Ga (-40°C ≤ Ta ≤ 50°C) when supplied from a Certified FISCO [Ex ia] Group IIB source.

FS32/FS32G Fieldbus Surge Protection Device, either Top Connector J1 or Bottom Connector J2 Pins "+", "S" or "-".

$$\begin{aligned}U_i &= 17.5V \\I_i &= 380mA \\P_i &= 5.32W \\C_i &= 0 \\L_i &= 0\end{aligned}$$

FS32/FS32G Fieldbus Surge Protection Device, either Top Connector J1 or Bottom Connector J2 Pins "+", "S" or "-".

$$\begin{aligned}U_o &= U_i \\I_o &= I_i \\P_o &= P_i\end{aligned}$$

The cable parameters associated with the Field and Surge Protected Connectors will be determined by the source supplying the intrinsically safe circuit.

The input power and current may be reduced from 5.32W and 380mA to 2.56W and 183mA respectively. The FS32/FS32G Fieldbus Surge Protection Devices are considered to be coded Ex II 1G Ex ia IIC T4 Ga (-40°C ≤ Ta ≤ 50°C) when supplied from a Certified FISCO [Ex ia] Group IIC source.

FS32/FS32G Fieldbus Surge Protection Device, either Top Connector J1 or Bottom Connector J2 Pins "+", "S" or "-".

$$\begin{aligned}U_i &= 17.5V \\I_i &= 183mA \\P_i &= 2.56W \\C_i &= 0 \\L_i &= 0\end{aligned}$$

FS32/FS32G Fieldbus Surge Protection Device, either Top Connector J1 or Bottom Connector J2 Pins "+", "S" or "-".

$$\begin{aligned}U_o &= U_i \\I_o &= I_i \\P_o &= P_i\end{aligned}$$

The input power may be further reduced to 1.8W. The FS32/FS32G Fieldbus Surge Protection Devices are considered to be coded Ex II 1G Ex ia IIC T4 Ga (-40°C ≤ Ta ≤ 75°C) when supplied from a Certified [Ex ia] Group IIC source.

FS32/FS32G Fieldbus Surge Protection Device, either Top Connector J1 or Bottom Connector J2 Pins “+”, “S” or “-”.

$$\begin{aligned} I_i &= 380\text{mA} \\ P_i &= 1.8\text{W} \\ C_i &= 0 \\ L_i &= 0 \end{aligned}$$

FS32/FS32G Fieldbus Surge Protection Device, either Top Connector J1 or Bottom Connector J2 Pins “+”, “S” or “-”.

$$\begin{aligned} U_o &= U_i \\ I_o &= I_i \\ P_o &= P_i \end{aligned}$$

16 Report Number

GB/BAS/ExTR16.0326/00

17 Specific Conditions of Use

1. The FS32/FS32G Fieldbus Surge Protection Devices may not be capable of withstanding the 500V voltage withstand test for one minute without breakdown to earth. This must be taken into consideration in any installation.
2. When the FS32/FS32G Fieldbus Surge Protection Devices are mounted within a Hazardous Area the plastic enclosure is considered to present a potential electrostatic risk. Do not rub or clean with solvents.
3. The FS32/FS32G Fieldbus Surge Protection Devices do not meet the requirements of IP20 at the top and bottom connectors. This must be taken into consideration in any installation and once installed the overall assembly must meet the requirements of IP20.

18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject
1.4.1	External effects
1.4.2	Aggressive substances, etc.

19 Drawings and Documents

New drawings submitted for this issue of certificate:

Number	Sheet	Issue	Date	Description
1100526	1-6	B	8.16	FS32 / FS32G Certification Drawing

The above drawing is associated and held with IECEx BAS 09.0083X Iss. 3

Current drawings which remain unaffected by this issue:

Number	Sheet	Issue	Date	Description
1301923	1	B	23-APR-13	Heatsink

The above drawing is associated and held with IECEx BAS 09.0083X

20 Certificate History

Certificate No.	Date	Comments
Baseefa09ATEX0180X	30 September 2009	The release of the prime certificate. The associated test and assessment against the requirements of EN 60079-0: 2006 And EN60079-7: 2007 is documented in Test Report No. GB/BAS/ExTR/09.0118/00 and project 09/0095.
Baseefa09ATEX0180X/1	24 October 2013	To confirm that the equipment conforms to the requirements of EN60079-0: 2012 and EN60079-11: 2012
Baseefa09ATEX0180X Issue 2	12 June 2017	<p>This issue of the certificate incorporates previously issued primary & supplementary certificates into one certificate and confirms the current design meets the requirements of EN 60079-0: 2012 + A11: 2013.</p> <p>The certificate also permits the manufacturer's name to be changed on the certificate and the equipment marking. No other changes are made to the equipment design.</p> <p>The associated assessment is documented in Certification Report No. GB/BAS/ExTR16.0326/00, Project File No. 16/0371.</p>
For drawings applicable to each issue, see original of that issue.		