



FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

*Member of the FM Global Group*

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

**MTL4995, MTL5995 and MTL5995-PS. Isolated Fieldbus Power Supply**  
NI / I / 2 / ABCD / T6 Ta = 60°C – SCI-763

Equipment Ratings:

Nonincendive for Class I, Division 2, Groups A, B, C and D, T6 Ta = 60°C hazardous (classified)  
indoor locations in accordance with installation drawing SCI-763

FM Approved for:

Measurement Technology Ltd  
Great Marlings, Butterfield, Luton, United Kingdom



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1989
Class 3611	1999
Class 3810	1989

Original Project ID: 3001197

Approval Granted: June 15, 1998

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
980807	July 20, 1998		
3005744	October 7, 1999		
081003	March 27, 2008		

FM Approvals LLC

  
 J. E. Marquedant  
 Group Manager, Electrical

Re-issued 11 June 2010  
 Date