

British Approvals Service for Electrical  
Equipment in Flammable Atmospheres



## Certificate of Conformity

1

2

BAS No. Ex 98E2203

3

This certificate is issued for the intrinsically safe electrical system:

**AN MTL8000 I/O SERIES SYSTEM WITH I.S. FIELD TERMINALS**

4

Submitted for certification by:

**MEASUREMENT TECHNOLOGY LTD**  
of Power Court, Luton, Bedfordshire, LU1 3JJ

5

This electrical system and any acceptable variation thereto is specified in the Schedule to this Certificate and the documents therein referred to.

6

BASEEFA being an Approved Certification Body in accordance with Article 14 of the Council Directive of the European Communities of 18 December 1975 (76/117/EEC) certifies that the system has been found to comply with harmonised European Standards:

**EN50 039: 1980**

and has successfully met the examination and test requirements recorded in confidential Report number:

**98(C)0333 dated 11 December 1998**

7

The system is coded:

**EEx ia IIC (-40°C ≤ Ta ≤ +70°C)**

8

It is the responsibility of the system certificate holder to supply the relevant documentation to the installer of the intrinsically safe electrical system referred to in this certificate.

The installer has the responsibility to ensure that the system conforms to the specification laid down in the Schedule to this certificate and has satisfied routine verifications and tests specified therein.

9

This system may be marked with the Distinctive Community Mark specified in Annex II to the Commission Directive of 16 January 1984 (Doc 84/47/EEC). A facsimile of this mark is printed on sheet 1 of this certificate.

File No: EECS 0703/02/259

Sheet 1 of 3

This certificate is granted subject to the general conditions of the Electrical Equipment Certification Service. It does not necessarily indicate that the system may be used in particular industries or circumstances. A system is an assembly of apparatus (all of which are subject to certification and licensing requirements in their own right) and is therefore not listed on an EECS Manufacturing Licence.



I M CLEARE  
DIRECTOR

11 December 1998



Registration Number  
020  
The use of the Accreditation  
Mark indicates accreditation in  
respect of those activities  
covered by the accreditation  
certificate number 020.



**Electrical Equipment Certification Service**  
Health and Safety Executive  
Harpur Hill, Buxton, Derbyshire. SK17 9JN, United Kingdom  
Tel: 01298 28000 Fax: 01298 28244



Certificate of Conformity BAS No. Ex 98E2203

**SYSTEM DESCRIPTION**

An MTL8000 I/O Series System with I.S. Field Terminals comprising of:-

1. Apparatus located in the non-hazardous area (safe area).
  - 1.1 An MTL8000 I/O Node with I.S. Field Terminals to BASEEFA Certificate No. BAS98ATEX7202 and coded [EEx ia] IIC in an ambient temperature of -40°C to +70°C.
  - 1.2 Connections to the hazardous area are made via the following I/O modules and field terminals:-
    - i) An 8215-DO-IS, 4-Channel IS DO, solenoid driver to Component Certificate No. BAS98ATEX7204U. Terminations will be made via either an 8621-FT-IS, IS field terminals or an 8622-FT-IS, IS field terminal, loop-disconnect to Component Certificate No. BAS98ATEX7211U.
    - ii) An 8204-AO-IS, 8-Channel IS AO, 4-20mA to Component Certificate No. BAS98ATEX7205U. Terminations will be made via either an 8621-FT-IS, IS field terminals or an 8622-FT-IS, IS field terminal, loop-disconnect to Component Certificate No. BAS98ATEX7211U.
    - iii) An 8220-DI-IS, 16-Channel IS DI, switch/proximity detector or 8220-DI-IS, 8-Channel IS DI, switch/proximity detector to Component Certificate No. BAS98ATEX7206U. Terminations will be made via an 8624-FT-IS, IS field terminal, 8-channel DI to Component Certificate No. BAS98ATEX7211U
    - iv) An 8201-HI-IS, 8-Channel IS AI, 4-20mA with HART to Component Certificate No. BAS98ATEX7207U. Terminations will be made via either an 8621-FT-IS, IS field terminals or an 8622-FT-IS, IS field terminal, loop-disconnect to Component Certificate No. BAS98ATEX7211U
  - 1.3 The MTL 8000 I/O Node with I.S. Field Terminals is to be supplied from apparatus which is unspecified except that it must not be supplied from nor contain in normal or abnormal conditions a source of potential with respect to earth in excess of 250 volts r.m.s. or 250 volts d.c.
2. Apparatus which may be located in the Hazardous Area
  - 2.1 Devices i.e. switches, thermocouples, PRTs or resistors meeting the requirements of Clause 5.4 of EN50020: 1994. The PRTs and resistors must have a surface area of between 20mm<sup>2</sup> and 10cm<sup>2</sup>. They must be provided with a degree of protection of at least IP20, be installed in accordance with the requirements of clause 6 of EN50 020: 1994 and must be capable of withstanding an a.c. test voltage of 500V r.m.s. to earth, or to the frame of the equipment, without breakdown. Such devices do not require to be certified or marked.



Certificate of Conformity BAS No. Ex 98E2203

3. Permissible Interconnecting Cables.

- 3.1 The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area cables must not exceed the load parameter values detailed in the individual Component Certificates for each individual I/O module.
- 3.2 Wiring to terminals of the appropriate I/O module may be achieved by separate cables or by separate circuits within a Type A or Type B multicore cable (as defined in clause 5.3 of EN50 039) subject to the following:-
- The circuit to be individually screened when used within a Type A multicore cable.
  - The peak voltage of any other circuit within a Type B multicore cable must not exceed 60V.

**DRAWINGS**

| Number   | Sheet | Issue | Date  | Description                 |
|----------|-------|-------|-------|-----------------------------|
| *SCI-784 | 1     | 3     | 12.98 | Common Installation Drawing |
| *SCI-784 | 2     | 3     | 12.98 | Common Installation Drawing |
| *SCI-784 | 3     | 3     | 12.98 | Common Installation Drawing |
| SCI-784  | 4     | 3     | 12.98 | System Information          |
| SCI-785  | 1     | 3     | 12.98 | 8201 System                 |
| SCI-785  | 2     | 3     | 12.98 | 8201 System                 |
| SCI-786  | 1     | 3     | 12.98 | 8204 System                 |
| SCI-786  | 2     | 3     | 12.98 | 8204 System                 |
| SCI-787  | 1     | 3     | 12.98 | 8215 System                 |
| SCI-787  | 2     | 3     | 12.98 | 8215 System                 |
| SCI-788  | 1     | 3     | 12.98 | 8220 System                 |
| SCI-788  | 2     | 3     | 12.98 | 8220 System                 |

Drawings marked \* are held on BASEEFA Certificate No. BAS98ATEX7202

BASEEFA List Keywords

2ISOLBAR

British Approvals Service for Electrical  
Equipment in Flammable Atmospheres



## Certificate of Conformity - Variation

SUPPLEMENTARY CERTIFICATE BAS No. Ex 98E2203/1

This is to certify that System Certificate number:

**Ex 98E2203**

held by:

**MEASUREMENT TECHNOLOGY LTD**

of:

**Power Court, Luton, Bedfordshire, LU1 3JJ**

for the:

**MTL 8000 I/O SERIES SYSTEM WITH I.S. FIELD TERMINALS**


is hereby extended to apply to the system designed and constructed in accordance with the specification set out in the Schedule of the said Certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This Supplementary Certificate shall be held with the original Certificate.

File No: EECS 0703/02/259

Sheet 1 of 2

This certificate is granted subject to the general conditions of the Electrical Equipment Certification Service. It does not necessarily indicate that the apparatus may be used in particular industries or circumstances. A system is an assembly of apparatus (all of which are subject to certification and licensing requirements in their own right) and is therefore not listed on an EECS Manufacturing Licence.



IM CLEARE  
DIRECTOR  
30 June 1999



Registration Number  
020  
The use of the Accreditation  
Mark indicates accreditation in  
respect of those activities  
covered by the accreditation  
certificate number 020.



**Electrical Equipment Certification Service**  
Health and Safety Executive  
Harpur Hill, Buxton, Derbyshire, SK17 9JN, United Kingdom  
Tel: 01298 28000 Fax: 01298 28244

British Approvals Service for Electrical  
Equipment in Flammable Atmospheres



## *Schedule*

Supplementary Certificate BAS No. Ex 98E2203/1

### VARIATION ONE

To permit the apparatus listed in Item 1.2 iii) of the original schedule to be extended to include the option of an 8623-FT-IS, IS Field Terminal, 16 Channel DI introduced at Variation One BAS98ATEX7211U/1.

### DRAWINGS

| <u>Number</u> | <u>Sheet</u> | <u>Issue</u> | <u>Date</u> | <u>Description</u>          |
|---------------|--------------|--------------|-------------|-----------------------------|
| *SCI-784      | 1            | 4            | 6.99        | Common Installation Drawing |
| *SCI-784      | 2            | 4            | 6.99        | Common Installation Drawing |
| *SCI-784      | 3            | 4            | 6.99        | Common Installation Drawing |
| SCI-784       | 4            | 4            | 6.99        | System Information          |

\*These drawings are held on BASEEFA Certificate No BAS98ATEX7202/1

British Approvals Service for Electrical  
Equipment in Flammable Atmospheres



## *Certificate of Conformity - Variation*

SUPPLEMENTARY CERTIFICATE BAS No. Ex 98E2203/2

This is to certify that System Certificate number:

**Ex 98E2203**

held by:

**MEASUREMENT TECHNOLOGY LTD**

of:

**Power Court, Luton, Bedfordshire, LU1 3JJ**

for the:

**MTL 8000 I/O SERIES SYSTEM WITH I.S. FIELD TERMINALS**


is hereby extended to apply to the system designed and constructed in accordance with the specification set out in the Schedule of the said Certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This Supplementary Certificate shall be held with the original Certificate.

File No: EECS 0703/02/259

Sheet 1 of 2

This certificate is granted subject to the general conditions of the Electrical Equipment Certification Service. It does not necessarily indicate that the apparatus may be used in particular industries or circumstances. A system is an assembly of apparatus (all of which are subject to certification and licensing requirements in their own right) and is therefore not listed on an EECS Manufacturing Licence.



I M CLEARE  
DIRECTOR  
18 April 2000



Registration Number  
020  
The use of the Accreditation  
Mark indicates accreditation in  
respect of these activities  
covered by the accreditation  
certificate number 020.



**Electrical Equipment Certification Service**  
Health and Safety Executive  
Harpur Hill, Buxton, Derbyshire. SK17 9JN. United Kingdom  
Tel: 01298 28000 Fax: 01298 28244

British Approvals Service for Electrical  
Equipment in Flammable Atmospheres



## Schedule

Supplementary Certificate BAS No. Ex 98E2203/2

### VARIATION TWO

To permit the apparatus listed in Item 1.2 of the original schedule to be extended to include the option of alternative modules;

- (v) MTL8205-TI-IS, 8 Channel IS, Thermocouple Input, BASEEFA Component Certificate No BAS99ATEX7316U with the hazardous area terminations made by certified IS field terminals 8625-FT-IS Thermocouple Field Terminals, BASEEFA Component Certificate No BAS98ATEX7211U/4.
- (vi) MTL8206-TI-IS, 8 Channel IS, RTD Input, BASEEFA Component Certificate No BAS99ATEX7316U with the hazardous area terminations made by certified IS field terminals 8626-FT-IS RTD Field Terminals, BASEEFA Component Certificate No BAS98ATEX7211U/4.

### DRAWINGS

| <u>Number</u> | <u>Sheet</u> | <u>Issue</u> | <u>Date</u> | <u>Description</u>          |
|---------------|--------------|--------------|-------------|-----------------------------|
| *SCI-784      | 1            | 5            | 1/00        | Common Installation Drawing |
| *SCI-784      | 2            | 5            | 1/00        | Common Installation Drawing |
| *SCI-784      | 3            | 5            | 1/00        | Common Installation Drawing |
| *SCI-784      | 4            | 5            | 1/00        | Common Installation Drawing |
| SCI-784       | 5            | 5            | 1/00        | System Information          |
| SCI-853       | 1            | 1            | 12/99       | 8205 System                 |
| SCI-853       | 2            | 1            | 12/99       | 8205 System                 |
| SCI-854       | 1            | 1            | 12/99       | 8206 System                 |
| SCI-854       | 2            | 1            | 12/99       | 8206 System                 |

\*These drawings are held on BAS98ATEX7202/2

British Approvals Service for Electrical  
Equipment in Flammable Atmospheres



## *Certificate of Conformity - Variation*

SUPPLEMENTARY CERTIFICATE BAS No. Ex 98E2203/3

This is to certify that System Certificate number:

**Ex 98E2203**

held by:

**MEASUREMENT TECHNOLOGY LIMITED**

of:

**Luton, Bedfordshire, LU1 3JJ**

for the:

**MTL8000 I/O SERIES SYSTEM WITH I.S. FIELD TERMINALS**

is hereby extended to apply to the system designed and constructed in accordance with the specification set out in the Schedule of the said Certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This Supplementary Certificate shall be held with the original Certificate.

File No: EECS 0703/02/259

Sheet 1 of 2

This certificate is granted subject to the general conditions of the Electrical Equipment Certification Service. It does not necessarily indicate that the apparatus may be used in particular industries or circumstances. A system is an assembly of apparatus (all of which are subject to certification and licensing requirements in their own right) and is therefore not listed on an EECS Manufacturing Licence.



**I M CLEARE  
DIRECTOR**

9 November 2000



Registration Number  
0210  
The use of the Accreditation  
Mark indicates accreditation in  
respect of those activities  
covered by the accreditation  
certificate number 020.

  
**HSE**  
Health & Safety  
Executive

**Electrical Equipment Certification Service**  
Health and Safety Executive  
Harpur Hill, Buxton, Derbyshire, SK17 9JN, United Kingdom  
Tel: 01298 28000 Fax: 01298 28244



British Approvals Service for Electrical  
Equipment in Flammable Atmospheres



## Schedule

Supplementary Certificate BAS No. Ex 98E2203/3

### VARIATION THREE

To permit drawing changes associated with changes to the MTL8000 I/O Node with Intrinsically Safe Field Terminals to BASEEFA Certificate No BAS98ATEX7202/3.

### DRAWINGS

| <u>Number</u> | <u>Sheet</u> | <u>Issue</u> | <u>Date</u> | <u>Description</u>          |
|---------------|--------------|--------------|-------------|-----------------------------|
| SCI-784       | 1 to 5       | 6            | 10.00       | Common Installation Drawing |

These drawings are held on BASEEFA Certificate No BAS98ATEX7202/3

British Approvals Service for Electrical  
Equipment in Flammable Atmospheres



## Certificate of Conformity - Variation

SUPPLEMENTARY CERTIFICATE BAS No. Ex 98E2203/4

This is to certify that System Certificate number:

**Ex 98E2203**

held by:

**MEASUREMENT TECHNOLOGY LIMITED**

of:

**Power Court, Luton, Bedfordshire, LU1 3JJ**

for the:

**MTL 8000 I/O SERIES SYSTEM WITH I.S. FIELD TERMINALS**


is hereby extended to apply to the system designed and constructed in accordance with the specification set out in the Schedule of the said Certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This Supplementary Certificate shall be held with the original Certificate.

File No: EECS 0703/02/259

Sheet 1 of 2

This certificate is granted subject to the general conditions of the Electrical Equipment Certification Service. It does not necessarily indicate that the apparatus may be used in particular industries or circumstances. Representation of equipment as "Certified" is valid only when the number of the prime certificate to which this certificate is a supplement is given on the relevant EECS Manufacturing Licence or Verification Certificate.



**I M CLEARE**  
**DIRECTOR**

15 December 2000



Registration Number  
020  
The use of the Accreditation  
Mark indicates accreditation in  
respect of those activities  
covered by the accreditation  
certificate number 020.



**Electrical Equipment Certification Service**  
Health and Safety Executive  
Harpur Hill, Buxton, Derbyshire. SK17 9JN. United Kingdom  
Tel: 01298 28000 Fax: 01298 28244

British Approvals Service for Electrical  
Equipment in Flammable Atmospheres



## Schedule

Supplementary Certificate BAS No. Ex 98E2203/4

### VARIATION FOUR

To permit the apparatus listed in Item 1.2 of the original schedule to be extended to include the option of an alternative module;

- (v) MTL8223-PI-IS, 2 Channel Pulse Input Module, BASEEFA Component Certificate No BAS00ATEX7202U with the hazardous area terminations made by certified IS field terminals 8621-FT-IS, IS Field Terminals or 8622-FT-IS, IS Field Terminals, Loop Disconnect, BASEEFA Component Certificate No BAS98ATEX7211U.

### DRAWINGS

| <u>Number</u> | <u>Sheet</u> | <u>Issue</u> | <u>Date</u> | <u>Description</u>          |
|---------------|--------------|--------------|-------------|-----------------------------|
| *SCI-784      | 1            | 7            | 11/00       | Common Installation Drawing |
| *SCI-784      | 2            | 7            | 11/00       | Common Installation Drawing |
| *SCI-784      | 3            | 7            | 11/00       | Common Installation Drawing |
| *SCI-784      | 4            | 7            | 11/00       | Common Installation Drawing |
| SCI-784       | 5            | 7            | 11/00       | System Information          |
| SCI-929       | 1-5          | 1            | 11/00       | 8223 System                 |

\* These drawings are held on BAS98ATEX7202/4



British Approvals Service for Electrical  
Equipment in Flammable Atmospheres



## *Certificate of Conformity - Variation*

SUPPLEMENTARY CERTIFICATE BAS No. Ex 98E2203/5

This is to certify that System Certificate number:

**Ex 98E2203**

held by:

**MEASUREMENT TECHNOLOGY LIMITED**

of

**Power Court, Luton, Bedfordshire, LU1 3JJ**

for the:

**MTL 8000 I/O SERIES SYSTEM WITH I.S. FIELD TERMINALS**

is hereby extended to apply to the system designed and constructed in accordance with the specification set out in the Schedule of the said Certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This Supplementary Certificate shall be held with the original Certificate.

File No: EECS 0703/02/259

Sheet 1 of 2



**I M CLEARE  
DIRECTOR**

17 September 2001

This certificate is granted subject to the general conditions of the Electrical Equipment Certification Service. It does not necessarily indicate that the system may be used in particular industries or circumstances. A system is an assembly of apparatus (all of which are subject to certification and licensing requirements in their own right) and is therefore not listed on EECS Manufacturing Licence.



**Electrical Equipment Certification Service**  
Health and Safety Executive  
Harpur Hill, Buxton, Derbyshire, SK17 9JN, United Kingdom  
Tel: +44 (0)1298 28000 Fax: +44 (0)1298 28244  
internet: www.baseefa.com e-mail: baseefa.info.eecs@hsl.gov.uk



British Approvals Service for Electrical  
Equipment in Flammable Atmospheres



## Schedule

Supplementary Certificate BAS No. Ex 98E2203/5

### VARIATION FIVE

To permit the apparatus listed in Item 1.2 of the original schedule to be extended to include the option of an alternative module;

- (viii) MTL8202-HO-IS, 8 Channel IS AO, 4-20mA with HART Module, BASEEFA Component Certificate No BAS01ATEX7185U with the hazardous area terminations made by certified IS field terminals 8621-FT-IS, IS Field Terminals or 8622-FT-IS, IS Field Terminals, Loop Disconnect, BASEEFA Component Certificate No BAS98ATEX7211U.

### DRAWINGS

| <u>Number</u> | <u>Sheet</u> | <u>Issue</u> | <u>Date</u> | <u>Description</u>          |
|---------------|--------------|--------------|-------------|-----------------------------|
| *SCI-784      | 1            | 8            | 05/01       | Common Installation Drawing |
| *SCI-784      | 2            | 8            | 05/01       | Common Installation Drawing |
| *SCI-784      | 3            | 8            | 05/01       | Common Installation Drawing |
| *SCI-784      | 4            | 8            | 05/01       | Common Installation Drawing |
| *SCI-784      | 5            | 8            | 05/01       | Common Installation Drawing |
| SCI-784       | 6            | 8            | 05/01       | System Information          |
| SCI-940       | 1-2          | 1            | 05/01       | 8202 System                 |

\* These drawings are held on BAS98ATEX7202/6



British Approvals Service for Electrical  
Equipment in Flammable Atmospheres



## Certificate of Conformity - Variation

SUPPLEMENTARY CERTIFICATE BAS No. Ex 98E2203/6

This is to certify that System Certificate number:

**Ex 98E2203**

held by:

**MEASUREMENT TECHNOLOGY LIMITED**

of

**Luton, Bedfordshire, LU1 3JJ**

for the:

**MTL 8000 I/O SERIES SYSTEM WITH I.S. FIELD TERMINALS**

is hereby extended to apply to the system designed and constructed in accordance with the specification set out in the Schedule of the said Certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This Supplementary Certificate shall be held with the original Certificate.

File No: EECS 0703/02/259

Sheet 1 of 2

This certificate is granted subject to the general conditions of the Electrical Equipment Certification Service. It does not necessarily indicate that the system may be used in particular industries or circumstances. A system is an assembly of apparatus (all of which are subject to certification and licensing requirements in their own right) and is therefore not listed on EECS Manufacturing Licence.



JP

**I M CLEARE**  
**DIRECTOR**  
14 December 2001



**Electrical Equipment Certification Service**  
Health and Safety Executive  
Harpur Hill, Buxton, Derbyshire, SK17 9JN, United Kingdom  
Tel: +44 (0)1298 28000 Fax: +44 (0)1298 28244  
internet: www.baseefa.com e-mail: baseefa.info.eecs@hsl.gov.uk



020





British Approvals Service for Electrical  
Equipment in Flammable Atmospheres



## Schedule

Supplementary Certificate BAS No. Ex 98E2203/6

### VARIATION SIX

To permit the apparatus listed in Item 1.2 of the original schedule to be extended to include the option of an alternative module;

- (ix) MTL8230-AI-IS, 8 Channel IS Analogue Input Module, BASEEFA Component Certificate No BAS01ATEX7346U with the hazardous area terminations made by certified IS field terminals 8623-FT-IS, IS Field Terminals BASEEFA Component Certificate No BAS98ATEX7211U.

### DRAWINGS

| <u>Number</u> | <u>Sheet</u> | <u>Issue</u> | <u>Date</u> | <u>Description</u>          |
|---------------|--------------|--------------|-------------|-----------------------------|
| *SCI-784      | 1            | 9            | 9.01        | Common Installation Drawing |
| *SCI-784      | 2            | 9            | 9.01        | Common Installation Drawing |
| *SCI-784      | 3            | 9            | 9.01        | Common Installation Drawing |
| *SCI-784      | 4            | 9            | 9.01        | Common Installation Drawing |
| *SCI-784      | 5            | 9            | 9.01        | Common Installation Drawing |
| SCI-784       | 6            | 9            | 9.01        | System Information          |
| SCI-941       | 1-3          | 1            | 9.01        | 8230 System                 |

\*These drawings are held on BAS98ATEX7202/7





---

## Certificate of Conformity - Variation

This is to certify that System Certificate number: **Ex 98E2203**  
issued to: **Measurement Technology Limited**  
of: **Luton, Bedfordshire, LU1 3JJ**  
for the: **MTL8000 I/O Series System with IS Field Terminals**

is hereby extended to apply to the system conforming with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This Supplementary Certificate shall be held with the original Certificate

The Electrical Equipment Certification Service, retains responsibility for its original documentation. Baseefa is responsible only for the additional work relating to this supplementary certificate and any other supplementary certificate that it has issued.

This certificate may only be reproduced in its entirety, without any change, Schedule included.

Baseefa Customer Reference No. 0703

Project File No. 06/0947

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

R S SINCLAIR

DIRECTOR

On behalf of  
Baseefa (2001) Ltd.

### Baseefa

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa (2001) Ltd  
Registered in England No. 4305578 at the above address





---

---

## Schedule

### Description of the variation

#### Variation 7.1

To permit the system drawings to be updated, following the transfer of control of the extension cables from Certificate Number BAS98ATEX7210U to Certificate Number BAS98ATEX7202. The maximum number of I/O Modules is increased from 32 to 64 following the introduction of the MTL8729-CA-08 \*-Module, 64-Address Carrier in BAS98ATEX7210U/2 and changes to the software. There are no other changes to the system.

#### Report No.

None

#### Drawings

| Number   | Sheet  | Issue | Date  | Description                 |
|----------|--------|-------|-------|-----------------------------|
| *SCI-784 | 1 to 5 | 10    | 10.06 | Common Installation Drawing |
| SCI-784  | 6      | 10    | 10.06 | Common Installation Drawing |

\* These drawings are common to and are held with Certificate Number BAS98ATEX7202/8

#### Special Conditions for Safe Use

None



## Certificate of Conformity - Variation

This is to certify that System Certificate number: **Ex 98E2203/8**  
issued to: **GE Fanuc Intelligent Platforms**  
of: **Luton, Bedfordshire, LU2 8DL**  
for the: **8000 I/O Series System with IS Field Terminals**

is hereby extended to apply to the system conforming with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This Supplementary Certificate shall be held with the original Certificate Ex 98E2203.

The Electrical Equipment Certification Service, retains responsibility for its original documentation. Baseefa is responsible only for the additional work relating to this supplementary certificate and any other supplementary certificate that it has issued.

This certificate may only be reproduced in its entirety, without any change, Schedule included.


Baseefa Customer Reference No. **6198**

Project File No. **08/0573**

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

### Baseefa

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa Ltd  
Registered in England No. 4305578. Registered address as above.

  
D B TEARLEY  
R S SINCLAIR  
DIRECTOR  
On behalf of  
Baseefa



## Schedule

### Description of the variation

#### Variation 8.1

To permit minor changes to various drawings that do not affect the original assessment.

#### Report No.

None.

#### Drawings

| Number    | Sheet  | Issue | Date | Description   |
|-----------|--------|-------|------|---|
| SCI-784 # | 1 to 6 | 11    | 6.08 | 8000 Series I/O Node with Intrinsically Safe Field Terminals<br>Common Installation Drawing     |
| SCI-785   | 1 to 2 | 4     | 7.08 | Installation Drawing for the 8201-HI-IS 8-Channel Analogue Input<br>Module, with HART           |
| SCI-786   | 1 to 2 | 4     | 7.08 | Installation Drawing for the 8204-AO-IS 8-Channel Analogue<br>Output Module                     |
| SCI-787   | 1 to 2 | 4     | 7.08 | Installation Drawing for the 8215-DO-IS 4-Channel Discrete Output<br>Module, Solenoid Driver    |
| SCI-788   | 1 to 2 | 4     | 7.08 | Installation Drawing for the 8220-DI-IS Discrete Input,<br>Switch/Proximity Detector I/O module |
| SCI-853   | 1 to 2 | 2     | 7.08 | Installation Drawing for the 8205-TI-IS 8-Channel Temperature<br>Input (Thermocouple) Module    |
| SCI-854   | 1 to 2 | 2     | 7.08 | Installation Drawing for the 8206-TI-IS 8-Channel Temperature<br>Input (RTD) Module             |
| SCI-929   | 1 to 5 | 2     | 7.08 | Installation Drawing for the 8223-PI-IS 2-Channel Pulse Frequency<br>Input Module               |
| SCI-940   | 1 to 2 | 2     | 7.08 | Installation Drawing for the 8202-HO-IS 8-Channel Analogue<br>Output Module, 4-20mA with HART   |
| SCI-941   | 1 to 3 | 2     | 7.08 | Installation Drawing for the 8230-AI-IS   |

# sheets 1 to 5 of this drawing are common to and held with BAS98ATEX7202/9.

#### Special Conditions for Safe Use

None.



## Certificate of Conformity - Variation

This is to certify that System Certificate number: **Ex 98E2203/9**  
issued to: **GE Intelligent Platforms**  
(formerly GE Fanuc Intelligent Platforms)  
of: **2500 Austin Drive, Charlottesville, Virginia 22911,**  
**USA**  
(formerly Luton, Bedfordshire, LU2 8DL)  
for the: **8000 I/O Series System with IS Field Terminals**

is hereby extended to apply to the system conforming with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This Supplementary Certificate shall be held with the original Certificate Ex 98E2203

The Electrical Equipment Certification Service, retains responsibility for its original documentation. Baseefa is responsible only for the additional work relating to this supplementary certificate and any other supplementary certificate that it has issued.

This certificate may only be reproduced in its entirety, without any change, Schedule included.


Baseefa Customer Reference No. **6623**

Project File No. **10/0571**

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

### Baseefa

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa Ltd  
Registered in England No. 4305578. Registered address as above.

  
pp R S SINCLAIR M. BOWNEY  
DIRECTOR  
On behalf of  
Baseefa



## Schedule

### Description of the variation

#### Variation 9.1

To permit minor drawing changes not affecting the original assessment.

#### Report No.

None.

#### Drawings

| Number   | Sheet  | Issue | Date | Description  |
|----------|--------|-------|------|--|
| SCI-784* | 1 to 6 | 12    | 2.10 | 8000 Series I/O Node with Intrinsically Safe Field Terminals Common Installation Drawing       |
| SCI-785  | 1 & 2  | 5     | 2.10 | Installation Drawing for the 8201-HI-IS 8-Channel Analogue Input Module, with HART             |
| SCI-786  | 1 & 2  | 5     | 2.10 | Installation Drawing for the 8204-AO-IS 8-Channel Analogue Output Module                       |
| SCI-787  | 1 & 2  | 5     | 2.10 | Installation Drawing for the 8215-DO-IS 4-Channel Discrete Output Module, Solenoid Driver      |
| SCI-788  | 1 & 2  | 5     | 2.10 | Installation Drawing for the 8220-DI-IS Discrete Input, Switch / Proximity Detector I/O Module |
| SCI-853  | 1 & 2  | 3     | 2.10 | Installation Drawing for the 8205-TI-IS 8-Channel Temperature Input (Thermocouple) Module      |
| SCI-854  | 1 & 2  | 3     | 2.10 | Installation Drawing for the 8206-TI-IS 8-Channel Temperature Input (RTD) Module               |
| SCI-929  | 1 to 5 | 3     | 2.10 | Installation Drawing for the 8223-PI-IS 2-Channel Pulse / Frequency Input Module               |
| SCI-940  | 1 & 2  | 3     | 2.10 | Installation Drawing for the 8202-HO-IS 8-Channel Analogue Output Module, 4-20mA with HART     |
| SCI-941  | 1 to 3 | 3     | 2.10 | Installation Drawing for the 8230-AI-IS  |

\* Sheets 1 to 5 of this drawing are common to and held with BAS98ATEX7202/10.

#### Special Conditions for Safe Use

None.



---

## Certificate of Conformity - Variation

This is to certify that System Certificate number: **Ex 98E2203/10**  
issued to: **GE Intelligent Platforms**  
of: **2500 Austin Drive, Charlottesville, Virginia 22911,  
USA**  
for the: **8000 I/O Series System with IS Field Terminals**

is hereby extended to apply to the system conforming with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This Supplementary Certificate shall be held with the original Certificate Ex 98E2203

The Electrical Equipment Certification Service, retains responsibility for its original documentation. Baseefa is responsible only for the additional work relating to this supplementary certificate and any other supplementary certificate that it has issued.

This certificate may only be reproduced in its entirety, without any change, Schedule included.

Baseefa Customer Reference No. **6623**

Project File No. **11/0547**

This certificate is granted subject to the general terms and conditions of Baseefa. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

### Baseefa

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ  
Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [info@baseefa.com](mailto:info@baseefa.com) web site [www.baseefa.com](http://www.baseefa.com)  
Baseefa is a trading name of Baseefa Ltd  
Registered in England No. 4305578. Registered address as above.



R S SINCLAIR

DIRECTOR  
On behalf of  
Baseefa



---

## Schedule

### Description of the variation

#### Variation 10.1

To permit minor drawing changes not affect the original assessment.

#### Report No.

None.


#### Drawings

| Number   | Sheet  | Issue | Date | Description   |
|----------|--------|-------|------|---|
| SCI-784* | 1 to 6 | 14    | 8.11 | 8000 Series I/O Node with Intrinsically Safe Field Terminals Common Installation Drawing  |
| SCI-786  | 1 & 2  | 6     | 7.11 | Installation Drawing for the 8204-AO-IS 8-Channel Analogue Output Module                  |
| SCI-853  | 1 & 2  | 4     | 8.11 | Installation Drawing for the 8205-TI-IS 8-Channel Temperature Input (Thermocouple) Module |

\* Sheets 1 to 5 of this drawing are common to and held with BAS98ATEX7202/11.

#### Special Conditions for Safe Use

None.



**Note**

- The system shown above represents a typical 8000 Series "Node". This comprises Unspecified Safe Area Apparatus (U.S.A.A.), a single Railbus Isolator, I/O modules, and all other necessary apparatus such as power supplies, carriers, carrier extenders, etc. A node has a maximum length of 6.8m (including interconnections) and may include up to 64 I/O modules. Provided they are fitted to the right-hand side of the Railbus Isolator in the above circuit, the relative positions of Power Supplies and the different types of carrier is optional.


2. Modules A,C and E may be replaced while the power is on. This is known as "Hot-swapping".

|    |       |   |
|----|-------|---|
| 13 | 7.11  | See Sheets 2, 3 & 5.  |
| 12 | 2.10  | First GE Intelligent Platforms issue.   |
| 11 | 6.08  | First GE Fanuc issue.   |
| 10 | 10.06 | Redrawn. Extension cables were "H". Maximum number of modules was 32. See also sheet 4. |
| 9  | 9.01  | SEE SHEETS 4,5,6.   |
| 8  | 5.01  | SEE SHEETS 3,4,5,6.   |
| 7  | 11.00 | SEE SHEETS 3,4,5.   |
| 6  | 10.00 | SEE SHEET 2.  |

Certifying Authority : Baseefa



**NOTES**


Third Angle Projection 

- Apparatus to be supplied from source with a maximum nominal voltage of 30V which under abnormal conditions cannot be a source of potential with respect to earth in excess of 250V r.m.s. or 250V d.c.
- The Node comprises the items shown in the table below.
- Each I/O Module interfaces to the field via Field Terminal (See table below)
- For specific output characteristics of individual I/O modules see appropriate component certificate.
- A rotary keying system ensures compatibility between I/O Modules and FTAs after installation is complete.

At the time of installation the FTA rotary keys must be adjusted to match the pre-set keys on the mating I/O Module.

See Table 2 for details of the key positions assigned to each I/O module.

- I/O Module carrier types 8720-CA-04 and 8727-CA-08 are provided with connections to enable interfacing with earth leakage detection devices. Details of permissible devices will be added by amendment to this drawing.
- A Module Blanking cover 8420-BK-MC must be fitted to any permanently unoccupied location on an I/O Module Carrier. (Permanently unoccupied implies no I/O Module AND no FTA are intended for the particular location.)

| REF | MAX QTY. | MODULE   | PERMISSIBLE FIELD TERMINALS FOR MODULE   | REF | CH. No. TERM   | REF | MODULE CARRIER  |
|-----|----------|--|--|-----|--|-----|---|
| A   | 1        | 8622-RB-IS, Railbus Isolator<br>BAS98ATEX208U  | Not applicable   |     | Not applicable   | B   | 8723-CA-RB or 8725-CA-RB Railbus Carriers, Part of BAS98ATEX208U  |
| C   | 10       | 8920-PS-DC, IS Module Power Supply, etc input<br>BAS98ATEX209U   | Not applicable   |     | Not applicable   | D   | 8724-CA-PS, IS Power Supply Carrier Part of BAS98ATEX209U   |
| E1  |          | 8215-DO-IS, 4-Channel IS DO, Solenoid Driver<br>BAS98ATEX204U  | 8621-FT-IS, IS Field Terminal, standard<br>8622-FT-IS, IS Field Terminal, loop-disconnect<br>BAS98ATEX211U                             | F1  | 1 1 & 3<br>2 5 & 7<br>3 9 & 11<br>4 13 & 15  |     |   |
| E2  |          | 9204-AO-IS, 8 - Channel IS AO, 4-20mA<br>BAS98ATEX205U   | 8621-FT-IS, IS Field Terminal, standard<br>8622-FT-IS, IS Field Terminal, loop-disconnect<br>BAS98ATEX211U                             | F2  | 1 1 & 2<br>2 3 & 4<br>3 5 & 6<br>4 7 & 8<br>5 9 & 10<br>6 11 & 12<br>7 13 & 14<br>8 15 & 16  |     |   |
| E3  | 84       | 8620-DH-IS, 8 - Channel IS DI, switch/proximity detector<br>8620-DH-IS, 16 - Channel IS DI, switch/proximity detector<br>BAS98ATEX206U | 8624-FT-IS, IS Field Terminal, 8 - Channel DI<br>BAS98ATEX211U, and<br>8623-FT-IS, IS Field Terminal, 16-Channel DI<br>BAS98ATEX211U/1 | F3  | 1 1 & 2<br>2 3 & 4<br>3 5 & 6<br>4 7 & 8<br>5 9 & 10<br>6 11 & 12<br>7 13 & 14<br>8 15 & 16<br>9 17 & 18<br>10 19 & 20<br>11 21 & 22<br>12 23 & 24<br>13 25 & 26<br>14 27 & 28<br>15 29 & 30<br>16 31 & 32 | G   | 8720-CA-04, 4 - Module Carrier,<br>8727-CA-08, 8 - Module Carrier,<br>BAS98ATEX210U<br><br>8729-CA-08, 8 - Module Carrier,<br>BAS98ATEX210U/2   |
| E4  |          | 8201-H-IS, 8 - Channel IS AI, 4-20mA with HART<br>BAS98ATEX207U  | 8621-FT-IS, IS Field Terminal, standard<br>8622-FT-IS, IS Field Terminal, loop-disconnect<br>BAS98ATEX211U                             | F4  | 1 1 & 2<br>2 3 & 4<br>3 5 & 6<br>4 7 & 8<br>5 9 & 10<br>6 11 & 12<br>7 13 & 14<br>8 15 & 16  |     | <br>BAS98ATEX202/11<br>Ex 98E2203/10<br>Baseefa<br>Certification<br>Schedule<br>Drawing<br><br><i>M. Munro</i><br>M. Munro |

8000 I/O Node with IS Field Terminals

|   |       |  |    |       |                                       |
|---|-------|--|----|-------|---------------------------------------|
| 7 | 11:00 | SEE SHEETS 3,4,5.  | 11 | 6.08  | First GE Fabric Issue.                |
| 6 | 10:00 | 8725-CA-RB ADDED TO B.   | 10 | 10.06 | SEE SHEETS 1, 4.                      |
| 5 | 01:00 | TABLE ON THIS SHEET EXTENDED TO NEXT SHEET. DRAWING WAS 4 SHEETS | 9  | 9.01  | SEE SHEETS 4,5,6.                     |
| 4 | 6.99  | 8623 & 8729 & DETAILS ADDED; TABLE NO. REMOVED                   | 8  | 5.01  | SEE SHEETS 3,4,5,6.                   |
| 3 | 12.95 |  | 12 | 2.10  | First GE Intelligent Platforms issue. |
| 2 | 11.98 |  |    |       |                                       |

This document contains Certification Information and must not be modified without reference to the design authority.


|     |       |              |     |
|-----|-------|--------------|-----|
| 1   | 10.98 | Scale        | N/A |
| Iss | Date  | Modification |     |

Copyright Reserved  
Written Permission To Copy  
Should be Obtained

GE Intelligent Platforms

Title 8000 Series I/O Node with Intrinsic Safe Field Terminals  
Common Installation Drawing  
Certifying Authority : Baseefa

Sheet 2 of 6  
Drg. No  
SCI-784

| REF | MAX QTY. | MODULE   | PERMISSIBLE FIELD TERMINALS FOR MODULE  | CH. No. TERM  | REF | MODULE CARRIER  |
|-----|----------|--|---|---|-----|---|
| E5  |          | 8202-HQ-IS, 8-Channel IS AO, 4-20mA with HART<br>BAS98ATEX7185U      | 8621-FT-IS, IS Field Terminal, standard<br>8622-FT-IS, IS Field Terminal, loop disconnect<br>BAS98ATEX7211U | 1 1 & 2<br>2 3 & 4<br>3 5 & 6<br>4 7 & 8<br>5 9 & 10<br>6 11 & 12<br>7 13 & 14<br>8 15 & 16   |     |   |
| E6  |          | 8205-THS, 8-Channel IS TH/CMV Input<br>BAS98ATEX7316U                | 8625-FT-IS, IS Field Terminal, Thermocouple<br>8-Channel<br>BAS98ATEX7211U/4                                | 1 1 & 2<br>2 3 & 4<br>3 5 & 6<br>4 7 & 8<br>5 9 & 10<br>6 11 & 12<br>7 13 & 14<br>8 15 & 16   |     |   |
| E7  | 64       | 8208-THS, 8-Channel IS RTD/ Input<br>BAS98ATEX7316U                  | 8626-FT-IS, IS Field Terminal, RTD<br>8-Channel<br>BAS98ATEX7211U/4   | 1 1, 2, 17<br>and 18<br>2 3, 4, 19<br>and 20<br>3 5, 6, 21<br>and 22<br>4 7, 8, 23<br>and 24<br>5 9, 10, 25<br>and 26<br>6 11, 12, 27<br>and 28<br>7 13, 14, 29<br>and 30<br>8 15, 16, 31<br>and 32 | G   | 8720-CA-04, 4 - Module Carrier,<br>8727-CA-08, 8 - Module Carrier,<br>BAS98ATEX7210U<br><br>8729-CA-08, 8 - Module Carrier,<br>BAS98ATEX7210U/2   |
| E8  |          | 8223-PI-IS, 2-Channel Pulse/Frequency Input Module<br>BAS98ATEX7202U | 8621-FT-IS, IS Field Terminal, Standard<br>8622-FT-IS, IS Field Terminal, Loop Disconnect<br>BAS98ATEX7211U | 1 1, 2, 3, 4,<br>5, 11, 13,<br>14<br>2 6, 7, 8, 9,<br>10, 15, 16  |     | BAS98ATEX7202/11<br>Ex 98E2203/10<br><br>Baseefa<br>Certification<br>Schedule<br>Drawing<br><br><i>M. Muro</i><br>M. MURRO |

8000 I/O Node with IS Field Terminals

Certifying Authority : Baseefa

|    |       |  |
|----|-------|--|
| 12 | 2.10  | First GE Intelligent Platforms issue.                                  |
| 11 | 6.08  | First GE Fanuc issue.  |
| 10 | 10.06 | SEE SHEETS 1, 4, CDR06/006   |
| 9  | 9.01  | SEE SHEETS 4, 5, 6.  |
| 8  | 5.01  | 8202-HQ-IS ADDED. DRAWING NOW 6 SHEETS.                                |
| 7  | 11.00 | 8223-PI-IS ADDED.  |
| 6  | 10.00 | SEE SHEET 2.   |
| 5  | 01.00 | TABLE ON SHEET 2 EXTENDED ONTO THIS NEW SHEET. 8205, 8625, 8626 ADDED. |


|    |      |   |
|----|------|---|
| 14 | 8.11 | See sheets 5.   |
| 13 | 7.11 | Max. quantity of modules was 32. See also sheets 2 & 5. |

This document contains Certification Information and must not be modified without reference to the design authority.

|     |       |              |     |
|-----|-------|--------------|-----|
| 1   | 10.98 | Scale        | N/A |
| Iss | Date  | Modification | N/A |

|              |  |  |  |
|--------------|--|--|--|
| Title        |  | 8000 Series I/O Node with Intrinsically Safe Field Terminals Common Installation Drawing |  |
| Sheet 3 of 6 |  | Dwg. No  |  |
|              |  | SCI-784  |  |

S-EDGE 1 2 3 4 5 6 7 8 A3



Do Not Scale

8000 I/O Nodes with IS Field Terminals

| REF | MAX QTY. | MODULE   | PERMISSIBLE FIELD TERMINALS FOR MODULE                  | CH. No. TERM   | REF | MODULE CARRIER   |
|-----|----------|--|---|--|-----|--|
| E9  |          | 8230-AHS 8-Channel Analogue Input, 0-10V Potentiometer<br>BAS01ATEX7348U | 8623-FT-S, Field Terminal, 16-channel<br>BAS98ATEX7211U | V+ V- V0<br>1 18 17 2<br>2 20 19 4<br>3 22 21 6<br>4 24 23 8<br>5 26 25 10<br>6 28 27 12<br>7 30 29 14<br>8 32 31 16 | G   | 8720-CA-04, 4-Module Carrier,<br>8727-CA-08, 8-Module Carrier,<br>BAS98ATEX7210U,<br><br>8729-CA-08, 8-Module Carrier,<br>BAS98ATEX7210U/2 |

BAS98ATEX7210U

8030-CE-RH, IS Carrier Extender, right-hand  
8031-CE-LH, IS Carrier Extender, left-hand

IS Carrier Extension Cable Assembly.

This cable is comprised of a 18-twisted-pair multicore cable, covered by a layer of heatshrink sleeving. The combined thickness of insulation provided by the multicore and heatshrink sleeve is greater than or equal to 1.0mm, each component providing a minimum of 0.33mm. The heatshrink sleeve is applied over the whole length of the cable to within 10mm of the connector at each end.  
Suitable Assemblies are :- 8010-CC-XXX (where XXX defines the length in centimetres), 8012-CC-85 (0.85m long), 8013-CC-12 (1.2m long), 8014-CC-20 (2.0m long).  
These cables do not need to carry Baseefa approval markings.

IS Power Extension Cable Assembly.

This cable is comprised of up to six separately insulated cores, covered by a layer of heatshrink sleeving. The combined thickness of insulation of any core and the heatshrink sleeve is greater than or equal to 1.0mm, each component providing a minimum of 0.33mm. The heatshrink sleeve is applied over the whole length of the insulated cores, to within 20mm of the connector at each end.  
Suitable Assemblies are :- 8015-CC-XXX (where XXX defines the length in centimetres), 8016-CC-35 (0.35m long), 8017-CC-95 (0.95m long), 8018-CC-12 (1.2m long), 8019-CC-20 (2.0m long).  
These cables do not need to carry Baseefa approval markings.

BAS98ATEX7202/11  
Ex 98E2203/10



M. Munro

M. Munro

|     |       |  |           |      |                      |
|-----|-------|--|-----------|------|----------------------|
| 12  | 2.10  | First GE Intelligent Platforms issue.  | 14        | 6.11 | See sheet 5.         |
| 11  | 6.06  | First GE Fabric Issue.   | 13        | 7.11 | See Sheets 2, 3 & 5. |
| 10  | 10.05 | IS Carrier and Power Extension cables were part of section H, and carried Baseefa markings BAS98ATEX7210U. Also see sheet 1. |           |      |                      |
| 9   | 9.01  | 8230-AHS ADDED.  |           |      |                      |
| 8   | 5.01  | THIS SHEET ADDED FOR FUTURE USE.   |           |      |                      |
| Iss | Date  | Modification   | Scale     | N/A  |                      |
|     |       |  | Tolerance | N/A  |                      |

Certifying Authority : Baseefa

This document contains Certification Information and must not be modified without reference to the design authority.

|              |  |  |
|--------------|--|--|
| Sheet 4 of 6 | Title  | 8000 Series I/O Node with Intrinsically Safe Field Terminals Common Installation Drawing |
| Drg. No      | 8000 Series I/O Node with Intrinsically Safe Field Terminals Common Installation Drawing | SCI-784  |

Do Not Scale

ASSIGNMENT OF I/O MODULE KEY POSITIONS

| MODEL No.               | DESCRIPTION OF FIELD TERMINALS   | No. OF CHANNELS           | LETTER KEY POSITION | NUMBER KEY POSITION |
|-------------------------|--|---------------------------|---------------------|---------------------|
| Reserved For Future Use | Future Use   | X                         | Y                   | Z                   |
| Reserved For Future Use | Future Use   | X                         | Y                   | Z                   |
| 8201-HIS                | 25V, 93mA, 0.65W   | 8                         | A                   | 1                   |
| 8202-HO-IS              | 24.6V, 93mA, 0.57W   | 8                         | A                   | 4                   |
| 8204-AO-IS              | 24.6V, 93mA, 0.57W   | 8                         | A                   | 4                   |
| 8205-THIS               | Ch.1,2,3,4,7 & 8 :-<br>16.4V, 78mA, 0.33W<br>Ch.5 & 6 :-<br>1.5V, 1.3mA, 0.5mW | — 6<br>— 2<br>(Total = 8) | C                   | 1                   |
| 8206-THIS               | Ch 1 to 8 Together :-<br>15.4V, 217mA, 0.9W                                    | 8                         | C                   | 3                   |
| 8215-DO-IS              | 25V, 110mA, 0.69W  | 4                         | B                   | 5                   |
| 8220-DI-IS              | 10.5V, 14mA, 0.04W   | 8 or 16                   | B                   | 1                   |
| 8223-PI-IS              | All circuits of one channel combined<br>28.5V, 83.2mA, 0.639W                  | 2                         | F                   | 2                   |
| 8230-AHS                | 15.75V, 20mA,<br>0.315W Non-linear   | 2                         | C                   | 4                   |

Certifying Authority : Baseefa

This document contains Certification Information and must not be modified without reference to the design authority.

Sheet 5 of 6

Title  
8000 Series I/O Node with Intrinsically Safe Field Terminals  
Common Installation Drawing

GE Intelligent Platforms

Copyright Reserved  
Written Permission To Copy  
Should Be Obtained


Dwg. No  
SCI-784

BAS98ATEX7202/11  
Ex 98E2203/10  
MICROLEAKAGE  
Baseefa  
Certification  
Schedule  
Drawing



*M. Muro*


M. MURTO




FIELD TERMINAL

FOR ASSIGNMENT OF KEY POSITIONS TO SPECIFIC APPLICATIONS REFER TO THE ADJACENT TABLE ON THIS SHEET.


(CONFIGURATIONS BELOW ARE SHOWN FOR INFORMATION ONLY)



NON-RESONANT




NON-ARCING



SAFE AREA  
ORDINARY LOCATION

|    |       |  |
|----|-------|--|
| 14 | 8.11  | 8205-THIS Ch.5 & 6 were 1.0V, 1.1mA, 0.3mW.  |
| 13 | 7.11  | 8202 and 8204 were position B. 8204 was 23.3V, 86mA, 0.65W. See also sheets 2 & 3. |
| 12 | 2.10  | First GE Intelligent Platforms issue.  |
| 11 | 6.08  | First GE Fanuc issue.  |
| 10 | 10.05 | See sheets 1 & 4.  |
| 9  | 9.01  | 8230-AHS ADDED. CDR06/005  |
| 8  | 5.01  | 8202-HO-IS ADDED. DRAWING NOW 6 SHEETS.  |
| 7  | 11.00 | 8223-PI-IS ADDED.  |
| 6  | 10.00 | SEE SHEET 2.   |
| 5  | 01.00 | WAS SHEET 2. WAS 4 SHEETS 8205, 8206 ADDED TO TABLE.                               |
| 4  | 6.99  | TABLE NO. REMOVED. SEE ALSO SHEET 2.   |
| 3  | 12.98 |  |
| 2  | 11.98 |  |
| 1  | 10.98 |  |

|     |      |              |       |     |           |     |
|-----|------|--------------|-------|-----|-----------|-----|
| Iss | Date | Modification | Scale | N/A | Tolerance | N/A |
|     |      |              |       |     |           |     |



Do Not Scale


Third Angle Projection


**SYSTEM NOTES**

1. The installation must comply with national requirements (eg in the UK BS EN60079-14)
2. For system information on individual I/O Modules see following drawings :-

| MODULE  | SYSTEM DRAWING |
|---|----------------|
| 8201-HI-IS, 3 - Channel IS AI, 4-20mA with HART           | SCH785         |
| 8202-HO-IS, 8 - Channel IS AO, 4-20mA, with HART          | SCH940         |
| 8204-AO-IS, 8 - Channel IS AO, 4-20mA                     | SCH786         |
| 8205-TI-IS, 8 - Channel THCr/mV Input                     | SCH853         |
| 8206-TI-IS, 8 - Channel IS RTD/ Input                     | SCH854         |
| 8215-DO-IS, 4 - Channel IS DO, solenoid driver            | SCH787         |
| 8220-DI-IS, 16 - Channel IS DI, switchproximity detector  | SCH788         |
| 8223-PH-IS, 2 - Channel Pulse/Frequency Input Module      | SCH829         |
| 8230-AI-IS, 8-Channel Analogue Input, 0-10V Potentiometer | SCH941         |

3. The marking should normally appear on or adjacent to the principal item of electrical apparatus in the system or at the interface between the intrinsically safe and non-intrinsically safe circuits.


  
 8000 I/O Series System  
 with Intrinsically Safe Field Terminals  
 BAS No Ex 98E2203


  
 Ex 98E2203/10  
 Baseefa  
 Certification  
 Schedule  
 Drawing


*M. Munro*  
 M. Munro

|     |       |   |           |     |
|-----|-------|---|-----------|-----|
| 14  | 8.11  | See sheet 5.                            |           |     |
| 13  | 7.11  | See sheets 2, 3 & 5.                    |           |     |
| 12  | 2.10  | First GE Intelligent Platforms issue.   |           |     |
| 11  | 6.08  | First GE Fanuc issue.                   |           |     |
| 10  | 10.06 | See sheets 1 & 4.                       | CDR06/008 |     |
| 9   | 9.01  | 8230-AI-IS ADDED.                       |           |     |
| 8   | 5.01  | 8202-HO-IS ADDED. DRAWING NOW 6 SHEETS. |           |     |
| 7   | 11.00 | 8223-PH-IS ADDED.                       |           |     |
| 6   | 10.06 | SEE SHEET 2.                            |           |     |
| 5   | 01.00 | WAS SHEET 4; DRAWING WAS 4 SHEETS.      |           |     |
| 4   | 6.99  | SEE SHEET 2                             |           |     |
| 3   | 12.98 |   |           |     |
| 2   | 11.99 |   |           |     |
| 1   | 10.98 |   | Scale     | N/A |
| Iss | Date  | Modification                            | Tolerance | N/A |

Certifying Authority : Baseefa

This document contains Certification Information and must not be modified without reference to the design authority.

| Copyright Reserved<br>Written Permission To Copy<br>Should Be Obtained | GE Intelligent Platforms | Title   | Sheet 6 of 6 |
|--|--------------------------|---|--------------|
|  |                          | 8000 Series I/O Node with Intrinsically Safe Field Terminals<br>Common Installation Drawing | SCI-784      |



|     |       |     |                       |
|-----|-------|-----|-----------------------|
| Iss | Date  | Dwn | Modification          |
| 1   | 10.98 | CAT |                       |
| 2   | 11.98 | SK  |                       |
| 3   | 12.98 | SK  |                       |
| 4   | 7.08  | CMB | First GE Fanuc Issue. |

|     |      |     |                                       |
|-----|------|-----|---------------------------------------|
| Iss | Date | Dwn | Modification                          |
| 5   | 2.10 | JES | First GE Intelligent Platforms Issue. |

GE Intelligent Platforms  
 Copyright Reserved - Written Permission  
 to Copy Should be Obtained

|   |                   |
|---|-------------------|
| Certifying Authority: BASEEFA   | Scale: N/A        |
| Tolerance unless otherwise stated ± N/A   | Sheet: 1 of 2     |
| Title: Installation Drawing for the 8201-HI-IS 8-Channel Analogue Input Module, with HART | Drg. No.: SCI-785 |

|  |  |  |  |              |  |                                       |  |
|--|--|--|--|--------------|--|---------------------------------------|--|
| Ctd  |  | Dimensions in mm   |  | Do Not Scale |  | Third Angle Projection                |  |
| Iss  |  | Date   |  | Drm          |  | Modification                          |  |
| 1  |  | 10.98  |  | CAT          |  |                                       |  |
| 2  |  | 11.98  |  | SM           |  |                                       |  |
| 3  |  | 12.98  |  | SM           |  |                                       |  |
| 4  |  | 7.08   |  | ORR          |  | First GE Fanuc Issue.                 |  |
| 5  |  | 2.10   |  | JES          |  | First GE Intelligent Platforms Issue. |  |
| <input checked="" type="checkbox"/><br>GE Intelligent Platforms<br>Copyright Reserved - Written Permission<br>to Copy Should be Obtained |  | Iss  |  | Date         |  | Drm                                   |  |
|  |  | <input checked="" type="checkbox"/>  |  |              |  |                                       |  |
|  |  | Certifying Authority: BASEEFA  |  | Scale        |  | N/A                                   |  |
|  |  | Tolerance unless otherwise stated ± N/A  |  | Sheet        |  | 2 of 2                                |  |
|  |  | Title<br>Installation Drawing for the 8201-HI-IS<br>8- Channel Analogue Input Module with HART |  | Drg. No.     |  | SCI-785                               |  |

3. The parameters of loads/cables which may be connected to each pair of terminals are given in the table below.

| Group | Capacitance (µF) | Inductance (mH) or L/R Ratio (µH/Ω) |
|-------|------------------|-------------------------------------|
| IIA   | 2.15             | 36.02                               |
| IIB   | 0.65             | 17.72                               |
| IIC   | 0.083            | 4.3                                 |

4. Wiring to each pair of terminals may be achieved using separate cables or means of separate circuits within Type A or Type B multicore cables (as defined in clause 5.3 of EN50039) subject to the following:-

- a) Each circuit within a Type A multicore cable is to be individually screened;
- b) The peak voltage of any circuit within a Type B multicore cable must not exceed 60V.


Ex 98E2203/9



Baseefa  
Certification  
Schedule  
Drawing

*M. Munro*


M. Munro



|  |    |              |              |     |   |          |         |     |         |   |
|--|----|--------------|--------------|-----|---|----------|---------|-----|---------|---|
| Ckd  | AW | Modification | Modification | Iss | 6 | Date Drn | 7.11.98 | JES | 7.11.98 | SAFETY DESCRIPTION (Uo, Io, Po) modified as BAS98ATEX7205U/7. |
| GE Intelligent Platforms<br>Copyright Reserved - Written Permission to Copy Should be Obtained |    |              |              |     |   |          |         |     |         |   |
| Ckd  |    | Modification |              | Iss |   | Date     |         | CHB |         | First GE Fanuc Issue.   |
| 1  |    |              |              | 1   |   | 10.98    |         | CAT |         | First GE Intelligent Platforms Issue.                         |
| 2  |    |              |              | 2   |   | 11.98    |         | SM  |         |   |
| 3  |    |              |              | 3   |   | 12.98    |         | SM  |         |   |
| 4  |    |              |              | 4   |   | 7.08     |         | CHB |         |   |
| 5  |    |              |              | 5   |   | 2.10     |         | JES |         |   |




| Ckd  |                               | Dimensions in mm                                 |     | Do Not Scale  |                               | Third Angle Projection   |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
|--|-------------------------------|--|-----|---|-------------------------------|--|--|-----|------|----|-----|-----|------|------|-----|-----|-------|-----|----|--|--|--|--|
| Iss  |                               | Date   |     | Dm  |                               | Modification   |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| 6  |                               | 7.11   |     | YES   |                               | Load parameters (Co, Lo, L/R) modified as BAS98ATEX7203U/7.  |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| X  |                               | X  |     | X   |                               | <p>GE Intelligent Platforms<br/>Copyright Reserved - Written Permission<br/>to Copy Should be Obtained</p> |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| 1  |                               | 10.98  |     | CMT   |                               | First GE Fanuc issue.  |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| 2  |                               | 11.98  |     | SW  |                               | First GE Intelligent Platforms issue.  |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| 3  |                               | 12.98  |     | SW  |                               |  |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| 4  |                               | 7.08   |     | CWB   |                               |  |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| 5  |                               | 2.10   |     | YES   |                               |  |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| <p>3. The parameters of loads/cables which may be connected to each pair of terminals are given in the table below.</p> <table border="1"> <thead> <tr> <th>Group</th> <th>Capacitance (<math>\mu\text{F}</math>)</th> <th colspan="2">Inductance (mH) or L/R Ratio (<math>\mu\text{H/W}</math>)</th> </tr> </thead> <tbody> <tr> <td>IIA</td> <td>3.12</td> <td>36</td> <td>505</td> </tr> <tr> <td>IIB</td> <td>0.87</td> <td>17.7</td> <td>239</td> </tr> <tr> <td>IIC</td> <td>0.116</td> <td>4.3</td> <td>64</td> </tr> </tbody> </table> |                               |  |     | Group   | Capacitance ( $\mu\text{F}$ ) | Inductance (mH) or L/R Ratio ( $\mu\text{H/W}$ )   |  | IIA | 3.12 | 36 | 505 | IIB | 0.87 | 17.7 | 239 | IIC | 0.116 | 4.3 | 64 | <p>4. Wiring to each pair of terminals may be achieved using separate cables or means of separate circuits within Type A or Type B multicore cables (as defined in clause 5.3 of EN50039) subject to the following:-</p> <p>a) Each circuit within a Type A multicore cable is to be individually screened;</p> <p>b) The peak voltage of any circuit within a Type B multicore cable must not exceed 60V.</p> |  |  |  |
| Group  | Capacitance ( $\mu\text{F}$ ) | Inductance (mH) or L/R Ratio ( $\mu\text{H/W}$ ) |     |   |                               |  |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| IIA  | 3.12                          | 36   | 505 |   |                               |  |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| IIB  | 0.87                          | 17.7   | 239 |   |                               |  |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| IIC  | 0.116                         | 4.3  | 64  |   |                               |  |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| <p>Ex 98E2203/10<br/>Baseefa<br/>Certification<br/>Schedule<br/>Drawing</p> <p><i>M. Munro</i><br/>M. Munro</p>  |                               |  |     | <p>Certifying Authority: BASEEFA</p> <p>Scale N/A</p> |                               |  |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| <p>Tolerance unless otherwise stated <math>\pm</math> N/A</p>  |                               |  |     | <p>Sheet 2 of 2</p>                                   |                               |  |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |
| <p>Title Installation Drawing for the 8204-A0-IS<br/>8- Channel Analogue Output Module</p>   |                               |  |     | <p>Drg. No. SCI-786</p>                               |                               |  |  |     |      |    |     |     |      |      |     |     |       |     |    |  |  |  |  |



Dimensions in mm      Do Not Scale      Third Angle Projection

Intrinsically safe  
Field Device  
( x 4 )  
See Note 1

8215-DO-IS  
BAS98ATEX7204U



BAS98ATEX7210U  
See also SCI-784

Hazardous Area      Safe Area

Notes

1. Devices i.e. switches, thermocouples, PRTs or resistors meeting the requirements of clause 1.3 of EN50014:1977 or Clause 5.4 of EN50020:1994. The PRTs and resistors must have a surface area of between 20mm<sup>2</sup> and 10cm<sup>2</sup>. They must be provided with a degree of protection of at least IP20, to be installed in accordance with the requirements of clause 5 of EN50 020: 1977 or clause 6 of EN50 020: 1994 and must be capable of withstanding an a.c. test voltage of 500V r.m.s. to earth, or to the frame of the equipment, without breakdown. Such devices do not require to be certified or marked.
2. The pair of terminals on the Field Terminal Assembly used by each channel is defined on SCI784. Each pair of terminals has the following safety description.

U<sub>0</sub> ≤ 25Vdc      I<sub>0</sub> ≤ 110mA      P<sub>0</sub> ≤ 0.69w

Ex 98E2203/9



Baseefa  
Certification  
Schedule  
Drawing


*M. Munro*

M. Munro

|     |       |     |                                       |     |      |     |     |
|-----|-------|-----|---------------------------------------|-----|------|-----|-----|
| Iss | Date  | Drn | Mod                                   | Iss | Date | Drn | Mod |
| 1   | 10.98 | CAT |                                       |     |      |     |     |
| 2   | 11.98 | BN  |                                       |     |      |     |     |
| 3   | 12.98 | SN  |                                       |     |      |     |     |
| 4   | 7.08  | ONE | First GE Family issue.                |     |      |     |     |
| 5   | 2.10  | JES | First GE Intelligent Platforms issue. |     |      |     |     |

|   |  |          |         |
|---|--|----------|---------|
| Certifying Authority: BASEEFA   |  | Scale    | N/A     |
| Tolerance unless otherwise stated ± N/A   |  | Sheet    | 1 of 2  |
| Title<br>Installation Drawing for the 8215-DO-IS<br>4-Channel Discrete Output Module, Solenoid Driver |  | Drg. No. | SCI-787 |

| Ckd          |                               | Dimensions in mm   |                                       | Do Not Scale                                       |  | Third Angle Projection |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
|--------------|-------------------------------|--|---------------------------------------|--|--|------------------------|--|-------|-------------------------------|---|--|-----|------|-------|-----|-----|-------|-------|-----|-----|-------|------|----|
| Modification |                               | <p>3. The parameters of loads/cables which may be connected to each pair of terminals are given in the table below.</p> <table border="1"> <thead> <tr> <th>Group</th> <th>Capacitance (<math>\mu\text{F}</math>)</th> <th colspan="2">Inductance (mH) or L/R Ratio (<math>\mu\text{H}/\Omega</math>)</th> </tr> </thead> <tbody> <tr> <td>IIA</td> <td>2.97</td> <td>26.12</td> <td>432</td> </tr> <tr> <td>IIB</td> <td>0.840</td> <td>13.02</td> <td>205</td> </tr> <tr> <td>IIC</td> <td>0.110</td> <td>3.08</td> <td>53</td> </tr> </tbody> </table> <p>4. wiring to each pair of terminals may be achieved using separate cables or means of separate circuits within Type A or Type B multicore cables (as defined in clause 5.3 of EN50039) subject to the following:-</p> <p>a) Each circuit within a Type A multicore cable is to be individually screened;</p> <p>b) The peak voltage of any circuit within a Type B multicore cable must not exceed 60V.</p> |                                       |  |  |                        |  | Group | Capacitance ( $\mu\text{F}$ ) | Inductance (mH) or L/R Ratio ( $\mu\text{H}/\Omega$ ) |  | IIA | 2.97 | 26.12 | 432 | IIB | 0.840 | 13.02 | 205 | IIC | 0.110 | 3.08 | 53 |
| Group        | Capacitance ( $\mu\text{F}$ ) | Inductance (mH) or L/R Ratio ( $\mu\text{H}/\Omega$ )  |                                       |  |  |                        |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| IIA          | 2.97                          | 26.12  | 432                                   |  |  |                        |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| IIB          | 0.840                         | 13.02  | 205                                   |  |  |                        |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| IIC          | 0.110                         | 3.08   | 53                                    |  |  |                        |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| Date Dwn     |                               |  |                                       |  |  |                        |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| Iss          |                               |  |                                       |  |  |                        |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| X            |                               | <p>GE Intelligent Platforms<br/>Copyright Reserved - Written Permission<br/>to Copy Should be Obtained</p>   |                                       |  |  |                        |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| X            |                               | <p>Ex 98E2203/9<br/>Baseefa<br/>Certification<br/>Schedule<br/>Drawing</p> <p style="text-align: center;"><i>M. Munro</i></p> <p style="text-align: center;">M. Munro</p>  |                                       |  |  |                        |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| Ckd          |                               |  |                                       | Certifying Authority: BASEEFA                      |  | Scale N/A              |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| Modification |                               |  |                                       | Tolerance unless otherwise stated $\pm$ N/A        |  | Sheet 2 of 2           |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| Date Dwn     |                               |  |                                       | Title Installation Drawing for the 8215-DO-IS      |  | Drg. No.               |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| Iss          |                               |  |                                       | 8- Channel Discrete Output Module, Solenoid Driver |  | SCI-787                |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| 1            | 10.98                         | CAT  |                                       |  |  |                        |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| 2            | 11.98                         | SM   |                                       |  |  |                        |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| 3            | 12.98                         | SM   |                                       |  |  |                        |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| 4            | 7.08                          | CM8  | First GE Fanuc Issue.                 |  |  |                        |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |
| 5            | 2.10                          | DES  | First GE Intelligent Platforms Issue. |  |  |                        |  |       |                               |   |  |     |      |       |     |     |       |       |     |     |       |      |    |



|     |       |     |                                       |       |     |     |       |     |     |      |     |
|-----|-------|-----|---------------------------------------|-------|-----|-----|-------|-----|-----|------|-----|
| Iss | Date  | Dwn | Iss                                   | Date  | Dwn | Iss | Date  | Dwn | Iss | Date | Dwn |
| 1   | 10-98 | CAT | 2                                     | 11-98 | SW  | 3   | 12-98 | SW  | 4   | 7-08 | CNS |
| 5   | 2-10  | JES | FIRST GE INTELLIGENT PLATFORMS ISSUE. |       |     |     |       |     |     |      |     |

GE Intelligent Platforms  
 Copyright Reserved - Written Permission  
 to Copy Should be Obtained

|     |      |       |                                       |                        |
|-----|------|-------|---------------------------------------|------------------------|
| Iss | Date | Drn   | Modification                          | Ckd                    |
|     | 1    | 20.98 | CAT                                   |                        |
|     | 2    | 11.98 | SR                                    |                        |
|     | 3    | 12.98 | SR                                    |                        |
|     | 4    | 7.08  | CRB                                   | First GE Fabric Issue. |
| 5   | 2.10 | IES   | First GE Intelligent Platforms Issue. |                        |

GE Intelligent Platforms  
 Copyright Reserved - Written Permission  
 to Copy Should be Obtained

Dimensions in mm                      Do Not Scale                      Third Angle Projection

3. The parameters of loads/cables which may be connected to each pair of terminals are given in the table below.

| Group | Capacitance ( $\mu F$ ) | Inductance (mH) or L/R Ratio ( $\mu H/\Omega$ ) |      |
|-------|-------------------------|---|------|
| IIA   | 75.0                    | 1000  | 1333 |
| IIB   | 16.8                    | 680   | 1333 |
| IIC   | 2.41                    | 175   | 983  |

4. Wiring to each pair of terminals may be achieved using separate cables or means of separate circuits within Type A or Type B multicore cables (as defined in clause 5.3 of EN50039) subject to the following:-

- a) Each circuit within a Type A multicore cable is to be individually screened;
- b) The peak voltage of any circuit within a Type B multicore cable must not exceed 60V.

Ex 98E2203/9




Baseefa  
 Certification  
 Schedule  
 Drawing

M. Munro

M. Munro

|   |                         |
|---|-------------------------|
| Certifying Authority: <b>BASEEFA</b>  | Scale <b>N/A</b>        |
| Tolerance unless otherwise stated $\pm$ <b>N/A</b>  | Sheet <b>2 of 2</b>     |
| Title <b>Installation Drawing for the 8220-DI-IS<br/>Discrete Input, Switch/Proximity Detector I/O Module</b> | Drg. No. <b>SCI-788</b> |



|              |   |       |     |                                       |  |  |
|--------------|---|-------|-----|---------------------------------------|--|--|
| Iss          | 1   | 12.98 | ACV |                                       |  |  |
|              | 2   | 7.08  | CMB | First GE Fabuc Issue.                 |  |  |
|              | 3   | 2.10  | JES | First GE Intelligent Platforms Issue. |  |  |
|              | 4   | 8.11  | JES | See sheet 1.                          |  |  |
| Iss          | <input checked="" type="checkbox"/> GE Intelligent Platforms<br>Copyright Reserved - Written Permission<br>to Copy Should be Obtained |       |     |                                       |  |  |
| Iss          | <input checked="" type="checkbox"/>   |       |     |                                       |  |  |
| Date         | Drn   |       |     |                                       |  |  |
| Modification |   |       |     |                                       |  |  |
| Ckd          |   |       |     |                                       |  |  |

Dimensions in mm Do Not Scale Third Angle Projection

3. The parameters of loads/cables which may be connected to the terminals of each channel are given in the tables below.

TABLE 1 (Channels 1,2,4,7 & 8)

| Group | Capacitance (μF) | Inductance (mH) or L/R Ratio (μH/Ω) |
|-------|------------------|-------------------------------------|
| IIC   | 0.41             | 5.8                                 |
| IIB   | 2.49             | 23.8                                |
| IIA   | 9.98             | 49.1                                |

TABLE 2 (Channels 5 & 6)

| Group | Capacitance (μF) | Inductance (mH) or L/R Ratio (μH/Ω) |
|-------|------------------|-------------------------------------|
| IIC   | 100              | 1,000                               |
| IIB   | 1,000            | 1,000                               |
| IIA   | 1,000            | 1,000                               |

4. Wiring to each pair of terminals may be achieved using separate cables, or by means of separate circuits within Type A or Type B multicore cables (as defined in clause 5.3 of EN50039) subject to the following:-
- a) Each circuit within a Type A multicore cable is to be individually screened;
  - b) The peak voltage of any circuit within a Type B multicore cable must not exceed 60V.

Ex 98E2203/10




Baseefa  
Certification  
Schedule  
Drawing

*M. Munro*

M. Munro

|   |  |          |         |
|---|--|----------|---------|
| Certifying Authority: BASEEFA   |  | Scale    | N/A     |
| Tolerance unless otherwise stated = N/A   |  | Sheet    | 2 of 2  |
| Title<br>Installation Drawing for the 8205-TI-IS<br>8-Channel Temperature Input (Thermocouple) Module |  | Drg. No. | SCI-853 |



**NOTES**

1. Each channel comprises four terminals as detailed in the table below.

| Ch. No. | Terminals         |
|---------|-------------------|
| 1       | 1, 2, 17 and 18   |
| 2       | 3, 4, 19 and 20   |
| 3       | 5, 6, 21 and 22   |
| 4       | 7, 8, 23 and 24   |
| 5       | 9, 10, 25 and 26  |
| 6       | 11, 12, 27 and 28 |
| 7       | 13, 14, 29 and 30 |
| 8       | 15, 16, 31 and 32 |

Ex 98E2203/9



Baseefa  
Certification  
Schedule  
Drawing

*M. Munro*


M. Munro


2. Devices, i.e. switches, thermocouples, PRTs or resistors meeting the requirements of clause 1.3 of EN50014:1997, or clause 5.4 of EN50020:1994. The PRTs and resistors must have a surface area of between 20mm<sup>2</sup> and 10cm<sup>2</sup>. They must be provided with a degree of protection of at least IP20, be installed in accordance with the requirements of clause 6 of EN50020:1994 or clause 5 of EN50 020:1977 and must be capable of withstanding an a.c. test voltage of 500V r.m.s. to earth, or the frame of the equipment, without breakdown.  
Such devices do not need to be certified or marked.

|  |  |          |         |
|--|--|----------|---------|
| Certifying Authority: BASEEFA  |  | Scale    | N/A     |
| Tolerance unless otherwise stated ± N/A  |  | Sheet    | 1 of 2  |
| Title<br>Installation Drawing for the 8206-TI-IS<br>8-Channel Temperature Input (RTD) Module |  | Drg. No. | SCI-854 |

|   |   |       |     |                                       |     |
|---|---|-------|-----|---------------------------------------|-----|
| Iss   | 1 | 12.99 | ACW | Modification                          | ckd |
| Date  | 2 | 7.08  | CMB | First GE Fanuc Issue.                 |     |
| Iss   | 3 | 2.10  | JES | First GE Intelligent Platforms Issue. |     |
| GE Intelligent Platforms<br>Copyright Reserved - Written Permission<br>to Copy Should be Obtained |   |       |     |                                       |     |
| Iss   |   |       |     |                                       |     |
| Date  |   |       |     |                                       |     |
| Drn   |   |       |     |                                       |     |
| Mod   |   |       |     |                                       |     |



| Ckd                                 |                         | Dimensions in mm   | Do Not Scale  | Third Angle Projection |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
|-------------------------------------|-------------------------|--|---|------------------------|-------|-------------------------|---|--|-----|-------|------|----|-----|------|------|----|-----|------|------|-----|
| Modification                        |                         | NOTES  |   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
|                                     |                         | <p>3. The safety description for all channels (connected together) is:-</p> <p style="text-align: center;"><math>U_0 \leq 16.4V</math> dc      <math>I_0 \leq 217mA</math>      <math>P_0 \leq 0.9W</math></p> <p>4. The parameters of all loads/cables which may be attached to the output terminals are given in the table below.</p> <table border="1" style="margin: auto;"> <thead> <tr> <th>Group</th> <th>Capacitance (<math>\mu F</math>)</th> <th colspan="2">Inductance (mH) or L/R Ratio (<math>\mu H/\Omega</math>)</th> </tr> </thead> <tbody> <tr> <td>IIC</td> <td>0.389</td> <td>0.39</td> <td>20</td> </tr> <tr> <td>IIB</td> <td>2.47</td> <td>1.50</td> <td>90</td> </tr> <tr> <td>IIA</td> <td>9.96</td> <td>4.20</td> <td>182</td> </tr> </tbody> </table> <p>5. wiring to field devices may be achieved using either separate cables or separate circuits within Type A or Type B multicore cables, (as defined in clause 5.3 of EN50039) subject to the following:-</p> <p>a) each circuit within a Type A multicore is to be individually screened:<br/> b) the peak voltage of any circuit within a Type B multicore must not exceed 60V.</p> |   |                        | Group | Capacitance ( $\mu F$ ) | Inductance (mH) or L/R Ratio ( $\mu H/\Omega$ ) |  | IIC | 0.389 | 0.39 | 20 | IIB | 2.47 | 1.50 | 90 | IIA | 9.96 | 4.20 | 182 |
| Group                               | Capacitance ( $\mu F$ ) | Inductance (mH) or L/R Ratio ( $\mu H/\Omega$ )  |   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| IIC                                 | 0.389                   | 0.39   | 20  |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| IIB                                 | 2.47                    | 1.50   | 90  |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| IIA                                 | 9.96                    | 4.20   | 182   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| Iss                                 |                         |  |   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| date                                |                         |  |   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| Drn                                 |                         |  |   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| <input checked="" type="checkbox"/> |                         | <p>GE Intelligent Platforms<br/> Copyright Reserved - Written Permission<br/> to Copy Should be Obtained</p>   |   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| <input checked="" type="checkbox"/> |                         | <p>Ex 98E2203/9<br/>  Baseefa<br/> Certification<br/> Schedule<br/> Drawing</p> <p style="text-align: center;"><i>M. Munro</i><br/> M. Munro</p>   |   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| Ckd                                 |                         |  |   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| Modification                        |                         |  |   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
|                                     |                         |  |   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
|                                     |                         |  |   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
|                                     |                         |  |   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| 1                                   | 12-99                   | ACW  |   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| 2                                   | 7-08                    | CMB  | First GE Fanuc Issue.   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| 3                                   | 2-10                    | JES  | First GE Intelligent Platforms Issue.   |                        |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
| Iss                                 | date                    | Drn  | Drn   | Drn                    |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
|                                     |                         |  | Certifying Authority: BASEEFA   | Scale N/A              |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
|                                     |                         |  | Tolerance unless otherwise stated $\pm$ N/A   | sheet 2 of 2           |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |
|                                     |                         |  | Title Installation Drawing for the 8206-TI-IS<br>8-Channel Temperature Input (RTD) Module | Drg. No.<br>SCI-854    |       |                         |   |  |     |       |      |    |     |      |      |    |     |      |      |     |



|  |  |                             |
|--|--|-----------------------------|
| ckd  |  |                             |
| Modification   |  |                             |
| Date   | Drn  |                             |
| Iss  |  |                             |
| X  | <p style="text-align: center;">Hazardous Area      Safe Area</p> |                             |
| <p><b>GENERAL APPARATUS DISPOSITION</b></p> <p>(See Individual Connection Arrangements Below)</p>  |  |                             |
| <p style="text-align: center;">Notes</p> <p>1. Devices i.e. switches, thermocouples, PRTs or resistors meeting the requirements of clause 1.3 of EN50014:1977 or clause 5.4 of EN50020:1994. The PRTs and resistors must have a surface area of between 20mm<sup>2</sup> and 10cm<sup>2</sup>. They must be provided with a degree of protection of at least IP20, to be installed in accordance with the requirements of clause 5 of EN50 020: 1977 or clause 6 of EN50 020: 1994 and must be capable of withstanding an a.c. test voltage of 500V r.m.s. to earth, or to the frame of the equipment, without breakdown. Such devices do not require to be certified or marked.</p> |  |                             |
| <p>Ex 98E2203/9</p> <p><b>Baseefa</b> Certification Schedule Drawing</p> <p><i>M. Munro</i></p> <p>M. Munro</p>  |  |                             |
| <p>Certifying Authority: BASEEFA</p>   |  | <p>Scale      N/A</p>       |
| <p>Tolerance unless otherwise stated ±      N/A</p>  |  | <p>Sheet      1 of 5</p>    |
| <p>Title      Installation Drawing for the 8223-PI-IS<br/>2-Channel Pulse/Frequency Input Module</p>   |  | <p>Drq. No.<br/>SCI-929</p> |

GE Intelligent Platforms  
 Copyright Reserved - Written Permission  
 to Copy Should be Obtained


GE Intelligent Platforms  
 Copyright Reserved - Written Permission  
 to Copy Should be Obtained

|  |  |                             |
|--|--|-----------------------------|
| ckd  |  |                             |
| Modification   |  |                             |
| Date   | Drn  |                             |
| Iss  |  |                             |
| X  | <p style="text-align: center;">Hazardous Area      Safe Area</p> |                             |
| <p><b>GENERAL APPARATUS DISPOSITION</b></p> <p>(See Individual Connection Arrangements Below)</p>  |  |                             |
| <p style="text-align: center;">Notes</p> <p>1. Devices i.e. switches, thermocouples, PRTs or resistors meeting the requirements of clause 1.3 of EN50014:1977 or clause 5.4 of EN50020:1994. The PRTs and resistors must have a surface area of between 20mm<sup>2</sup> and 10cm<sup>2</sup>. They must be provided with a degree of protection of at least IP20, to be installed in accordance with the requirements of clause 5 of EN50 020: 1977 or clause 6 of EN50 020: 1994 and must be capable of withstanding an a.c. test voltage of 500V r.m.s. to earth, or to the frame of the equipment, without breakdown. Such devices do not require to be certified or marked.</p> |  |                             |
| <p>Ex 98E2203/9</p> <p><b>Baseefa</b> Certification Schedule Drawing</p> <p><i>M. Munro</i></p> <p>M. Munro</p>  |  |                             |
| <p>Certifying Authority: BASEEFA</p>   |  | <p>Scale      N/A</p>       |
| <p>Tolerance unless otherwise stated ±      N/A</p>  |  | <p>Sheet      1 of 5</p>    |
| <p>Title      Installation Drawing for the 8223-PI-IS<br/>2-Channel Pulse/Frequency Input Module</p>   |  | <p>Drq. No.<br/>SCI-929</p> |

|              |       |                       |                                       |  |
|--------------|-------|-----------------------|---------------------------------------|--|
| Iss          | 1     | 2                     | 3                                     |  |
| Date         | 11-09 | 7-08                  | 2-10                                  |  |
| Drn          | ACW   | CMB                   | JES                                   |  |
| Modification |       | First GE Fanuc Issue. | First GE Intelligent Platforms Issue. |  |
| ckd          |       |                       |                                       |  |

GE Intelligent Platforms  
 Copyright Reserved - Written Permission  
 to Copy Should be Obtained

Dimensions in mm Do Not Scale Third Angle Projection



2. The connection arrangement shown above is for channel 1 of the 8223-PI-IS. For Channel 2 in the same configuration the connection to Terminal 1 must be replaced by a connection to Terminal 7.

The connection arrangements for both Channels have the following parameters.  
 $U_o \leq \pm 1.1V$   $I_o \leq 53mA$   $P_o \leq 15mW$

The load/cable parameters shown below must not be exceeded.


| Group | Capacitance ( $\mu F$ ) | Inductance (mH) or | L/R Ratio ( $\mu H/\Omega$ ) |
|-------|-------------------------|--------------------|------------------------------|
| IIC   | 1000                    | 13.1               | 2436                         |
| IIB   | 1000                    | 39.3               | 7308                         |
| IIA   | 1000                    | 104.8              | 19488                        |

$U_i = 1.1V$   $I_i = 50mA$   $C_i = 0\mu F$   $L_i = 5\mu H$

Ex 98E2203/9



Baseefa  
 Certification  
 Schedule  
 Drawing



*M. Munro*

M. Munro

3. The connection arrangement shown above is for channel 1 of the 8223-PI-IS. For Channel 2 in the same configuration the connection to Terminal 5 must be replaced by a connection to Terminal 6.

|   |  |                  |
|---|--|------------------|
| Certifying Authority: BASEEFA   |  | Scale N/A        |
| Tolerance unless otherwise stated $\pm$ N/A   |  | Sheet 2 of 5     |
| Title Installation Drawing for the 8223-PI-IS<br>2-Channel Pulse/Frequency Input Module |  | Drg. No. SCI-929 |

|     |       |     |                                       |     |
|-----|-------|-----|---------------------------------------|-----|
| Iss | Date  | Drn | Modification                          | ckd |
| 1   | 11.00 | ACM |                                       |     |
| 2   | 7.08  | CWB | First GE Panic Issue.                 |     |
| 3   | 2.10  | JES | First GE Intelligent Platforms Issue. |     |

GE Intelligent Platforms  
 Copyright Reserved - Written Permission  
 to Copy Should be Obtained


Dimensions in mm Do Not Scale Third Angle Projection

Note 3 (continued)  
 The connection arrangements for both Channels have the following parameters.  
 $U_o \leq 27.4V$      $I_o \leq 93.2mA$      $P_o \leq 639mW$   
 $C_i = 0\mu F$      $L_i = 10\mu H$

The load/cable parameters shown below must not be exceeded.


| Group | Capacitance ( $\mu F$ ) | Inductance (mH) | or | L/R Ratio ( $\mu H/\Omega$ ) |
|-------|-------------------------|-----------------|----|------------------------------|
| IIC   | 0.087                   | 4.2             |    | 56                           |
| IIB   | 0.261                   | 12.6            |    | 168                          |
| IIA   | 0.696                   | 33.6            |    | 448                          |

Ex 98E2203/9



*M. Munro*

M. Munro  
 BAS98ATEX7210U  
 See also SCI-784



4. The connection arrangement shown above is for Channel 1 of the 8223-PI-IS. For channel 2 in the same configuration the connection to Terminal 3 must be replaced by a connection to Terminal 9.

The connection arrangements for both channels have the following parameters.  
 $U_o \leq 9.6V$      $I_o \leq 25mA$      $P_o \leq 57mW$

The load/cable parameters shown in the following table must not be exceeded.


| Group | Capacitance ( $\mu F$ ) | Inductance (mH) | or | L/R Ratio ( $\mu H/\Omega$ ) |
|-------|-------------------------|-----------------|----|------------------------------|
| IIC   | 3.6                     | 56.6            |    | 191                          |
| IIB   | 10.8                    | 208             |    | 744                          |
| IIA   | 28.8                    | 419             |    | 868                          |

$U_i = 18.2V$      $P_i = 333mW$      $C_i = 0\mu F$      $L_i = 0mH$

|   |  |                   |
|---|--|-------------------|
| Certifying Authority: BASEEFA   |  | Scale: N/A        |
| Tolerance unless otherwise stated $\pm$ N/A   |  | Sheet: 3 of 5     |
| Title: Installation Drawing for the 8223-PI-IS<br>2- Channel Pulse/Frequency Input Module |  | Drg. No.: SCI-929 |

| Ckd  |                         | Dimensions in mm | Do Not Scale | Third Angle Projection       |                                    |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
|--|-------------------------|------------------|--------------|------------------------------|------------------------------------|-------|-------------------------|-----------------|----|------------------------------|-----|-----|------|--|-----|-----|------|-----|--|-----|-----|------|-----|--|-----|
| Modification   |                         | See Note 5       |              |                              | See Notes 5 and 8                  |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| Date   | Drm                     | See Note 1       |              |                              | BAS98ATEX7210U<br>See also SCI-784 |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| Iss  | Date                    | See Note 1       |              |                              |                                    |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| Iss  | Date                    | See Note 1       |              |                              |                                    |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| Iss  | Date                    | See Note 1       |              |                              |                                    |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| Iss  | Date                    | See Note 1       |              |                              |                                    |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| Iss  | Date                    | See Note 1       |              |                              |                                    |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| <p>5. The connection arrangement shown above is for Channel 1 of the 8223-PI-IS. For channel 2 in the same configuration the connection to Terminal 2 must be replaced by a connection to Terminal 8.</p> <p>The connection arrangements for both Channels have the following parameters.</p> <p style="text-align: center;"><math>U_o \leq 9,6V</math>      <math>I_o \leq 25mA</math>      <math>P_o \leq 57mW</math></p> <p>The load/cable parameters shown below must not be exceeded.</p> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th>Group</th> <th>Capacitance (<math>\mu F</math>)</th> <th>Inductance (mH)</th> <th>or</th> <th>L/R Ratio (<math>\mu H/\Omega</math>)</th> </tr> </thead> <tbody> <tr> <td>IIC</td> <td>3.6</td> <td>56.6</td> <td></td> <td>191</td> </tr> <tr> <td>IIB</td> <td>10.8</td> <td>208</td> <td></td> <td>744</td> </tr> <tr> <td>IIA</td> <td>28.8</td> <td>419</td> <td></td> <td>868</td> </tr> </tbody> </table> <p style="text-align: center;"><math>U_i = 18.2V</math>      <math>P_i = 333mW</math>      <math>C_i = 0\mu F</math>      <math>L_i = 0mH</math>      Ex 98E2203/9</p> |                         |                  |              |                              |                                    | Group | Capacitance ( $\mu F$ ) | Inductance (mH) | or | L/R Ratio ( $\mu H/\Omega$ ) | IIC | 3.6 | 56.6 |  | 191 | IIB | 10.8 | 208 |  | 744 | IIA | 28.8 | 419 |  | 868 |
| Group  | Capacitance ( $\mu F$ ) | Inductance (mH)  | or           | L/R Ratio ( $\mu H/\Omega$ ) |                                    |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| IIC  | 3.6                     | 56.6             |              | 191                          |                                    |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| IIB  | 10.8                    | 208              |              | 744                          |                                    |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| IIA  | 28.8                    | 419              |              | 868                          |                                    |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| <p>6. The connection arrangement shown above is for Channel 1. To connect channel 2 in the same configuration Terminals 15 and 16 must be used. For both channels 1 and 2 the following parameters apply.</p> <p style="text-align: center;"><math>U_o = 0V</math>      <math>I_o = 0mA</math>      <math>P_o = 0mW</math><br/> <math>U_i \leq 30V</math>      <math>P_i \leq 333mW</math></p> <p>The load/cable parameters are determined by the circuit into which these terminals of the 8223-PI-IS are connected.</p>  |                         |                  |              |                              |                                    |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| Certifying Authority: BASEEFA  |                         |                  |              | Scale                        | N/A                                |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| Tolerance unless otherwise stated $\pm$ N/A  |                         |                  |              | Sheet                        | 4 of 5                             |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |
| Title Installation Drawing for the 8223-PI-IS<br>2-Channel Pulse/Frequency Input Module  |                         |                  |              | Drg. No.                     | SCI-929                            |       |                         |                 |    |                              |     |     |      |  |     |     |      |     |  |     |     |      |     |  |     |

GE Intelligent Platforms  
Copyright Reserved - Written Permission  
to Copy Should be Obtained




*M. Munro*

M. Munro  
BAS98ATEX7210U  
See also SCI-784

|  |       |     |                                       |     |
|--|-------|-----|---------------------------------------|-----|
| Iss  | Date  | Drn | Modification                          | ckd |
| 1  | 11.00 | ACW |                                       |     |
| 2  | 7.08  | CWB | First GE Fabric Issue.                |     |
| 3  | 2.10  | JES | First GE Intelligent Platforms issue. |     |
| <b>GE Intelligent Platforms</b><br>Copyright Reserved - Written Permission<br>to Copy Should be Obtained |       |     |                                       |     |

Dimensions in mm Do Not Scale Third Angle Projection



7. This configuration has the following parameters.

$U_0 \leq 9.6V$        $I_0 \leq 25mA$        $P_0 \leq 57mW$

The load/cable parameters shown below must not be exceeded.

| Group | Capacitance ( $\mu F$ ) | Inductance (mH) | or | L/R Ratio ( $\mu H/\Omega$ ) |
|-------|-------------------------|-----------------|----|------------------------------|
| IIC   | 3.6                     | 56.6            |    | 191                          |
| IIB   | 10.8                    | 208             |    | 744                          |
| IIA   | 28.8                    | 419             |    | 868                          |

$U_i = 18.2V$        $P_i = 333mW$        $C_i = 0\mu F$        $L_i = 0mH$


8. wiring from each channel to each field device may be achieved using separate cables or by means of separate circuits within Type A or Type B multicore cables (as defined in Clause 5.3 of EN50039) subject to the following:-
- a) each circuit within a Type A multicore cable is to be individually screened;
  - b) the peak voltage of any circuit within a type B multicore cable must not exceed 60V.

Ex 98E2203/9

Baseefa  
Certification  
Schedule  
Drawing


*M. Munro*  
M. Munro

|   |  |                  |
|---|--|------------------|
| Certifying Authority: BASEEFA   |  | Scale: N/A       |
| Tolerance unless otherwise stated $\pm$ N/A   |  | Sheet 5 of 5     |
| Title: Installation Drawing for the 8223-PI-IS 2-Channel Pulse/Frequency Input Module |  | Drg. No. SCI-929 |




|   |      |     |     |      |     |     |      |     |     |      |     |
|---|------|-----|-----|------|-----|-----|------|-----|-----|------|-----|
| Iss   | Date | Drm | Iss | Date | Drm | Iss | Date | Drm | Iss | Date | Drm |
| 1   | 5.01 | ACW | 2   | 7.08 | CMB | 3   | 2.10 | JES | 1   | 5.01 | ACW |
| GE Intelligent Platforms<br>Copyright Reserved - Written Permission<br>to Copy Should be Obtained |      |     |     |      |     |     |      |     |     |      |     |
| Modification<br>First GE Fanuc issue.<br>First GE Intelligent Platforms issue.                    |      |     |     |      |     |     |      |     |     |      |     |

|   |                  |
|---|------------------|
| Certifying Authority: BASEEFA   | Scale: N/A       |
| Tolerance unless otherwise stated ± N/A   | Sheet 1 of 2     |
| Title: Installation Drawing for the 8202-HO-IS 8-Channel Analogue Output Module, 4-20mA with HART | Drg. No. SCI-940 |

| Ckd                                 |                  | Dimensions in mm  |     | Do Not Scale |  | Third Angle Projection |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
|-------------------------------------|------------------|---|-----|--------------|--|------------------------|--|--------------|------------------|-------------------------------------|---|----------|------|-------|----------|-----------------------|------|----------|---------------------------------------|-----|-------|------|----|
| Modification                        |                  | 3. The parameters of loads/cables which may be connected to each pair of terminals are given in the table below.  |     |              |  |                        |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
|                                     |                  | <table border="1"> <thead> <tr> <th>Group</th> <th>Capacitance (µF)</th> <th colspan="2">Inductance (mH) or L/R Ratio (µH/Ω)</th> </tr> </thead> <tbody> <tr> <td>IIA</td> <td>3.12</td> <td>36.02</td> <td>505</td> </tr> <tr> <td>IIB</td> <td>0.87</td> <td>17.72</td> <td>239</td> </tr> <tr> <td>IIC</td> <td>0.116</td> <td>4.30</td> <td>64</td> </tr> </tbody> </table> |     |              |  |                        |  | Group        | Capacitance (µF) | Inductance (mH) or L/R Ratio (µH/Ω) |   | IIA      | 3.12 | 36.02 | 505      | IIB                   | 0.87 | 17.72    | 239                                   | IIC | 0.116 | 4.30 | 64 |
| Group                               | Capacitance (µF) | Inductance (mH) or L/R Ratio (µH/Ω)   |     |              |  |                        |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| IIA                                 | 3.12             | 36.02   | 505 |              |  |                        |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| IIB                                 | 0.87             | 17.72   | 239 |              |  |                        |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| IIC                                 | 0.116            | 4.30  | 64  |              |  |                        |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| Date                                |                  | 4. Wiring to each pair of terminals may be achieved using separate cables or means of separate circuits within Type A or Type B multicore cables (as defined in clause 5.3 of EN50039) subject to the following:-   |     |              |  |                        |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| Iss                                 |                  | <p>a) Each circuit within a Type A multicore cable is to be individually screened;</p> <p>b) The peak voltage of any circuit within a Type B multicore cable must not exceed 60V.</p>   |     |              |  |                        |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| <input checked="" type="checkbox"/> |                  | <p>Ex 98E2203/9</p>  <p>Baseefa<br/>Certification<br/>Schedule<br/>Drawing</p> <p><i>M. Munro</i></p> <p>M. Munro</p>  |     |              |  |                        |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| <input checked="" type="checkbox"/> |                  | <p>GE Intelligent Platforms<br/>Copyright Reserved - Written Permission<br/>to Copy Should be Obtained</p>  |     |              |  |                        |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| Ckd                                 |                  | <table border="1"> <thead> <tr> <th colspan="2">Modification</th> <th>Ckd</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>5.01 ACM</td> <td></td> </tr> <tr> <td>2</td> <td>7.08 CMB</td> <td>First GE Panic issue.</td> </tr> <tr> <td>3</td> <td>2.10 JES</td> <td>First GE Intelligent Platforms issue.</td> </tr> </tbody> </table>   |     |              |  |                        |  | Modification |                  | Ckd                                 | 1 | 5.01 ACM |      | 2     | 7.08 CMB | First GE Panic issue. | 3    | 2.10 JES | First GE Intelligent Platforms issue. |     |       |      |    |
| Modification                        |                  | Ckd   |     |              |  |                        |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| 1                                   | 5.01 ACM         |   |     |              |  |                        |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| 2                                   | 7.08 CMB         | First GE Panic issue.   |     |              |  |                        |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| 3                                   | 2.10 JES         | First GE Intelligent Platforms issue.   |     |              |  |                        |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| Date                                |                  | Certifying Authority: BASEEFA   |     |              |  | Scale N/A              |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| Iss                                 |                  | Tolerance unless otherwise stated ± N/A   |     |              |  | Sheet 2 of 2           |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |
| Date                                |                  | Title Installation Drawing for the 8202-HO-IS 8-Channel Analogue Output Module, 4-20mA with HART  |     |              |  | Drg. No. SCI-940       |  |              |                  |                                     |   |          |      |       |          |                       |      |          |                                       |     |       |      |    |





GE Intelligent Platforms  
 Copyright Reserved - Written Permission  
 to Copy Should be Obtained

**Notes**

1. Devices, e.g. switches, thermocouples, PRTs or resistors meeting the requirements of Clause 1.3 of EN50014:1997, or Clause 5.4 of EN50 020:1977. The PRTs must have a surface area of between 20mm<sup>2</sup> and 10cm<sup>2</sup>. They must be provided with a degree of protection of at least IP20, must be installed in accordance with the requirements of Clause 5 of EN50 020:1977 or Clause 6 of EN50020:1994 and must be capable of withstanding an a.c. test voltage of 500V r.m.s. to earth or the frame of the equipment, without breakdown.. Such devices do not require to be certified or marked.
2. For installations with a voltage input the pair of terminals for each channel as shown in the table below has the following safety description.

$$U_o \leq 15.75V \quad I_o \leq 20mA \quad P_o \leq 0.315W$$

| Channel | Terminals |
|---------|-----------|
| 1       | 17,18     |
| 2       | 19,20     |
| 3       | 21,22     |
| 4       | 23,24     |
| 5       | 25,26     |
| 6       | 27,28     |
| 7       | 29,30     |
| 8       | 31,32     |




Ex 98E2203/9  
 Baseefa  
 Certification  
 Schedule  
 Drawing

*M. Munro*

M. Munro

For details of load/cable parameters see Note 4.

|  |  |          |         |
|--|--|----------|---------|
| Certifying Authority: BASEEFA                    |  | Scale    | N/A     |
| Tolerance unless otherwise stated ±              |  | Sheet    | 1 of 3  |
| N/A  |  | Drg. No. | SCI-941 |
| Title<br>Installation Drawing for the 8230-AI-IS |  |          |         |



|     |  |      |  |     |  |                                       |  |
|-----|--|------|--|-----|--|---------------------------------------|--|
| Iss |  | Date |  | Drm |  | Modification                          |  |
| 1   |  | 9.01 |  | ACW |  |                                       |  |
| 2   |  | 7.08 |  | CMB |  | First GE Fanuc issue.                 |  |
| 3   |  | 2.10 |  | JES |  | First GE Intelligent Platforms issue. |  |

|  |  |          |              |
|--|--|----------|--------------|
| Certifying Authority: BASEEFA                    |  | Scale    | N/A          |
| Tolerance unless otherwise stated ±              |  | N/A      | Sheet 2 of 3 |
| Title<br>Installation Drawing for the 8230-AI-IS |  | Drg. No. | SCI-941      |

Dimensions in mm

Do Not Scale

Third Angle Projection

- 4. The parameters of loads/cables which may be connected to the terminals of each channel in either the voltage input or potentiometer input configuration are shown in the table below.

| Group | Capacitance (μF) | Inductance (mH) or L/R Ratio (μH/Ω) |     |
|-------|------------------|-------------------------------------|-----|
| IIC   | 0.47             | 87.5                                | 334 |
| IIB   | 2.88             | 328                                 | 952 |
| IIA   | 11.6             | 633                                 | 952 |

- 5. wiring to the terminals of each channel may be achieved using separate cables or by means of separate circuits within Type A or Type B multicore cables (as defined in Clause of EN50039) subject to the following :-
  - a) Each circuit within a Type A multicore cable is to be individually screened;
  - b) The peak voltage of any circuit within a Type B multicore cable must not exceed 60V.

Ex 98E2203/9



Baseefa  
Certification  
Schedule  
Drawing

M. Munro

GE Intelligent Platforms  
Copyright Reserved - Written Permission  
to Copy Should be Obtained

| Iss | Date | Drn | Modification                          | Iss | Date | Drn | Modification | Iss | Date | Drn | Modification |
|-----|------|-----|---------------------------------------|-----|------|-----|--------------|-----|------|-----|--------------|
| 1   | 9.01 | ACW |                                       |     |      |     |              |     |      |     |              |
| 2   | 7.08 | OMB | First GE Fanuc issue.                 |     |      |     |              |     |      |     |              |
| 3   | 2.10 | JES | First GE Intelligent Platforms issue. |     |      |     |              |     |      |     |              |

|  |  |           |         |
|--|--|-----------|---------|
| Certifying Authority: BASEEFA                    |  | Scale     | N/A     |
| Tolerance unless otherwise stated ± N/A          |  | Sheet     | 3 of 3  |
| Title<br>Installation Drawing for the 8230-AI-IS |  | Drng. No. | SCI-941 |