



II 3 G Certificate

1
2

Document number GE10ATEX8510X Issue 2

3 European Community Declaration of Conformity for Group II Category 3 G equipment in
accordance with Directive 94/9/EC.

4 Declaration relating to: 8510-MO-NS Node Services Module

5 Assessed and Manufactured by: GE Intelligent Platforms, 2500 Austin Drive, Charlottesville,
VA 22911, USA.

6 This apparatus fulfils all the requirements for Group II, Category 3 G equipment in accordance
with Directive 94/9/EC. The design complies with EN 60079-11: 2012 & EN 60079-15:2010 (EN
60079-15:2005 for Legacy 'nL' installations). The design is fully documented in GE Intelligent
Platforms Technical File Number TF8510.

7 The apparatus in normal operation is energy-limited, and is designed to be installed and used
in accordance with EN 60079-14:2008 & EN 60079-25: 2010 and installation drawing no. SCI-1530.

8 The required marking of the apparatus is specified in GE Intelligent Platforms Technical File
No TF8510 and includes the distinctive community mark:



9 In addition, the marking includes the CENELEC code Ex ic nL IIC T4. The ic or nL applies
both to the energy-limited Railbus and Carrier connections and to the non-ignition-capable energy and
hot surfaces within the product.

10 The ambient temperature range for the apparatus is -40°C to +70°C.

11 Manufacture is controlled by an ISO9001:2008 approved system, and is externally audited by
CSA and FM.

12 The apparatus meets the ATEX Directive requirements for electromagnetic radiation by
complying with the EMC Directive 2004/108/EC.

13 The standards published in the Official Journal of the European Commission with reference to
the Low Voltage Directive 2006/95/EC have been used to fulfil 1.2.7 of Annex II of directive 94/9/EC
to eliminate electrical risks.

14 Special Conditions of Safe Use

- a. The apparatus must be installed in an enclosure or an environment that provides a degree
of protection not less than IP54 when used in Zone 2.
- b. In order to comply with the transient requirements, the voltage for this apparatus must be
provided by regulated power supply units complying with the requirements of European
Community Directives.
- c. Where the interconnecting cable utilizes part of a multi-core cable containing other
intrinsically safe circuits, then the multi-core cable shall be in accordance with the
requirements of a multi-core cable type A or B, as specified in Clause 9 of IEC 60079-25.
- d. A multi-core cable containing circuits classified as level of protection "ia", "ib" or "ic"
shall not contain non-intrinsically safe circuits.



Srinivas

Srinivas Kodagandla.....
Technology Manager, Quality & Regulatory,
GE Intelligent Platforms,
India Innovation Center, Hyderabad.

Date24th May 2013.....

Revision History

Issue	Date	Remarks
1	23 rd February 2012	First GE Intelligent Platforms issue
2	24 May 2013	CENELEC marking ic added with assessment note in section 6, 7, 9 and section 14. Reference to installation drawing SCI-1530 added in section 7.