



Certificate of Compliance

Certificate: 2019096

Master Contract: 161192

Project: 2660382

Date Issued: November 20, 2013

Issued to: Azonix Corporation

101 Billerica Ave, Bldg 4
Billerica, MA 01862
USA
Attention: John Grega

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Nicholas Cameron

Issued by: Nicholas Cameron

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

Class I, Zone 2, Temperature Code T3

Ex nA IIC T3 IP56 Gc

AEx nA IIC T3 IP56 Gc

Industrial Computer, Model Barracuda WS, P/N E62-US-CANRIG

w/ Optional Keyboard P/N 60-700002

Permanently connected, rated 100-240 V ac, 50/60 Hz, 2.6 A Max

Ambient Operating Temperature: -40°C to 50°C,



Certificate: 2019096

Master Contract: 161192

Project: 2660382

Date Issued: November 20, 2013

Conditions of Certification

1) To be installed in an area with low risk of mechanical impact

CSA C22.2 No. 1010.1 (Ver 2.0) CERTIFICATION REPORT
SUPPLEMENT IS AN INTEGRAL PART OF THIS REPORT

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0-M10 - General Requirements - Canadian Electrical Code Part II.

CAN/CSA-C22.2 No. 61010-1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

CAN/CSA-60079-0:11 - Part 0: General requirements

CAN/CSA-60079-15:12 - Part 15: Type of protection "n"

UL Std. No. 61010-1 (2nd Edition) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

UL Std. No. 60079-0, 5th Edition - Part 0: General requirements

UL Std. No. 60079-15, 4th Edition - Part 15: Type of protection "n"