

9112-NI

FNICO POWER SUPPLIES

IIB / GROUPS C, D

- ◆ **320mA output current:** supports 20 x 15mA fieldbus devices per power supply
- ◆ **Fieldbus repeater** allows connection to an uncertified host
- ◆ **250V ac input/output/power supply isolation**
- ◆ **Switch selectable terminator** on host side
- ◆ **Fixed terminator** on NI side
- ◆ **Switch selectable power** for host side
- ◆ **Mountable in Zone 2/Division 2**

MODULE SPECIFICATION

See also *Common Specification*

OUTPUT

Number of channels

One

Voltage

13.1V (min.) at 25°C (see note)

Design current

0 to 320mA - 60°C max. ambient temperature

Current limit

>340mA

Output ripple

Complies with clause 22.6.2 of the fieldbus standard †

Minimum load

No load

Maximum cable length

Determined by NI load

Isolation

Input to output: 250V ac rms
Input and output to power supply: 250V ac rms

INPUT

Input voltage

20 - 30V dc

Current consumption:

490 mA (typical) 550 mA (max.) at 20V
400 mA (typical) 460 mA (max.) at 24V
320 mA (typical) 370 mA (max.) at 30V

Power dissipation with 320mA field load + 30mA host load:

4.5 W (typical) 6 W (max.)

Input protection

Fuse + supply reversal diode

Note: Temperature coefficient 12mV/°C. If the power supply and fieldbus cable are operated at low temperatures, the reduced resistance of the cable more than compensates for the reduction in output voltage.

Fieldbus Foundation™ and FOUNDATION™ are trademarks of Fieldbus Foundation, Austin, Texas, USA.

† The applicable fieldbus specifications and standards are:
— FOUNDATION™ fieldbus 31.25 kb/s
Physical Layer Profile Specification, document FF-816.
— IEC 61158-2: 2000.
— ISA-S50.02-1992 for 31.25 kb/s fieldbus systems.



SAFETY

Location of module

Safe area, Zone 2, IIB T4 hazardous area or Class 1, Div 2, Groups C, D T4 hazardous location.

Location of field wiring

Zone 2, IIB T4 hazardous area or Class 1, Div 2, Groups C, D T4 hazardous location.

Field wiring protection

Non-incendive

Certification Code

II 3 G EEx nA[L] IIB T4

Safety description

14.8V, 380mA

FM entity parameters

14.8V, 380mA

FM Certificate number

FM3016981

ATEX Certificate number

MTL03ATEX9112X

Certification is compatible with:

IEC60079-27/CDV: 2004

EC Directive 94/9/EC (ATEX100A)

MECHANICAL

Mounting

DIN rail/surface mounting

Module width

42mm

Weight

360g

LED INDICATORS

	OFF	ON
Power (green)	Power fail	Power OK
Fault (red)	Normal	Fault
Host Comm (yellow)	Comms failure	Comms OK
NI Comm (yellow)	Comms failure	Comms OK

The given data is only intended as a product description and should not be regarded as a legal warranty of properties or guarantee. In the interest of further technical developments, we reserve the right to make design changes.



EUROPE (EMEA): +44 (0)1582 723633
enquiry@mtl-inst.com

THE AMERICAS: +1 800 835 7075
csinfo@mtl-inst.com

ASIA-PACIFIC: +65 6 487 7887
sales@mtlsing.com.sg

EPS9000 RevD 010410