



NOTES:  
- Ensure alarm contacts are wired to the correctly numbered terminal for the window number as shown  
- Cable used should be no greater than 2.5mm<sup>2</sup>  
- If annunciator requires more than one PSU, refer to manual for wiring details  
- All external power supplies (Shown as PSU1) MUST comply with EN60950 or UL60950

- The annunciator supply is fused in the SPR Module at 10A T  
- Panel cut-out to be 10mm smaller than the overall  
- Unit depth is 145mm behind panel door  
- Warning labels supports on module may be removed for ease of wiring but must be replaced before the annunciator enters service

						Scale	Material			
						NTS	SEE NOTES			
						Tolerance	Finish			
1	-	DF	-	JC	21 OCT 14	±0.2mm/±2°	SEE NOTES			
0	-	GN	-		15 APR 10					
Issue	Ecr No	Drawn	Chk'd	App'd	Date					

Title	Project	Project Title	
CONNECTION DRAWING FOR TYPICAL P725 ANNUNCIATOR	P725	P725 ALARM ANNUNCIATOR	
	Source	Cross Reference	Drawing Number
			P725