

DA170 Series Intrinsically Safe LED Cluster

Introduction

This manual provides the information necessary to install, connect, test and maintain RTK's intrinsically safe LED cluster lamps

Description

The DA170 range of LED Clusters provides visual on/off indication of process conditions in safe and hazardous areas. Available in six super-bright colours – red, green, yellow, orange, blue and white - they are standard 22.5mm diameter and seal to IP65 to the panel door. All colours are fully current limited and take only 20mA.

The input on all units is non-polarised to prevent damage by reversed supplies. The DA170 also has an optional current by-pass to divert a small amount of current from the cluster.

In hazardous areas it is possible to combine LEDs from a single IS interface, two for IIC interfaces and four with a IIB interface.

The standard LED Cluster can also be supplied fully mounted in stainless steel or polycarbonate boxes ready for immediate mounting on-site.

With the LED's lower power consumption, lower heat dissipation and far greater life expectancy the DA-170 is an ideal standard indicator for safe and hazardous areas alike.

LED Cluster models

Model no.	Colour	Current limited to
DA170-XX	RD,GN, AM, YW, WT, BL	20mA

The XX in the model number is replaced by the following letters to indicate the colour of the cluster lens

RD = Red
GN = Green
AM = Amber
YW = Yellow
WT = White
BL = Blue


IS Interfaces

These units can be used in gas group IIC powered through a 28V 300Ω shunt-diode safety barrier (such as the MTL7728+ unit) or an isolating interface unit (such as MTL5525 model). They include an internal current limiting device, combined with the exceptionally high efficiency of LED's used, enables two clusters to be driven through one barrier/isolator in IIC areas with consequent savings in hardware and plant cabling costs, or four through one interface when limited to IIB applications. Ambient temperature rating is up to 60°C for single and two-cluster installations and up to 40°C for four-cluster (see application configurations)

Installation

General

General assembly details for all models are shown in figure 1.



Required torque level for securing screws is 0.8–1.0Nm

Location

All models can be used in zones 0, 1 and 2 (Equipment categories 1, 2 and 3) hazardous areas and have an external operating temperature range of -20°C to +60°C, except for IIB installations in which four DA170's are driven through one interface when the range is -20°C to +40°C. Light output of the cluster is not seriously affected by cable resistance (see maximum cable parameters)

Operational Conditions and Power Requirements

For installations in IIC hazardous areas, power for the clusters is provided from the safe area through intrinsically safe interface units (eg, MTL 7728+ and MTL5525) from a 24/28V dc supply. Two DA170's clusters can be supplied through one interface unit while, for IIB applications only, up to four clusters can be powered through one interface.

The clusters current consumption is internally regulated to 20mA, thereby avoiding the need for external current limitation – which makes them compatible with different power supplies and simplifies many applications.

When a DA170 is used in a safe area, the power supply voltage should be limited to 14 to 26VDC.


Electrical Certification and Safety

The DA170 clusters are classed as 'simple apparatus' as defined by CENELEC standard EN50014 and can therefore be connected without further certification into any intrinsically safe circuit.

Any number of clusters can be included in one circuit. The category (ia or ib) and the gas group classification (IIC, IIB or IIA) of the circuit remains unchanged.

The temperature classification of the loop is determined by the available power within the loop and the required ambient temperature. For a maximum available power of 1.3W the maximum ambient temperature must not exceed 40°C and for a maximum power of 1.2W must not exceed 60°C.

The front lens, when a cluster is properly installed, is protected to a level of IP65. All models withstand 500V insulation test when conventionally mounted and also meet all other requirements relevant to simple apparatus. The lens is prevented from static build-up by a permanent anti-static coating.



Mounting the clusters

Mounting details are shown in figure 2 and 3. Clusters can be mounted in any instrumentation panel with a thickness up to 6mm

- Punch or drill an appropriate diameter hole in the panel for each cluster. To prevent rotation add a notch detailed below. Note that the centres of the mounting cut-outs must be at least 50mm apart either vertically or horizontally and 30mm in the other direction (without optional label-holders) or 50mm vertically and 30mm horizontally (with label holders) for label to appear above or below lamp
- Separate the mounting collar from the lens unit by twisting the lens unit a quarter turn anticlockwise and pulling the lens unit away from the collar.
- Insert the lens unit into the hole from the front of the panel.
- From the rear of the panel, locate the mounting collar over the lens unit and lock into place by twisting the lens unit a quarter of a turn clockwise.
- Tighten the two fixing screws recessed in the mounting collar to clamp the unit in position.

Figure 2 – LED Cluster Dimensions




Figure 3

Cable connections

Cable connections are made to the terminal block on the rear of each unit. The unit is non-polarised therefore the positive of the power supply can go to any terminal, with the power supply negative going to the other terminal.


Maximum Cable Parameters

The capacitive cable parameters associated with the recommended 28V barrier and isolator interfaces are 0.13µF in IIC and 0.39µF in IIB. This corresponds to approximately 500m and 1.5Km of cable length respectively and hence is not likely to be a problem. The inductive parameters are in all cases sufficiently large to be ignored.

Precise details of cable parameters for the particular interface used can be found in the associated literature

Labeling

For labeling, a DA-658 label holder for interchangeable labels (DA-659) is available (figure 4). The DA-659 labels are provided blank for user engraving. Figure 4 shows the engraving area and the number of characters 2.8mm or 4mm in height that can be engraved on it. During mounting, the label holder is slid onto the back of the lens unit before reconnecting the lens unit to the mounting collar through the panel.



Testing


Warning

For intrinsically safe applications, make sure all testing is carried out according to the appropriate nationally accepted code of practice (eg, BS EN60079 in the UK or recommended practice ISA RP 12.6 in the USA). If fault finding is necessary, make sure permission to carry out the work is granted and/or conform to required company procedures to avoid the possibilities of causing a plant malfunction.

Testing

Clusters can be tested on site or in the workshop, using the following procedure :
 Before testing in hazardous areas make sure the cluster remains connected to its intrinsically safe interface. In safe areas or workshops the voltage applied should be between 14 and 26VDC.
 With a suitably certified multimeter, check that the cluster illuminates under the following conditions. The supply across the two terminals on the cluster is between 14 and 26V while the supply current taken is between 17mA and 23mA.

Application Configurations



Maintenance

Routine Maintenance

The only maintenance required is limited to routine periodic inspection and cleaning.

At monthly intervals (or whenever necessary)

Clean the lens with soap and water. Do not use abrasive substances or solvents to clean the lens.

At six-monthly intervals

Check that the mechanical mounting of the cluster is secure. Check that the cable connections to the cluster are secure

Faulty Units

Apart from the test operations and the maintenance procedures described above, no other repair work can be carried out by the user as there are no replaceable parts in the cluster. Faulty units should be returned to RTK Instruments for investigation and possible replacement.

Specification

Colours

RD = Red, GN = Green, AM = Amber, YW = Yellow,
WT = White, BL = Blue

Power supply requirements (Vin)

Hazardous area use

All models (with an MTL7728 safety barrier) : 22 to 26V
All models (with an MTL5525 isolator) : 20 to 35V

Safe area use

Direct connection : 14 to 26VDC

Current Consumption

20mA (an optional current bypass may increase the current consumption of the unit)

Note: Useful light output from 8mA for all units

Electrical Safety

Non-energy storing simple apparatus. Will not store or generate more than 1.5V, 0.1A, 20 μ J or 25mW when connected to intrinsically safe equipment with a maximum open circuit voltage of not more than 40V.

Ambient Temperature

Working : -40°C to +60°C (matched power to 1.2W)

Working : -40°C to +40°C (matched power to 1.3W)

Storage : -40°C to +70°C

Lifetime

100 000 hours minimum (11 years) continuously energised at 40°C ambient temperature

Humidity

5-95% RH

Casing

Housing/mounting collar : Polyamide 6.6 / reinforced fibreglass FR4

Lens: Polycarbonate (coated with anti-static coating)

Mounting

Panel, up to 6mm thickness, through 22.5mm diameter hole. Notch required to prevent rotation

Connections

Rising clamp screw terminals for cable 0.5mm² to 1.5mm²

Protection

IP65 when panel mounted.

IP20 from the rear.

Accessories


Black label holder (DA-658) with interchangeable label (DA-659)

EMC Compliance

Immunity to EN61000-6-2

Emissions to EN61000-6-4

Standards : CENELEC BS EN50014 & 50020 & 50284

Approved for : Ex ia IIC T4 Ga  II 1 G

Certificate No : BAS02ATEX1311

Safety Parameters:

Ui = 40V

Pi = 1.2W (max ambient temp. = 60°C)

Pi = 1.3W (max ambient temp. = 40°C)

Ci = Li = 0

The device can be powered from an EEx ia IIC certified interface with output parameters lower than those shown above

Due to our policy of continuous product development, we reserve the right to amend these specifications without notice.

EC DECLARATION OF CONFORMITY

This is to certify that the DA170 LED Clusters


Manufactured by:-

**RTK INSTRUMENTS LTD
ST JAMES BUSINESS PARK
KNARESBOROUGH
NORTH YORKSHIRE
HG5 8PJ**

Conforms to the protection requirements of the following directives:

- Council directive 89/336/EEC (EMC Directive) to BS EN 61000-6-4 and BS EN 61000-6-2
- Council Directive 94/9/EC (ATEX Directive) to EN60079-0:2009 and EN60079-11:2007

The product is certified to:

Ex ia IIC T4 Ga (-20°C ≤ Ta ≤ +40°C/+40°C)  II 1 G

Certificate No: BAS02ATEX1311

The Quality System is certified and monitored by Baseefa Ltd, notified Body number 1180, Rockhead Business Park, Staden Lane, Buxton, Derbyshire, SK17 9RZ.



.....
PAUL HARTLEY - MANAGING DIRECTOR

Date: 21st June 2011

REV	Detail of Change	Date
0	Original Issue	
1	Changed to new RTK Instruments format	27/10/04
2	Various changes	Dec 2005
3	Changed to DA170 type with single lens type, DA*171 and DA*172 removed	Sep 2006
4	Addition of safety parameters	May 2007
5	Tolerance change on cut out diagram	July 2007
6	EC Declaration added	May 2008
7	MTL Barrier and Isolator details added	July 2009
8	Baseefa notified body number added and declaration updated	Dec 2009
9	Declaration amended following Baseefa certificate re-issue	June 2011
10	Recommended torque level added to Installation	Nov 2011